

FINAL REPORT

PROJECT A-2180

**CIRCULATING FIREPLACE
COMBUSTION EFFICIENCY STUDIES**

By

**H.T. Ghaffari
W.S. Bulpitt**

Prepared for

**The Department of Energy
July 1, 1978 to July 1, 1979**

July, 1979

GEORGIA INSTITUTE OF TECHNOLOGY

**Engineering Experiment Station
Atlanta, Georgia 30332**



1979



PROJECT A-2180

CIRCULATING FIREPLACE
COMBUSTION EFFICIENCY STUDIES

FINAL REPORT TO
The Department of Energy
July 1, 1978 to July 1, 1979

Prepared by:

H. T. Ghaffari
W. S. Bulpitt

GEORGIA INSTITUTE OF TECHNOLOGY
Engineering Experiment Station
Technology & Development Laboratory
Atlanta, Georgia 30332

July 7, 1979

TABLE OF CONTENTS

	SUMMARY	iii
	TEXT NOMENCLATURE	iv
I.	INTRODUCTION AND BACKGROUND	1
II.	EXPERIMENTAL APPARATUS AND INSTRUMENTATION	4
III.	FIREPLACE TEST PROCEDURES	11
IV.	ANALYSIS	15
V.	TEST PLAN AND TEST RESULTS	24
VI.	CONCLUSIONS AND RECOMMENDATIONS	43
VII.	REFERENCES	47
	APPENDIX A: COMPUTER PROGRAM FLOW CHART, LISTING AND NOMENCLATURE	A-1
	APPENDIX B: COMPUTER ANALYSIS DATA SHEETS	B-1
	APPENDIX C: HEATING VALUE TEST RESULTS	C-1

SUMMARY

This paper represents the final report on a series of tests performed at Georgia Tech to assess the performance of circulating fireplaces. The test program was funded jointly by the Teague Brick Sales Company of Tyler, Texas and the Fossil Fuel Utilization Division of the Department of Energy.

A factory-built fireplace was installed in a well insulated calorimeter room on the Georgia Tech campus and subjected to more than thirty wood firing tests to determine the thermal efficiency and net heat output of the fireplace under varying conditions. Parameters that were investigated included variations in fuel firing rate, the use of glass doors, the use of different forms of fuel, the use of different heat exchange flow rates, and the use of circulating fans.

Results indicated that the fireplace as tested could perform with a thermal efficiency of 3% to 33% depending upon the operational configuration. The overall average of the test efficiencies was 15.7%. It was determined that having glass doors open during a well established fire resulted in significantly higher heat transfer to the room. In addition, the use of circulating features (including electric fans) were shown to offer a significant increase in fireplace efficiency.

Included in this report are a description of the test facilities and associated instrumentation, a description of the test program, a description of the analysis methods (including a computer program) for reducing the data, and a discussion of conclusions.

TEXT NOMENCLATURE

SYMBOLS

C	Carbon
CO	Carbon monoxide
CO ₂	Carbon dioxide
C _p	Specific heat coefficient (Btu/lbm -°F)
E	Electricity usage (Btu/hr)
h	Enthalpy (Btu/lbm)
HHV	Higher heating value (Btu/lbm)
H ₂ O	Water
KWH	Kilowatt hour
LHV	Lower heating value (Rtu/lbm)
O	Oxygen
q	Heat rate (Btu/min)
T	Temperature (°F)
w	Work (Btu/min)

GREEK LETTERS

η	Efficiency
ρ	Density (lbm/ft ³)
ω	Specific humidity ratio

SUBSCRIPTS

ae	Air exit
ai	Air inlet

SUBSCRIPTS (Continued)

ai_1	Indirect for combustion
ai_2	Direct for combustion
am	Air moisture
c	Combustion
ca	Combustion air
CO	Carbon monoxide
dfg	Dry flue gas
e	Electricity
e_1	Part of the fireplace being tested
e_2	Not part of the fireplace being tested
f	Fuel
fm	Fuel moisture
H	High
H_2	Hydrogen
in	Input
l	Leakage
L	Low, lab
NH	Net heat output
r	Calorimeter room
uc	Uncombustibles

SUPERSCRIPITS

\therefore	Time rate (1/min)
--------------	-------------------

I. INTRODUCTION AND BACKGROUND

Wood as an energy source has realized renewed interest since the Arab oil embargo of 1973, and this trend shows no signs of letting up, especially when the effect on the price of home heating oil that the latest series of OPEC price increases will have is considered. Early in the history of our nation, wood supplied most of the energy for cooking and residential heating, and even today it has been estimated that 1/3 of the residences in the world are still heated with wood (1).

In terms of tons per year, most of the wood used in the U.S. today is used by the forest products industries for the production of building materials, pulp and paper, and chemicals. There is also a growing trend toward the use of wood as an industrial energy source as well as for residential heating, since there are certain advantages to burning wood. One advantage in certain installations is fuel costs, and another may be less severe environmental effects since wood contains only small amounts of sulfur. Particulate emissions from wood burning sources can create environmental problems but these can be controlled relatively easily with existing technologies. Wood is a complex fuel, however, and there is growing concern by some parties that trace elements may create environmental problems, particularly in areas where air pollution episodes have resulted from the concentrated use of residential wood heaters. The emissions of interest appear to be polycyclic organic materials (POMS) and studies have recently been started on these compounds (2). Other compounds found in wood smoke which may eventually be of interest environmentally are shown in Table 1.

Due to the recent upsurge in sales of wood heaters and fireplaces, there has been renewed interest in the real value of these appliances for providing space heating. Many new manufacturers have entered this field and some are making irresponsible claims for their products. There has been a demonstrated need for recognized testing procedures and it is in this regard that the test program described in this paper was undertaken. Many studies on the value of fireplaces have been done in the past, and the work of Konzo and Harris is one of the better known publications on total (uncontrolled) operating cycles (4). Controlled environments such as calorimeter rooms have been used for several years in the testing of HVAC devices such as

air conditioners, and more recently similar techniques have been used to test wood burners (5). Along these lines the Engineering Experiment Station at Georgia Tech was approached by a private contractor, Teague Brick Sales, to perform some basic tests on factory built fireplaces which were of interest to that company. In connection with this work a grant was awarded by the Department of Energy to perform some additional work that would be of interest to that agency. During this time frame, the Fireplace Institute, a manufacturers' organization, published a suggested method for rating fireplaces (7,8,9) and contracted with Auburn University to perform standardized rating tests on products built by member companies. The testing methods used by Georgia Tech and the methods advocated by the Fireplace Institute are similar in some respects, although the objective of this program is not to perform exhaustive tests on a wide range of wood heaters, but rather to carry out enough tests to make some basic judgments on the value of fireplaces as a heating medium. Other methods of arriving at similar conclusions for uncontrolled operating systems have recently been described by Sonderegger, et al (6), and further information on the Fireplace Institute programs for controlled steady state cycles can be found in publications by Maxwell, et al (10).

The remaining sections of this paper describe the fireplace test program performed at Georgia Tech. Descriptions of the apparatus and methods used are included, and conclusions based on the data collected are drawn.

TABLE 1: COMPOUNDS DETECTED IN HARDWOOD SMOKE
(from Reference 3)

ACIDS	HYDROCARBONS	PHENOLS(continued)
Formic	3,4-Benzpyrene	1,3-Demethyl Pyrogallol
Acetic	1,2,5,6-Dibenzanthracene	derivatives
Propionic	20-Methylcholanthrene	5-Methyl
Butyric	PHENOLS	5-Ethyl
Aconitic?	Cresols	5-Propyl
Tricarballic?	Creosol	1-0-Methyl-5-Methyl Pyrogallol
Ketoglutaric?	Guaiacol	Veratrole
ALCOHOLS	Guaiacol derivatives	Xylenols
Methanol	4-Ethyl	OTHERS
Ethanol	4-Propyl	Ammonia
CARBONYLS	6-Methyl	Carbon dioxide
Formaldehyde	6-Ethyl	Resins
Acetaldehyde	6-Propyl	Water
Acetone	Pyrogallol ethers	Waxes
Diacetyl	1-0-Methyl	
Furfural	1,3-Dimethyl	
Methyl Furfural		

II. EXPERIMENTAL APPARATUS AND INSTRUMENTATION

For this test program a well insulated fireplace calorimeter room was constructed within an existing concrete-block building on the Georgia Tech campus. The interior dimensions of the room are approximately 10 feet by 8 feet by 8 feet tall. The walls are constructed of 4 inch wood studs on 12 inch centers which are staggered alternately from the inside to the outside of 6 inch sills and plates. The insulation consists of woven fiberglass batts 4 inches thick which are woven through the studs. The inside and outside walls are gypsum wallboard and 3/4 inch thick styrofoam insulation is used between the studs and the inside layer of wallboard. One three foot access door is provided and this door is also insulated with fiberglass and styrofoam.

In the rear center portion of the room a modified circulating fireplace is installed on a poured concrete foundation. The basic design of the factory built fireplace is shown in Figure 1. The basic fireplace has been modified by the addition of a false floor allowing a three inch wide combustion air passage to be provided at the front of the combustion chamber. The combustion air is supplied by a rectangular sheet metal duct fitted to the rear of the fireplace shell. In addition, another duct has been cut through the rear of the shell to provide combustion air to the rear of the combustion chamber.

The steel fireplace was surrounded with standard masonry bricks giving a structure with dimensions of approximately 5' 1½" by 2' 10¼" by 4' 11". Side cool air inlets and a front warm air outlet are provided as shown in Figure 1. A standard triple wall flue pipe is provided at the top of the fireplace and passes through the roof of the calorimeter room and through the roof of the building.

The cool air inlets can be left open or closed, and in addition can be operated with two small circulating fans which are rated at 34.5 watts each. The fans force room air through the double shell of the fireplace and through a pipe heat exchanger which passes through the fireplace flue. This air then exits the fireplace structure through a warm air grille, which can be left open or easily blocked off to restrict convection.

The fireplace front opening is approximately 3 feet by 2 feet and is covered by a standard accessory glass door which can be opened or closed as




FIGURE 1. CIRCULATING FIREPLACE CONSTRUCTION
(COURTESY SUPERIOR FIREPLACE COMPANY)

desired. The fireplace is also equipped with a conventional damper which can be opened or closed as necessary. The hearth area is trapezoidal in shape with widths of 35" and 31.5" at the front and rear, respectively, and the firebox is 16.5" deep.

With the above modifications the fireplace can be provided with combustion air in one of three modes. Combustion air can be provided directly through the front fireplace opening or it can be ducted as "outside combustion air" to the front or rear of the hearth. A duct of approximate dimensions of 8½" by 4" is provided for the outside air and this duct is about ten feet in length. Due to the reinforced concrete construction of the building, the only available opening in the building wall for the duct to pass through was well above the hearth level, and this detail may have complicated the mechanics of the air introduction, as will be discussed later.

The overall concept of the facility is similar to the "calibrated room calorimeter" as described by the Fireplace Institute (FI) in their Standards (7,8,9). Due to the level of funding in this program and the time constraints involved in the construction (this project was started before the FI standard was published) no effort was made to duplicate the FI standard exactly.

The amount of heat provided by the fireplace to the calorimeter room is determined by using the room itself as a heat exchanger. Supply and exhaust ducts and fans are provided for this purpose as shown in Figure 2. The inlet and outlet fans are identical and are powered with ¾ horsepower motors. The inlet and outlet ducts have dimensions of 16" by 16" and the fan flow rates are controlled by adjustable dampers. Inlet and outlet flows are measured with Cambridge flow measuring stations. These are standard HVAC type devices and consist of a series of manifolded pitot tubes in a flow straightening section. Each flow measuring station is provided with its own stationary inclined manometer which is calibrated by the manufacturer. Flue gas velocity is measured with an "S-Type" pitot tube located in the stack, and velocity head is read with a portable inclined manometer. This pitot tube and manometer were calibrated at Georgia Tech using a low speed wind tunnel. An additional manometer was used to measure the pressure differential between the inside and outside of the calorimeter room (this was necessary for setting fan dampers).

Various temperature measurements were required during the tests, and these

were indicated by iron/constantan J type thermocouples using glass insulation. The readings of these various sensors are recorded with a fifteen channel key programmable data acquisition system manufactured by Esterline Angus. Locations of the thermocouples of interest will be discussed more fully in the next section and these locations are shown in Figures 2 and 3.

The fuel used for the majority of the tests in this program was wood brands made from standard builder grade #3 Douglas fir (cut to 3/4" by 3/4"), as recommended by the Fireplace Institute and Under-writers Laboratories (7). An illustration of a typical brand is included in Figure 4. In some of the tests, pine and oak logs were used. Preparation of the wood included kiln drying in a laboratory oven to 0% moisture content at approximately 220°F. Measuring the amount of time necessary to obtain no further weight loss indicated that 24 hours drying time was sufficient to obtain "bone dry" wood. The weight of logs and brands was determined using a 0 to 3000 g balance. Heating values of representative wood samples were determined in the laboratory using bomb calorimeter tests.

Relative humidities of the calorimeter room and the surrounding environment were determined using a sling psychrometer. Gaseous constituents of the fireplace flue gases were determined in some of the tests using an Orsat gas analyzer, although it was quickly determined that these results were not always reliable.




FIGURE 2
 FIREPLACE CALORIMETER SYSTEM
 (PLAN VIEW)




FIGURE 3
FIREPLACE CALORIMETER SYSTEM
(SIDE VIEW)




FIGURE 4. TYPICAL FIREPLACE WOOD BRANDS

III. FIREPLACE TEST PROCEDURES

The calorimeter room air circulation system could be adjusted over a wide range of flow rates and part of the test program was devoted to the determination of the flow conditions which produced acceptable tests. A series of flow rate tests yielded the following data:

<u>CONDITION</u>	<u>INLET AIR FLOW</u>	<u>OUTLET AIR FLOW</u>
I (Dampers 1/4 Open)	900 CFM (Approx. 67.5 lbm/min)	600 CFM (Approx. 43.2 lbm/min)
II (Dampers 1/2 Open)	1400 CFM (Approx. 105 lbm/min)	1300 CFM (Approx. 93.6 lbm/min)
III (Dampers 3/4 Open)	1900 CFM (Approx. 142.5 lbm/min)	1800 CFM (Approx. 129.6 lbm/min)

These air flows remain quite stable during the testing period and are not appreciably affected by the temperature rise of the calorimeter room. A series of tests were run at each air flow setting and it was determined that Condition II was the optimum configuration. Condition I resulted in test conditions that were uncomfortable for the test personnel and Condition III resulted in excessive turbulence in the room. Since a constant comfortable temperature range could not be maintained in the room with the equipment available, it was found that the inside room temperature could rise to as high as 130°F during the course of a test, which caused discomfort to test personnel, particularly when a fire showed any tendency to generate smoke. The lower flow rates did not allow enough fresh air to enter the room to permit the tester to remain reasonably comfortable by remaining near the inlet duct. On the other hand, the higher flow rates seemed to produce too much turbulence in the room even though deflector baffles were always placed between the inlet air and the fireplace. Under this condition, it was sometimes difficult to maintain a stable fire. For these reasons, Condition II was used most often for testing.

The pressure differential between the inside of the calorimeter and the surrounding building could be readily changed by varying the control settings for the inlet and outlet fans. It was attempted to maintain a

slightly negative pressure ($-0.015'' \text{ H}_2\text{O}$) in the calorimeter room to simulate a typical house, but sometimes this pressure setting had to be changed slightly to alleviate a smoking condition.

A typical test required several hours to complete, in addition to several hours of preparation which were devoted mostly to the making of brands and instrument calibration. Before test data was actually taken, the fireplace was "warmed up" using wood scraps or ordinary logs to maintain a fire. The door was kept closed as much as possible during this time in an attempt to achieve a steady state condition. During the warmup period, manometers were calibrated, test brands were removed from the oven, weighed, and placed in the calorimeter, and velocity measurement equipment was checked. This step included the cleaning of soot deposits from the pitot tube used to measure flue gas velocities. Temperature readouts were checked and if false readings were obtained, thermocouples were replaced. New thermocouples were checked for correct readings on the data acquisition system using an ice water bath.

Attempts were made early in the test program to measure the flow rates of the fireplace when an outside air source was used, but these efforts were not entirely successful due to the low duct velocities. A standard pitot tube was used at first, but was not sensitive enough for the low flows. It appears that a hot wire anemometer or laminar flow elements might have produced more acceptable data, but the purchase of this equipment was not within the budget. Further test programs may result in improvements for this area of the instrumentation.

The thermocouples used for monitoring temperatures during the tests included three in the calorimeter room, three within the hearth of the fireplace, one in each of the air flow measuring stations for the inlet and outlet air supply, one in the center of the flue pipe, two in the surrounding building, one in each of the combustion air supply ducts, and an additional thermocouple to determine outside air temperature. Radiation shields were provided for the thermocouples located over the hearth. Temperatures were recorded during the course of a test at seven minute intervals.

Leakage of heat from the calorimeter room was estimated using electric heaters. The heaters were placed inside the calorimeter room (with no fire present), the various inlet and outlet ducts were sealed off (and the fireplace damper was closed) and the electrical input was monitored for two hours using a kilowatt-hour meter. This energy usage was converted to Btu's and divided by temperature difference and time to obtain a heat leakage factor having the units of Btu/⁰F-minute.

Three different sizes of brands were made for the majority of the tests, giving weight differentials of about 3%. The weights for each brand category were 1.32 lb, 1.68 lb, and 2.10 lb. The burning of three sets of brand sizes during a test provided an indication of efficiency differences with firing rates. As mentioned, all brands were kiln dried to constant weight for at least 24 hours to provide a more consistent, repeatable fuel supply.

Relative humidity recordings were made during tests inside the calorimeter room, in the surrounding building, and outside the building.

During the course of most of the fireplace tests, flue gas samples were analyzed with an Orsat gas analyzer. Gas samples were withdrawn from the flue with a hand pump and analyzed for carbon dioxide (CO₂), carbon monoxide (CO), and oxygen (O₂). This analysis was normally performed at least once during the burning of each weight category of brands. Results of Orsat analyses were not always consistent due to grab samples being taken at random points during the "firing cycle" of a given brand, and these results indicated the need for continuous monitoring instruments if more detailed gas analysis is to be done in the future.

To review the procedure for a typical fireplace test, the following sequence of events normally occurred:

1. Warmup period - logs and scrap wood (1 to 2 hours)
2. Setting of air handling equipment, entry of personnel to calorimeter, closing of door
3. Commencement of test - one brand added every six minutes. Temperature data recorded every seven minutes, Orsat analysis carried out during different size category series.

4. Completion of test

Most tests consumed 21 brands, 7 each in each of the weight categories. A new brand was introduced to the hearth every six minutes, and thus a total test duration of approximately 126 minutes resulted. Due to space limitations in the calorimeter room, most tests were performed by one person. Acquisition of temperature data was automatic, and the tester's primary responsibilities included firetending and recording of velocity measurements and Orsat data, and the timing of events. An entire test from start to finish including warmup and shutdown usually required approximately four hours.

IV. ANALYSIS

The overall object of this test program is to determine the thermal efficiency of circulating fireplaces under a variety of steady state controlled test conditions. The thermal efficiency could be defined as the percentage of useful heat obtained from the burning of wood in the fireplace. This efficiency can be measured by several methods, as can be done with other heat generating devices such as steam boilers. This evaluation can be done by considering the ratio of the heat gained by the calorimeter room to the heat input to the room, or by considering a comparison of heat input with known heat losses. These methods will be considered in greater detail below.

If we consider a control volume containing the calorimeter room and its associated hardware, the energy input consists of the energy of the wood fuel plus any other form of energy (e.g. electricity) introduced into the control volume. The energy released by wood is evaluated by multiplying the mass rate of wood addition to the fire, \dot{m}_f , by the higher heating value (HHV)¹ of the wood:

$$q_f = (\dot{m}_f)(\text{HHV}) \text{ Btu/min} \quad (1)$$

Electrical energy input to the control volume (e.g. lights and circulating fans) is represented by E_{in} in kilowatts (KW) and converted to Btu/min by the proper conversion factor:

$$q_e = (56.9)(\Sigma E_{in}) \text{ Btu/min} \quad (2)$$

The total energy input to the system can thus be represented by q_H as in the following:

$$q_H = q_f + q_e \text{ Btu/min} \quad (3)$$

¹An expanded discussion of heating value conventions will be included in Section V.

Let us now consider a control volume as shown in Figure 5.




FIGURE 5. CONTROL VOLUME

The mass balance for this control volume will be as follows:

$$\Sigma \dot{m} = 0$$

$$\Sigma \dot{m}_e - \Sigma \dot{m}_i = 0 \quad (4)$$

$$(\dot{m}_{ae} + \dot{m}_{dfg}) - (\dot{m}_{ai} + \dot{m}_{ai2}) = 0 \quad (5)$$

where

\dot{m}_{ae} = mass flow of air exiting control volume through duct system

\dot{m}_{dfg} = mass flow of flue gas leaving stack

\dot{m}_{ai} = mass flow of air entering control volume through duct system

\dot{m}_{ai2} = mass flow of air to fire through combustion air system (if used)

An energy balance can now be made on the control volume as follows:

$$q + w = \sum \dot{m}_e h_e - \sum \dot{m}_i h_i \quad (6)$$

OR

$$q + w = q_H - q_L \quad (7)$$

where

q_H = energy input to the system

q_L = heat losses from the system

Then

$$q_H - q_L = (\dot{m}_{ae} h_{ae} + \dot{m}_{dfg} h_{dfg}) - (\dot{m}_{ai} h_{ai} + \dot{m}_{ai_2} h_{ai_2}) \quad (8)$$

Where the h values represent the fluid enthalpies for the flow rates of interest.

Then

$$q_H - q_L = (q_f + q_{e_1} + q_{e_2}) - (q_{H_2} + q_{co} + q_{am} + q_{fm} + q_{uc} + q_l) \quad (9)$$

where

q_{e_1} = electricity input to fireplace

q_{e_2} = other electricity input to control volume

q_{H_2} = heat loss due to endothermic combustion of hydrogen

- q_{co} = heat loss due to incomplete burning of carbon
 q_{am} = heat loss due to moisture in air
 q_{fm} = heat loss due to moisture in fuel
 q_{uc} = heat loss due to uncombusted material in ash
 q_l = heat loss due to leakage through calorimeter walls

OR

$$\begin{aligned}
 q_H - q_L = & (\dot{m}_{ae} C_{p_{ae}} T_{ae} + \dot{m}_{dfg} C_{p_{dfg}} T_{dfg}) - (\dot{m}_{ai} C_{p_{ai}} T_{ai} + \dot{m}_{ai_2} C_{p_{ai_2}} T_{ai_2}) \\
 & + (-\dot{m}_{ae} - \dot{m}_{dfg} + \dot{m}_{ai} + \dot{m}_{ai_2}) C_P T_r
 \end{aligned} \quad (10)$$

Where the last term represents zero, and the various C_p 's designate specific heats, while the T 's represent corresponding temperatures.

Manipulating the last term above and neglecting minor changes in specific heats, yields the following

$$\begin{aligned}
 q_H - q_L = & \dot{m}_{ae} C_{p_{ae}} T_{ae} + \dot{m}_{dfg} C_{p_{dfg}} (T_{dfg} - T_r) - (\dot{m}_{ae} + \dot{m}_{ai} - \dot{m}_{ae}) C_{p_{ai}} T_{ai} \\
 & - \dot{m}_{ai_2} C_{p_{ai_2}} (T_{ai_2} - T_r) + (-\dot{m}_{ae} + \dot{m}_{ai}) C_P T_r \\
 = & \dot{m}_{ae} C_{p_{ae}} (T_{ae} - T_{ai}) + \dot{m}_{dfg} C_{p_{dfg}} (T_{dfg} - T_r) \\
 & - (\dot{m}_{ai} - \dot{m}_{ae}) C_{p_{ai}} (T_{ai} - T_r) - \dot{m}_{ae} C_{p_{ai_2}} (T_{ai_2} - T_r)
 \end{aligned} \quad (11)$$

If we define $(\dot{m}_{ai} - \dot{m}_{ae})$ to be \dot{m}_{ai_1} , the combustion air supplied by the inlet fan, then

$$q_H - q_L = q_{ae} + q_{dfg} - q_{ai_1} - q_{ai_2} \quad (12)$$

Equating the above with an earlier definition gives

$$(q_f + q_{e_1} + q_{e_2}) - (q_{H_2} + q_{co} + q_{am} + q_{fm} + q_{uc} + q_\ell) = q_{ae} + q_{dfg} - q_{ai_1} - q_{ai_2} \quad (13)$$

If we consider the q_{dfg} to be a loss (heat carried out by the flue gas) we can arrange the equation as follows

$$q_f - (q_{H_2} + q_{co} + q_{am} + q_{fm} + q_{uc}) - q_{dfg} = q_{ae} + q_\ell + q_{ai_1} - q_{ai_2} - q_{e_1} - q_{e_2} \quad (14)$$

In this equation, q_ℓ is considered an unavoidable loss due to the construction of the calorimeter and thus is separated from the combustion losses.

We can then define q_{NH} to be the net heat generated by the system. This value is equal to the heat contained in the fuel minus the heat losses OR

$$q_{NH} = q_f - (q_{H_2} + q_{co} + q_{am} + q_{fm} + q_{uc}) - q_{dfg} \quad (15)$$

but we have seen from (14) above that this is also equal to

$$q_{NH} = q_{ae} + q_\ell - q_{ai_1} - q_{ai_2} - q_{e_1} - q_{e_2} \quad (16)$$

This gives two independent solutions for the net heat generated by the fireplace. Equation (16) above can be called the direct method and is analogous to determining the heat content of the steam produced by a boiler

minus the heat contained in the feedwater. The thermal efficiency of the system can then be defined by

$$\eta = \frac{q_{NH}}{q_f} = \frac{q_{ae} + q_\ell - q_{ai_1} - q_{ai_2} - q_{e_1} - q_{e_2}}{q_f} \quad (17)$$

Equation (15) above can be called the indirect or direct method or heat loss method and provides a check on the first method when continuous gas monitoring equipment is available.

Let us consider equation (16) again

$$q_{NH} = q_{ae} + q_\ell - q_{ai_1} - q_{ai_2} - q_{e_1} - q_{e_2}$$

The terms of this equation can be considered in more detail

$$q_{ae} = \dot{m}_{ae} C_P (T_{ae} - T_{ai}) \quad (18)$$

which represents the heat gained by the duct heat exchanging system

$$q_\ell = \left(\frac{2.0}{20}\right) \left(\frac{3413}{120}\right) (T_r - T_L) \text{ Btu/min}$$

This equation was determined by investigating the calorimeter room heat loss with electric heaters, by maintaining a 20°F temperature difference between the average temperature in the room (T_r), and the temperature in the laboratory surrounding the calorimeter (T_L), for a period of two hours.

$$q_{ai_1} = (\dot{m}_{ai} - \dot{m}_{ae}) C_P (T_{ai} - T_r) \quad (19)$$

This expression represents the indirect combustion heat flow

$$q_{ai_2} = \dot{m}_{ai_2} C_P (T_c - T_r) \quad (20)$$

Where T_c = measured temperature of combustion air. This results in the more complete equation

$$q_{NH} = \dot{m}_{ae} C_p (T_{ae} - T_{ai}) - \left(\frac{2.0}{20}\right) \left(\frac{3413}{120}\right) (T_r - T_L) - (\dot{m}_{ai_1} - \dot{m}_{ae}) C_p (T_{ai_1} - T_r) \\ - \dot{m}_{ai_2} C_p (T_c - T_r) - q_{e_1} - q_{e_2} \quad (21)$$

Where q_{e_1} and q_{e_2} vary depending upon the input electrical loads of the fireplace lab and its appliances.

Let us now look more closely at equation (15) again

$$q_{NH} = q_f - (q_{H_2} + q_{co} + q_{am} + q_{fm} + q_{uc}) - q_{dfg}$$

The terms in this equation can now be considered in greater detail. The heat loss due to the combustion of hydrogen can be defined as follows (8)

$$q_{H_2} = 8.933 \dot{m}_{H_2} (1090.7 - T_f + 0.455 T_{dfg}) \quad (22)$$

where

$$\dot{m}_{H_2} = \text{mass rate of burning of hydrogen in fuel}$$

$$T_{dfg} = \text{temperature of dry flue gas}$$

$$T_f = \text{temperature of fuel}$$

Moisture in the air used for combustion causes another heat loss which may be defined as follows

$$q_{am} = 0.444 \dot{m}_{ca} \omega (T_{dfg} - T_r) \quad (23)$$

where

\dot{m}_{ca} = mass flow rate of air being used for combustion

ω = specific humidity ratio

The effect of heat absorption by incomplete burning of carbon and the production of carbon monoxide would be

$$q_{co} = \left[\frac{(10160)(\%CO)_{dfg}(\%C)_f}{(\%CO_2)_{dfg} + (\%CO)_{dfg}} \right] \left[1 - (\%H_2O)_f \right] \dot{m}_f \quad (24)$$

The percentages of the flue gas constituents are measured with gas analysis equipment such as Orsats.

The higher heating value of the uncombusted materials (ash and unburned carbon) can be evaluated directly by the bomb calorimeter methods, and multiplied by the mass rate of production of uncombustible materials to obtain the heat loss due to uncombustibles

$$q_{uc} = (HHV)_{uc} \dot{m}_{uc} \quad (25)$$

The moisture content of the fuel would have an adverse effect on the useful heat produced

$$q_{fm} = \dot{m}_f (\%H_2O)_f (1090.7 - T_f + 0.455 T_{dfg}) / 100 \quad (26)$$

The effect of wood moisture is not pertinent to this test program since all of the fuel was kiln dried before each test.

Finally, the heat lost to the flue gas can be evaluated by

$$q_{dfg} = \dot{m}_{dfg} C_{p_{dfg}} (T_{dfg} - T_r) \quad (27)$$

Substituting the foregoing equations into equation (15) will yield the basic expression for the heat loss method.

Equation (16) for analysis of the direct method was used most extensively during this test program since the terms in the equation could be measured more readily with the instruments available. The terms in the heat loss equation (15) could only be estimated at best, largely due to the fact that continuous monitoring gas sampling equipment was not available for hydrogen content (although this percentage could be estimated from the literature without introducing a large error). The amount of uncombustibles was also impossible to determine for every test, since the scope of the program did not allow for analysis of ash samples for each test. Weighing of the total ash collected would also be a difficult matter. There is some question as to the validity of an indirect heat method due to the normal levels of excess air found in a typical fireplace. If continuous monitoring instruments had been available to maintain records of the levels of CO_1 , CO_2 , and O_2 in the stack and gas chromatographs had been used to measure the other smoke constituents, this questions could have been answered more completely.

A computer program was written to analyze the test data collected. A flow chart and listing of this program are included in Appendix A. While the program shows the analysis of efficiency utilizing both the direct method and the heat loss method, the results reported in the next section are based upon the direct methods since the data for the heat loss method were impossible to collect for all tests.

V. TEST PLAN AND TEST RESULTS

A comprehensive test plan was drawn up at the beginning of the program to ensure that the performance of a circulating fireplace could be adequately determined and that the effects of hardware changes and operational changes could be assessed. The results of thirty-two (32) of these controlled steady state tests are presented in Table 2. A careful examination of this table will reveal the parameters of interest which were carried through the test program.

The first column identifies the test by number. All tests are not in numerical order, but are placed in a logical sequence to group the data by test categories. Those test numbers that are missing were normally used for equipment checkout and the test numbers followed by "A" normally indicate a repeat of a previous test which yielded incomplete data.

The second column indicates the test setup airflow setting, an equipment variable which has already been discussed. The third column indicates the source of the combustion air used for the fire. "Room" indicates that the air was drawn from the room itself, through the open glass door (if the door was open) or through the vents provided by the door manufacturer around the glass doors (if the door was closed). These could be manually opened and closed, and sealing in the closed position was not completely positive. The amount of possible leakage through the glass doors was impossible to determine. "Front" air indicates combustion air was allowed to enter the fireplace from outside the calorimeter room and this air was introduced at the front of the hearth. "Rear" air indicates that combustion air entered the fireplace at the rear of the hearth. In some of the tests, the glass doors remained open and combustion air was supplied both from the room itself and through the auxiliary ducts. Due to the lack of sensitive instrumentation for the measurement of outside air velocities, exact estimates of the percentages of combustion air provided from the outside source could not be determined.

The "Glass Door" column is self-explanatory. The "Circulation" column indicates whether the fireplace convective passages were open or closed. When the passages were open, air could be drawn in from the room and circulated through the flue gas heat exchanger (under free or forced convection)

TABLE 2: FIREPLACE TEST DATA SUMMARY

Test	Airflow Setting	Combustion Air Supply	Glass Door	Cir.	Fans	(Btu/hr) $\frac{Q_{f1}}{Q_{NH1}}$	Eff ₁	(Btu/hr) $\frac{Q_{f2}}{Q_{NH2}}$	Eff ₂	(Btu/hr) $\frac{Q_{f3}}{Q_{NH3}}$	Eff ₃	(Btu/hr) $\frac{Q_{fAvg}}{Q_{NHAvg}}$	Eff _{Avg}	Comments
13	I	Room	OPEN	OPEN	NONE	107,018 31,396	0.29	139,659 48,191	0.35	175,964 59,620	0.34	140,880 46,402	0.33	↑ LOW FLOW FREE CONV.
9A	I	Rear	OPEN	OPEN	NONE	107,545 29,477	0.27	140,555 42,918	0.31	175,938 54,878	0.31	141,346 42,424	0.30	
11	I	Front	OPEN	OPEN	NONE	108,600 16,581	0.15	142,533 36,918	0.26	177,388 46,785	0.26	142,840 33,428	0.23	
14	I	Room	CLOSED	OPEN	NONE	108,363 26,493	0.24	140,371 36,846	0.26	174,040 43,636	0.25	140,924 35,658	0.25	
10	I	Rear	CLOSED	OPEN	NONE	109,681 10,374	0.09	142,032 18,923	0.13	178,759 27,439	0.15	143,491 18,912	0.13	↓ NORMAL FLOW FREE CONV.
12	I	Front	CLOSED	OPEN	NONE	111,922 8,598	0.08	145,512 24,186	0.17	181,316 35,375	0.20	146,250 22,720	0.15	
4A	II	Room	OPEN	OPEN	NONE	111,421 12,546	0.11	142,295 29,089	0.20	176,966 37,337	0.21	143,561 26,324	0.18	
6	II	Rear	OPEN	OPEN	NONE	109,787 21,366	0.19	141,953 28,248	0.20	176,202 35,750	0.20	142,647 28,455	0.20	
7	II	Front	OPEN	OPEN	NONE	110,841 16,389	0.15	143,086 25,518	0.18	179,392 33,424	0.19	144,440 25,110	0.17	↓
15	II	Room	CLOSED	OPEN	NONE	108,099 12,434	0.12	141,003 19,195	0.14	173,512 24,324	0.14	140,872 18,651	0.13	
5	II	Rear	CLOSED	OPEN	NONE	109,496 11,462	0.10	143,113 18,747	0.13	179,629 27,059	0.15	144,079 19,089	0.13	
8	II	Front	CLOSED	OPEN	NONE	110,077 9,804	0.09	141,874 17,529	0.12	176,544 25,051	0.14	142,831 17,462	0.12	

TABLE 2: FIREPLACE TEST DATA SUMMARY
(Cont'd)

Test	Airflow Setting	Combustion Air Supply	Glass Door	Cir.	Fans	(Btu/hr) $\frac{Q_{f1}}{Q_{NH1}}$	Eff ₁	(Btu/hr) $\frac{Q_{f2}}{Q_{NH2}}$	Eff ₂	(Btu/hr) $\frac{Q_{f3}}{Q_{NH3}}$	Eff ₃	(Btu/hr) $\frac{Q_{fAvg}}{Q_{NHAvg}}$	Eff _{Avg}	Comments
20	III	Room	OPEN	OPEN	NONE	108,547 15,334	0.14	140,450 20,246	0.14	177,599 25,763	0.15	142,199 20,447	0.14	↑ HIGH FLOW FREE CONV.
16	III	Rear	OPEN	OPEN	NONE	110,736 9,478	0.09	144,299 20,344	0.14	180,499 29,287	0.16	145,178 19,703	0.13	
18	III	Front	OPEN	OPEN	NONE	108,785 11,326	0.10	142,559 18,201	0.13	180,341 21,842	0.12	143,895 17,123	0.12	
21	III	Room	CLOSED	OPEN	NONE	108,706 10,175	0.09	138,762 10,728	0.08	175,701 14,231	0.08	141,056 11,711	0.08	
17	III	Rear	CLOSED	OPEN	NONE	111,632 4,730	0.04	141,452 9,655	0.07	177,203 13,668	0.08	143,429 9,351	0.06	↓ NORMAL FLOW NO CONV.
22	III	Front	CLOSED	OPEN	NONE	110,367 4,698	0.04	144,510 7,905	0.05	184,243 8,775	0.05	146,373 7,126	0.05	
29	II	Room	OPEN	CLOSED	NONE	107,493 21,207	0.20	140,239 29,474	0.21	172,985 38,467	0.22	140,239 29,716	0.21	
31	II	Rear	OPEN	CLOSED	NONE	108,363 19,500	0.18	142,348 31,837	0.22	177,388 40,899	0.23	142,700 30,745	0.21	
33	II	Front	OPEN	CLOSED	NONE	108,706 18,566	0.17	139,896 27,011	0.19	177,072 38,010	0.21	141,891 27,862	0.19	↓ PINE FUEL
30	II	Room	CLOSED	CLOSED	NONE	109,101 3,640	0.03	140,898 3,323	0.02	178,021 5,921	0.03	142,673 42,945	0.03	
32	II	Rear	CLOSED	CLOSED	NONE	108,020 7,154	0.07	140,582 8,399	0.06	175,648 10,525	0.06	141,416 8,693	0.06	
34	II	Front	CLOSED	CLOSED	NONE	107,704 4,859	0.05	138,446 6,857	0.05	172,748 9,917	0.06	139,632 7,211	0.05	
29A	II	Room	OPEN	CLOSED	NONE	114,998 17,493	0.15	106,021 18,493	0.17	106,388 19,418	0.18	109,135 18,468	0.17	OAK FUEL
29B	II	Room	OPEN	CLOSED	NONE	134,452 18,342	0.14	144,277 21,172	0.15	163,744 29,299	0.18	147,491 22,938	0.15	

TABLE 2: FIREPLACE TEST DATA SUMMARY
(Cont'd)

Test	Airflow Setting	Combustion Air Supply	Glass Door	Cir.	Fans	(Btu/hr)		(Btu/hr)		(Btu/hr)		(Btu/hr)		EffAvg	Comments
						$\frac{Q_{f1}}{Q_{NH1}}$	Eff ₁	$\frac{Q_{f2}}{Q_{NH2}}$	Eff ₂	$\frac{Q_{f3}}{Q_{NH3}}$	Eff ₃	$\frac{Q_{fAvg}}{Q_{NHAvg}}$	EffAvg		
23A	II	Room	OPEN	OPEN	TWO	110,498 16,531	0.15	143,113 34,596	0.24	177,575 42,246	0.24	143,789 31,124	0.21	↑ NORMAL FLOW FORCED CONV. ↓	
25A	II	Rear	OPEN	OPEN	TWO	108,310 23,863	0.22	139,817 35,056	0.25	175,041 44,493	0.25	141,056 34,471	0.24		
27	II	Front	OPEN	OPEN	TWO	108,890 16,464	0.15	142,058 27,829	0.20	178,733 34,192	0.19	143,227 26,162	0.18		
24	II	Room	CLOSED	OPEN	TWO	108,969 12,774	0.12	143,376 20,147	0.14	179,049 25,240	0.14	143,798 19,387	0.13		
26	II	Rear	CLOSED	OPEN	TWO	109,180 12,259	0.11	140,160 21,415	0.15	176,149 26,976	0.15	141,830 20,216	0.14		
28	II	Front	CLOSED	OPEN	TWO	110,314 16,375	0.15	141,953 23,891	0.17	175,516 30,351	0.17	142,594 23,539	0.16		

and allowed to escape through the warm air grille over the hearth. When the circulation features were closed, the side inlets and warm air outlet were all sealed with sheet metal covers and duct tape to prevent convective heating. The "Fans" column indicates whether or not the forced draft fans were in operation.

The next eight columns summarize the overall results of the tests. These columns were compiled from the raw data presented in the computer printouts included in Appendix B. Q_{F1} and Q_{NH1} indicate the average heat content of the fuel added to the fireplace (during the portion of the test using the lightest brands) and the average net heat delivered to the room by the fireplace. Eff_1 indicates the average thermal efficiency of the fireplace during this portion of the test. Q_{F2} and Q_{NH2} give corresponding values for the portion of the test during which intermediate weight brands were burned, and Eff_2 gives the average thermal efficiency for this portion of the test. Q_{F3} , Q_{NH3} , and Eff_3 give the same results for the last portion of the test burning the heavier brands and Q_{FAvg} , Q_{NHAvg} , and Eff_{Avg} give the summary average values for the entire test. The comments column is self-explanatory.

As can be seen from the table, the first six tests (in the order presented) are concerned with data collected under conditions of low air flow with free convection. The next six tests present data collected under normal airflow (Condition II) with free convection which was the airflow set-up used for most of the testing. The next six tests were performed using high airflow with free convection, and the following six tests were carried out with normal airflow and the convection passages sealed off. After these tests, two tests were run with alternate fuel (actual logs) and the last six tests shown were run with normal airflow and forced convection using the auxiliary fans.

The data presented in Table 2 can now be analyzed more fully through the use of data plots.

Figure 6 shows a series of curves generated from the data collected during the low calorimeter airflow (Setting I) tests. For this series of tests, the sides to the calorimeter heat exchanger were left open and air was allowed to pass through the heat exchanger through natural convection.




FIGURE 6. FIREPLACE SYSTEM PERFORMANCE FOR AIR FLOW SETTING I, CIRCULATOR OPEN, AND NO CIRCULATING FANS

No circulation fans were used for these tests. The horizontal scale on the graph indicates the heat input to the fireplace resulting from the wood combustion and the vertical scale indicates the useful heat transferred to the room. It is readily apparent that in most instances, the tests with the glass door open result in significantly higher net heat transfer to the room (indicating a high thermal efficiency). Also, it should be noted that the net heat transfer and efficiencies for greater firing rates as indicated from the three columns of points corresponding to the three series of progressively heavier brands.

For this series of tests, the highest apparent net heat transfers result from the test run with the glass door open and combustion air coming directly from the room. With combustion air coming from the rear of the hearth, the efficiency is slightly lower, and with the combustion air supplied to the front of the hearth, the efficiency is lower still. These results were not expected.

Figure 7 presents a series of curves similar to those in Figure 6 for the tests run with the fireplace circulator running under natural convection and the calorimeter airflow settings at Setting II. Again, the highest net heat transfer was obtained with the glass door open and the combustion air coming directly from the room. Net heat transfers with the glass doors closed were significantly lower. The low point for the lower fuel feed rate for test 4A is probably due to the warmup effects of the calorimeter. This tendency will also be apparent in other graphs.

Figure 8 gives similar trends to the two previous graphs for airflow setup III although the highest net heat output for these tests occurred during a test when the combustion air was being supplied from the rear of the hearth. Again, the differences in heat output with the glass doors opened and closed are apparent.

Figure 9 shows a set of curves from the data collected with airflow setup II and the side inlets and front outlet to the circulator closed allowing no heat transfer to the room by convection. Again, in this case the rear combustion air shows a trend toward higher efficiency than the room combustion air case. With no circulating effects, the difference between the heat transferred by the fireplace with the door opened and the door closed is even more dramatic. This effect can be seen by comparing this graph with Figure 7.




FIGURE 7. FIREPLACE SYSTEM PERFORMANCE FOR AIR FLOW SETTING II, CIRCULATOR OPEN, AND NO CIRCULATING FANS




FIGURE 8. FIREPLACE SYSTEM PERFORMANCE FOR AIRFLOW SETTING III, CIRCULATOR OPEN, AND NO CIRCULATING FANS




FIGURE 9. FIREPLACE SYSTEM PERFORMANCE FOR AIR FLOW SETTING II,
WITH CIRCULATOR CLOSED

Figure 10 shows some difference in steady state performance of the fireplace using different fuels. In these tests, the baseline used was the Douglas fir brands with airflow setting II, room combustion air, the glass door open and the circulating features of the fireplace closed. The oak and pine samples used were actual logs, so there was some difficulty assessing the actual heat content of the fuel, although the logs were dried in the oven and weighed. The graph shows lower net heat transfer for the other fuels, but the results cannot be considered conclusive. In order to obtain results with better correlation, the tests should be repeated with kiln dried pine and oak brands.

Figure 11 shows a set of curves resulting from a series of tests using airflow setting II with the fireplace circulator open and the two electric circulation fans in use. Again, the test with combustion air from the rear exhibits the highest net heat output. Comparing this graph with Figure 9 shows a trend to higher fireplace output with the circulating fans under all conditions.

Figure 12 shows the effect of changing the airflow setup on the net heat output. It appears that higher efficiencies are possible with lesser airflow through the calorimeter, but as mentioned previously, test conditions became intolerable for the operators at the lower airflow conditions. Since the change in the airflow setup affects the use of the calorimeter room as a heat exchanger, it is probably not accurate to compare this effect with the effects of air infiltration in an actual house since airflow setting I represents approximately one air change of the calorimeter volume per minute, airflow setting II represents approximately two air changes, and airflow setting III represents approximately three air changes. This is a much higher rate of change than would be expected in a normal house (one to two air changes per hour) but may show that a tighter house with less infiltration results in a higher output for the fireplace. This possible conclusion would have to be investigated further to find the definite answer.

Figure 13 presents some plots of data for airflow setting II, with the thermal efficiency of the fireplace plotted versus the heat input, with combustion air supplied from the room. Again, the adverse effects of test warmup efficiencies are shown for test 4A and test 23A. As might




FIGURE 10. FIREPLACE SYSTEM PERFORMANCE WITH ALTERNATIVE FUELS
AIR FLOW SETTING II, CIRCULATOR CLOSED, AND NO
CIRCULATION FANS




FIGURE II. FIREPLACE SYSTEM WITH AIR FLOW SETTING II, CIRCULATOR OPEN, AND TWO CIRCULATING FANS.




FIGURE 12. FIREPLACE SYSTEM PERFORMANCE WITH AIR FLOW SETTINGS I, II, III, OPEN CIRCULATOR, AND NO CIRCULATING FANS




FIGURE 13. CIRCULATING FIREPLACE EFFICIENCY CHARACTERISTICS FOR ROOM COMBUSTION AIR, AND CONDITION II AIR FLOW SETTING

be expected, the trend to highest efficiencies is shown by test 23A, with the glass door open and two fans operating. The lowest efficiencies were exhibited in test 30, with both the glass doors closed and the circulator closed. Indeed, under these conditions the fireplace supplies very little heat to the room. In contrast to test 30, test 24 with the door closed but with the addition of the two circulating fans shows a marked improvement in overall efficiency. Some surprising results are shown by the curve of test 29, since it would be expected that the results of test 4A would show a higher overall efficiency with the circulator open. If time had permitted, one of these tests could have been repeated to verify this difference. This set of curves shows that the thermal efficiencies tend to remain quite constant with variations in fuel feed rate, while the heat net output show sharper rises as fuel feed rates are increased.

Figure 14 shows a set of curves similar to those shown in Figure 13, but this time the combustion air was provided from the rear of the hearth. Again, the highest efficiency is exhibited with the glass doors open and the fans running, while the lowest efficiencies resulted with the doors closed and the circulator closed.

Figure 15 shows curves similar to the previous two plots for combustion air supplied from the front. Again, the fireplace performance with the door open and the circulator closed is remarkably high. In this case, the doors closed condition with the two fans in operation approaches the performance of the door open cases.

Overall Figures 13, 14, and 15 serve to illustrate the order of magnitude effects the circulating feature and the use of the glass doors have on fireplace performance. It should be noted that the glass doors used in this test program contained "Temper Pyrex" glass manufactured by the Corning Glass Works in Corning, New York.

The heating values for representative samples of the wood used in this test program were determined using a bomb calorimeter and the "high heating values" (HHV) was thus calculated and used as an input to the computer program. This heating value was determined to be 8379 Btu/lb and was used because it is generally the accepted practice in the United States to assign heating values based on HHV. In Europe, the "lower heating value" (LHV) is often used, and this heating value is approximately 8% lower or




FIGURE 14. CIRCULATING FIREPLACE EFFICIENCY CHARACTERISTICS FOR REAR COMBUSTION AIR, CONDITION II AIR FLOW SETTING




FIGURE 15. CIRCULATING FIREPLACE EFFICIENCY CHARACTERISTICS, FOR FRONT COMBUSTION AIR, CONDITION II AIR FLOW SETTING

about 7720 Btu/lb for Douglas fir. Using this heating value in the calculations results in a slightly higher net heat output for the fireplace and a slightly higher thermal efficiency. For comparison, a test case (test number 4A) was run using the two heating values. Test 4A (see Table 2) was run using room combustion air, the glass door open, the circulator open, and no circulating fans. The computer printouts for this revised case are included at the end of Appendix B. Comparative values using the two heating values are shown in Table 3.

TABLE 3: HEATING VALUE COMPARISON

Test	Heating Value	$\frac{(Btu/hr) Q_{f1}}{Q_{NH1}}$	Eff ₁	$\frac{(Btu/hr) Q_{f2}}{Q_{NH2}}$	Eff ₂	$\frac{(Btu/hr) Q_{f3}}{Q_{NH3}}$	Eff ₃	$\frac{(Btu/hr) Q_{fAvg}}{Q_{NHAvg}}$	Eff _{Avg}
4A	HHV (8379)	111,421 12,546	0.11	142,295 29,089	0.20	176,966 37,337	0.21	143,561 26,324	0.18
4A	LHV (7720)	102,653 12,782	0.12	131,097 29,325	0.22	163,304 37,572	0.23	132,263 26,560	0.19

VI. CONCLUSIONS AND RECOMMENDATIONS

The overall results of this test program have been interesting and, in some respects, surprising. Unanswered questions still remain, and due to the limited scope of the program, there was not sufficient time or funding to repeat all tests several times to obtain statistically significant data. General trends were apparent, however, and the more important of these will be discussed here. The purpose of these studies overall has been to show these general characteristics and not the absolute efficiencies.

Results of the thirty-two tests discussed in this report indicated fireplace thermal efficiencies from a low of 3% to a high of 33%. The arithmetical average of all the steady state controlled tests performed was 15.7%. Table 4 gives a brief summary of some of the data trends.

For each series of tests, a higher average thermal efficiency was found with the glass doors open. This difference amounted to a low of 5.6% and a high of 15.6%, with an average of 9.2%. This is to be expected since the transmittance of infrared radiation (thermal radiation with wavelengths greater than 3μ) through glass is poor (12). The major conclusion to be drawn from this result is that when a moderate to intense fire is burning in the fireplace, the glass doors should be left open to produce the maximum heating effect on the room and its occupants. The glass doors can be effective in limiting air outflow through the chimney when a fire is dying, but in normal operation, should remain open.

Table 4 also shows the overall value of a fireplace circulating device. As can be seen from the data, the use of circulating fans can add approximately 2.7% to the fireplace efficiency with the glass doors open and 1.6% with the glass doors closed. The tests with the circulating feature blocked off completely showed an efficiency almost as great as with the fans with the glass doors open, while with the doors closed, the efficiency was almost 10% less. The high efficiency with the doors open and the circulator closed is thus open to suspicion, and these tests should be repeated to obtain more conclusive results.

Table 5 illustrates the relative merits of the methods for introducing combustion air to the fire. Considering the tests performed under the same

TABLE 4 : FIREPLACE TEST SUMMARIES

<u>Test Condition</u>	<u>Glass Doors</u>	<u>Average Efficiency</u>
Airflow I, Circulator Open, No fans	Open	28.7%
	Closed	17.7%
Airflow II, Circulator Open, No fans	Open	18.3%
	Closed	12.7%
Airflow III, Circulator Open, No fans	Open	13.0%
	Closed	6.0%
Airflow II, Circulator Closed, No fans	Open	20.3%
	Closed	4.7%
Airflow II, Circulator Open 2 fans	Open	21.0%
	Closed	14.3%

TABLE 5 : COMBUSTION AIR TEST SUMMARIES

<u>Test Condition</u>	<u>Glass Doors</u>	<u>Efficiencies</u>	<u>Average</u>
Airflow II Room Combustion Air	Open	18, 21, 21	20.0
	Closed	13, 3, 13	9.7
Airflow II Rear Combustion Air	Open	20, 21, 24	21.6
	Closed	13, 6, 14	11.0
Airflow II Front Combustion Air	Open	17, 19, 18	18.0
	Closed	12, 5, 16	11.0

airflow conditions, the averages were computed and presented in the table. The differences in efficiencies for any of the air supplies is not dramatic, and thus the commonly held conclusion that outside combustion air has a significant positive effect on fireplace efficiency is not borne out by these results. However, it should be noted that a satisfactory device for measuring flow rates of outside combustion air was not available during the test program and there is some question as to the effectiveness of the method for outside air introduction. Examination of Figure 3 will show that in some respects the outside air ducts are arranged more like chimneys, and it may be that combustion air could be forced out of the calorimeter room rather than in, when the room balance was off even a small amount. Thus, more conclusive results could be obtained by routing the combustion air flow from an elevation significantly lower than the hearth and by accurately measuring air flow (and direction).

A closer look at Figure 10 reveals that the use of actual logs rather than carefully constructed firebrands results in a slight drop in heat output. Thus it is probable that the test efficiencies obtained in this program are somewhat higher than a person could expect to achieve at home with ordinary firewood. There were not enough tests performed to statistically evaluate fir as opposed to oak or pine, but other factors must be considered besides total heat release, and these include creosote buildup and the possibility of chimney fires when burning softwood.

The major question which results for the testing of a fireplace in a calorimeter room is whether or not these tests approximate what happens in a real house. The answer to this question is that the overall effect on the house as a system cannot be evaluated with this apparatus. Combustion air for the fireplace is normally drawn up the chimney from the conditioned air space and this air demand may indeed result in a higher heat demand on other systems (such as a gas furnace, etc.) which may be heating the house. With this test setup, there is no basis for estimation of these effects.

The conduct of this test program has pointed out some shortcomings in the calorimeter room as it exists, and several improvements could be made including provisions for the more accurate measurement of combustion air flows and for the continuous monitoring of flue gas constituents (CO , O_2 , CO_2) with electronic instruments to better utilize the heat loss efficiency calculation method.

With the calorimeter room as a tool, other tests on wood burning apparatus could be performed including the evaluation of fireplace inserts and wood stove to fireplace retrofits. In addition, other methods for hot air circulation could be evaluated as well as water heating devices. The existing laboratory could also be used for further analysis of smoke constituents of interest, possibly using gas chromatography.

In summary, the overall test program showed a steady state arithmetical average thermal efficiency for the fireplace of 15.7%. This efficiency is, of course, significantly less than is available with an airtight wood stove. The tests have shown that a more intense fire results in a slightly higher net heat output than a quiet fire. The results also show that open glass doors allow a higher net heat transfer to the surroundings when a well established fire is burning and that circulating features incorporation electric fans can add several percent to a fireplace's overall efficiency.

VII. REFERENCES



1. Shelton, J., and A. B. Shapiro, The Woodburners Encyclopedia, Vermont Crossroads Press, Waitsfield, VE (1976).
2. De Angelis, D. G. and R. B. Reznik, Source Assessment: Residential Combustion of Wood, Monsanto Research Corporation, ROAP NO. 21AXM-071 (1978).
3. Jahnsen, V., "The Chemical Composition of Hardwood Smoke", PhD dissertation, Purdue University, 1961.
4. Konzo, S., and W. S. Harris, Fuel Savings Resulting From Closing of Rooms and and From Use of a Fireplace, U. of Illinois Engineering Experiment Station, No. 348.
5. Shelton, J., "What Fireplaces and Fireplace Accessories are Really Worth", Wood Burning Quarterly, Winter 1978, p.169.
6. Sonderegger, R., et al., In-situ Measurement of Net Fireplace Efficiency Using Electric Co-heating, U. of California, Lawrence Berkeley Laboratories, 1979.
7. "Voluntary Method of Testing For Rating Wood Burning Fireplaces And Fireplace Stoves", Fireplace Institute, Chicago, IL., F. I. Standard, 1-77 (1977).
8. "Addendum 1 to the Volumary Method of Testing For Rating Wood Burning Fireplaces And Fireplace Stoves", Fireplace Institute, Chicago, IL, F.I. Standard 1-77 (1977).
9. "Test Standard for Rating Wood-fired, Closed Combustion Chamber, Heating Appliances", Fireplace Institute, Chicago, IL., (1978).
10. Maxwell, T., D. F. Dyer, and G. Maples, "Measuring the Efficiency and Heat Output of Residential Wood Heating Appliances", Proceedings of Wood Heating Seminar 4, Wood Energy Institute, Camden, ME, May 1979, p.105.
11. Fernandez, J. N., "Why not burn wood?" Chemical Engineering, 1977, p.159.
12. "ASHRAE HANDBOOK OF FUNDAMENTALS", American Society of Heating, Refrigerating and Air-Conditioning Engineers, New York, NY (1977).

APPENDIX A

COMPUTER ANALYSIS FLOW CHART

COMPUTER PROGRAM LISTING

COMPUTER ANALYSIS NOMENCLATURE



```

        PROGRAM FPR(INPUT,OUTPUT,TAPE5=INPUT,TAPE6=OUTPUT,TAPE7
        @TAPE8=ANS,DAT,TAPE9=DAT)
00110 DIMENSION Q(12),T(14),G(3),AD(5),PC(6),PH(3),AM(10),
        @EF(2),RA(2)
00115 REAL HHV,KWH
00121 READ(9,*) (G(N),N=1,2),(AD(N),N=1,4),(PC(N),N=1,3),(PH(N),N=1,3)
00172 TAEF=0
00174 TAQF=0
00176 TAQNH=0
00183 DO 1000 L=1,3
        81 READ(9,*) G(3)
00184 TEF=0
00185 TMF=0
00186 DO 900 M=1,7
        71 READ(9,*) FM,(T(N),N=1,14)
00190 DO 155 I=1,3
        155 AM(I)=AD(I)*G(I)
00222 AM(8)=AM(1)-AM(2)
00224 AM(6)=FM/(454*6)
00226 AM(5)=15.96*AM(6)
00227 AM(4)=AM(2)+AM(3)+AM(5)-AM(1)
00228 HHV=8379
00230 QF=AM(6)*HHV
00240 KWH=.04*2+.0345*2
C      WHEN THE CIRCULATING FANS ARE RUNNING,ADD (.0345*2) TO THE KWH.
00245 E1=KWH*56.9
00250 E2=((3/4)*42.4)*2
C      WE HAVE TWO 3/4 HP PUMPS WHICH CIRCULATE AIR INTO THE CALORIMETER.
C      THESE ARE CONSIDERED AS THE ELECTRICITY USEAGES E2(CF. THE TEXT),
C      WHICH ARE NOT PART OF THE FIREPLACE SYSTEM.
00255 TF=(T(5)+T(6)+T(7))/3
00260 TR=((T(9)+T(10)+T(11))/3+T(1))/2
00262 TL=(T(12)+T(13))/2
        31 TC=TR
00266 W=PH(3)/20
00268 CP=.24
00270 PC(4)=.56
00272 PC(5)=0.07
00274 PC(6)=0.0
00280 Q(12)=AM(5)*CP*(T(8)-TR)
C      EFFICIENCY ANALYSIS : METHOD I
00300 Q(1)=AM(2)*CP*(T(2)-T(1))
00305 Q(2)=(2./20.)*(3413./120.)*(TR-TL)
00310 Q(3)=AM(8)*CP*(T(1)-TR)
00315 Q(4)=AM(4)*CP*(TC-TR)
00320 Q(5)=E1+E2
00325 QG=Q(1)+Q(2)-Q(3)-Q(4)-Q(5)
00330 EF(1)=QG/QF
00335 RA(1)=Q(12)/(QF-QG)
        GO TO 550
C      EFFICIENCY ANALYSIS : METHOD II
00400 Q(6)=AM(6)*.063*8.933*(1090.7-TR+.455*T(8))
C 405 Q(7)=AM(7)*HHVA
00410 Q(8)=.444*AM(5)*W*(T(8)-TR)
00415 Q(9)=AM(6)*PC(6)*(1090.7-TR+.455*T(8))
00420 Q(10)=(10160*PC(2)*.523)*AM(6)/(PC(1)+PC(2))
00425 Q(11)=AM(3)*CP*(T(8)-TR)
00430 Q(12)=AM(5)*CP*(T(8)-TR)
00435 Q(7)=QF-(Q(6)+Q(8)+Q(9)+Q(10)+Q(11)+Q(12))-QG
00440 QL=Q(6)+Q(7)+Q(8)+Q(9)+Q(10)+Q(11)+Q(12)
00445 EF(2)=(QF-QL)/QF

```



```

00450 RA(2)=Q(12)/QL
00500 IF((EF(1)-EF(2)).LE.,.05) GO TO 550
00510 PRINT(8,515)
00515 FORMAT(" ",T10,"SOLUTION IS NOT CONSISTENT")
00550 IF(M.GT.1) GO TO 600
      PRINT (8,*) (" ")
      91 PRINT(8,461) L
461  FORMAT(" ",T10,"TEST NUMBER : -",I11,T50,"DATE : ")
196  PRINT (8,*) (" ")
      PRINT (8,198)
198  FORMAT(" ",T2,78("= "))
      PRINT (8,*) (" ")
      PRINT (8,201)
201  FORMAT(" ",T25,"FIREPLACE SIMULATION STUDIES")
      PRINT (8,*) (" ")
      PRINT (8,202)
202  FORMAT(" ",T20,"CHARACTERISTICS AND EFFICIENCY ANALYSIS")
      PRINT (8,*) (" ")
      PRINT (8,203)
203  FORMAT(" ",T2,78("= "))
      PRINT (8,*) (" ")
      41 PRINT(8,21)
      21 FORMAT(" ",T10,"COMBUSTION AIR : ",T50,"GLASS DOOR : ")
204  PRINT (8,*) (" ")
      PRINT (8,205)
205  FORMAT(" ",T10,"CIRCULATION FANS : ",
      @T50,"FUEL MATERIAL : ")
      PRINT (8,*) (" ")
      PRINT (8,206) HHV
206  FORMAT(" ",T10,"FUEL TYPE : ",T50,"HEATING VALUE =",
      @F7.2,T71,"(BTU/LB)")
      PRINT (8,*) (" ")
      PRINT (8,207)
207  FORMAT(" ",T2,78("= "))
      PRINT (8,*) (" ")
      PRINT (8,208) (AM(I),I=1,2)
208  FORMAT(" ",T10,"MASS AIR IN =",F6.2,"(LB/MIN)",T50,"MASS AIR ",
      @*OUT =",F6.2,"(LB/MIN)")
      PRINT (8,*) (" ")
      PRINT (8,209) AM(3),AM(5)
209  FORMAT(" ",T10,"MASS DRY FLUE GAS =",F5.2,"(LB/MIN)",
      @T50,"MASS COMB AIR =",F5.2,"(LB/MIN)")
      PRINT (8,*) (" ")
      PRINT (8,210)
210  FORMAT(" ",T2,78("= "))
      PRINT (8,*) (" ")
      PRINT (8,211) (PC(I),I=1,3)
211  FORMAT(" ",T10,"%CO2 =",F5.3,T30,"%CO =",F5.3,T50,"%O2 =",
      @F5.3)
      PRINT (8,*) (" ")
      PRINT(8,212) (PC(J),J=4,6)
212  FORMAT(" ",T10,"%C =",F5.3,T30,"%H =",F5.3,T50,"%MC =",
      @F5.3)
      PRINT (8,*) (" ")
      PRINT (8,213) (PH(I),I=1,3)
213  FORMAT(" ",T10,"(R.H.)LAB =",F5.3,T30,"(R.H.)OUT =",F5.3,
      @T50,"(R.H.)ROOM =",F5.3)
      PRINT (8,*) (" ")
      PRINT (8,214)
214  FORMAT(" ",T2,78("= "))
      PRINT (8,*) (" ")
      PRINT (8,215)

```

```

215 FORMAT(" ",T8,"FUEL",T71,"COMB AIR/")
    PRINT (8,216)
216 FORMAT(" ",T2,"TIME",T7,"WEIGHT",T32,"TEMPERATURE(F)",
    @T67,"EFF",T71,"TOT LOSS")
    PRINT (8,217)
217 FORMAT(" ",T2,78("-"))
    PRINT (8,218)
218 FORMAT(" ",T3,"MIN",T7,"LB/MIN",T16,"IN",T22,"OUT",T28,
    @ "STACK",T35,"COMB",T41,"FIRE",T48,"CALR",T54,"LAB",T60,
    @ "ENV",T68,"%",T74,"%")
    PRINT (8,219)
219 FORMAT(" ",T2,78("-"))
600 PRINT (8,620) M-1,AM(6),T(1),T(2),T(8),TC,TF,TR,TL,T(14),
    @EF(1),RA(1)
620 FORMAT(" ",T4,111,T7,F5.4,T15,F4.1,T21,F5.1,T28,F5.1,T34,
    @F5.1,T40,F6.1,T47,F5.1,T53,F5.1,T59,F5.1,T66,F4.2,T72,F4.2)
C    TOTAL MASS OF FUEL AND THE EFFICIENCY ARE EVALUATED,
C    FOR THE AVERAGE EFFICIENCY CALCULATIONS.
    TMF=TMF+AM(6)
    TEF=TEF+EF(1)
900 CONTINUE
    PRINT (8,*) (" ")
    PRINT (8,221)
221 FORMAT(" ",T2,78("="))
00630 AEF=TEF/(M-1)
00635 AMF=TMF/(M-1)
00640 AQF=AMF*HHV*60
00645 AQNH=AEF*AQF
00650 PRINT(8,910) AEF,AQF,AQNH
00910 FORMAT(" ",T3,"AEF=",F4.2,T22,"AQF=",E11.6,"(BTU/HR)",T54,
    @ "AQNH=",E10.5,"(BTU/HR)")
00655 PRINT(8,915)
00915 FORMAT(" ",T2,78("="))
00660 TAEF=TAEF+AEF
00665 TAQF=TAQF+AQF
00670 TAQNH=TAQNH+AQNH
1000 CONTINUE
00675 AEFT=TAEF/(L-1)
00680 AQFT=TAQF/(L-1)
00685 AQNHT=TAQNH/(L-1)
    PRINT(8,*) (" ")
00690 PRINT(8,930) AEFT,AQFT,AQNHT
00930 FORMAT(" ",T3,"AEFT=",F4.2,T22,"AQFT=",E11.6,"(BTU/HR)",T54,
    @ "AQNHT=",E10.5,"(BTU/HR)")
    PRINT(8,*) (" ")
00695 PRINT(8,940)
00940 FORMAT(" ",T2,78("="))
00700 STOP
00800 END

```

NOMENCLATURE

SYMBOLS

AD:	Air density (lbm/ft^3)
AF:	Air fuel ratio
AM:	Air mass (lbm/min)
C:	Carbon
CA:	Combustion air
CALR:	Calorimeter
CAR:	Combustion air ratio
CO:	Carbon monoxide
CO ₂ :	Carbon dioxide
C _p , CP:	Specific heat coefficient ($\text{Btu}/\text{lbm}-^\circ\text{F}$)
E:	Electricity usage (Btu/hr), E ₁ : part of the fireplace being tested, E ₂ : not part of the fireplace being tested.
EF:	Efficiency
G:	Volumetric flow rate (ft^3/min)
H ₂ :	Hydrogen
HHV:	Higher heating value (Btu/lbm)
KWH:	Kilowatt hour
M, m:	Mass (lbm)
MC:	Moisture content (wet basis)
MF:	Mass of fuel
O:	Oxygen
PC:	Percentage
PH:	Relative humidity
Q, q:	Heat rate (Btu/min)
RA:	Ratio of heat loss by combustion to the total heat loss
R.H.:	Relative humidity
T:	Temperature ($^\circ\text{F}$)
W:	Specific humidity

GREEK LETTERS

η : Efficiency
 ρ : Density (lbm/ft³)
 ω : Specific humidity

SUBSCRIPTS

A: Average, Ash
ae: Air exit
ai: Air inlet, ai₁: indirect for combustion, ai₂: direct for combustion
am: Air moisture
C_c: Combustion
ca: Combustion air
CO: Carbon monoxide
dfg: Dry flue gas
e: Electricity
F, f: Fuel
G: Gained
H₂: Hydrogen
 ℓ : Leakage
L: Losses, lab
NH: Net heat output
R: Calorimeter room
T: Total
uc: Uncombustibles

SUPERSCRIPTS

-: Average
.: Time rate (1/min)

APPENDIX B

COMPUTER ANALYSIS DATA SHEETS

TEST NUMBER : 13-1

DATE : 1/22/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 75.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =11.45(LB/MIN)

MASS COMB AIR = 3.39(LB/MIN)

%CO₂ = .030

%CO = .040

%O₂ = .010

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .800

(R.H.)ROOM = .400

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2122	33.6	53.4	106.6	49.7	449.7	49.7	67.6	33.6	.15	.03
1	.2137	34.0	64.8	262.8	51.5	525.3	51.5	68.4	34.0	.22	.12
2	.2162	35.7	74.8	360.9	54.5	599.6	54.5	67.6	35.7	.28	.19
3	.2096	35.2	76.6	347.4	55.9	584.8	55.9	67.3	35.2	.31	.19
4	.2129	34.5	83.0	364.2	57.5	606.8	57.5	68.8	34.5	.36	.22
5	.2122	35.8	82.2	359.1	58.6	596.8	58.6	67.8	35.8	.35	.21
6	.2133	36.1	85.6	229.3	59.8	569.6	59.8	68.2	36.1	.37	.12

AEF= .29

AQF=.107018E+06(BTU/HR)

AQNH=.31161E+05(BTU/HR)

TEST NUMBER : 13-2

DATE : 1/22/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 75.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 4.45(LB/MIN)

%CO2 = .030

%CO = .040

%O2 = .010

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .800

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2790	36.1	85.6	229.3	59.8	569.3	59.8	68.2	36.1	.28	.11
1	.2786	36.2	89.3	195.2	60.9	636.9	60.9	67.1	36.2	.31	.09
2	.2805	36.6	91.2	415.6	62.6	665.2	62.6	67.7	36.6	.32	.24
3	.2808	37.3	96.3	429.7	64.6	670.7	64.6	67.9	37.3	.34	.25
4	.2735	37.7	102.6	389.3	66.4	693.3	66.4	68.0	66.4	.38	.24
5	.2761	37.2	104.0	265.7	67.2	749.6	67.2	68.3	37.2	.39	.15
6	.2761	38.0	102.1	247.2	67.9	695.0	67.9	68.4	38.0	.38	.13

AEF= .34

AQF=.139659E+06(BTU/HR)

AQNH=.47955E+05(BTU/HR)

TEST NUMBER : 13-3

DATE : 1/22/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 75.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.65(LB/MIN)

%CO2 = .030

%CO = .040

%O2 = .010

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .800

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3543	38.0	102.1	247.2	67.9	695.0	67.9	68.4	38.0	.30	.12
1	.3517	38.2	105.0	409.6	69.1	707.6	69.1	67.7	38.2	.31	.23
2	.3517	38.4	108.2	519.0	71.0	697.4	71.0	68.6	38.4	.33	.31
3	.3506	39.9	110.1	509.1	72.6	685.7	72.6	69.1	39.9	.33	.30
4	.3488	38.4	113.3	422.7	73.4	714.3	73.4	67.5	38.4	.36	.25
5	.3480	38.2	113.6	294.0	73.1	806.5	73.1	65.6	38.2	.36	.16
6	.3451	39.1	112.8	259.7	74.9	829.0	74.9	66.0	39.1	.36	.13

AEF= .34

AQF=.175964E+06(BTU/HR)

AQNH=.59385E+05(BTU/HR)

AEFT= .32

AQFT=.140880E+06(BTU/HR)

AQNHT=.46167E+05(BTU/HR)

TEST NUMBER : 9A-1

DATE : 12/11/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 75.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =11.45(LB/MIN)

MASS COMB AIR = 3.46(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .650

(R.H.)ROOM = .400

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2166	40.7	55.7	127.7	51.9	574.9	60.1	70.0	38.3	.13	.04
1	.2148	41.5	71.4	169.5	50.4	668.7	57.2	70.0	38.2	.20	.06
2	.2159	43.9	75.1	333.7	56.4	679.9	66.0	70.2	38.7	.24	.16
3	.2137	43.7	96.5	344.4	58.2	834.0	69.1	69.9	38.9	.38	.20
4	.2122	42.9	82.1	306.3	58.3	881.5	69.2	70.3	39.1	.31	.16
5	.2115	45.6	85.7	220.8	58.6	864.2	71.1	69.3	37.9	.31	.10
6	.2129	44.9	87.9	194.8	58.2	819.8	70.7	69.2	40.1	.33	.08

AEF= .27

AQF=.107545E+06(BTU/HR)

AQNH=.29241E+05(BTU/HR)

TEST NUMBER : 9A-2

DATE : 12/11/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 75.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 4.50(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .650

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2819	44.9	87.9	194.8	58.2	819.8	70.7	69.4	40.1	.25	.08
1	.2790	45.1	88.0	389.8	60.0	792.3	72.8	70.2	40.0	.26	.20
2	.2790	45.8	96.0	421.2	61.2	769.0	74.3	68.7	40.3	.30	.23
3	.2790	45.8	100.7	436.7	62.6	810.8	75.9	69.7	39.6	.33	.24
4	.2849	47.0	107.4	357.4	62.6	683.8	77.0	70.3	41.8	.34	.19
5	.2764	47.3	99.4	266.4	63.0	612.4	77.7	69.1	41.2	.32	.13
6	.2768	46.4	101.0	238.5	62.7	570.6	77.1	70.4	40.6	.33	.11

AEF= .30

AQF=,140555E+06(BTU/HR)

AQNH=,42682E+05(BTU/HR)

TEST NUMBER : 9A-3

DATE : 12/11/78

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 75.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.65(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .650

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3543	46.4	101.0	238.5	62.7	570.6	77.1	70.4	40.6	.26	.10
1	.3521	45.5	115.8	484.3	63.7	631.3	78.6	68.6	41.1	.32	.27
2	.3488	46.8	110.7	478.8	65.8	662.6	81.2	69.6	42.8	.31	.26
3	.3484	48.1	107.4	467.5	66.5	658.0	83.3	69.1	43.0	.30	.25
4	.3469	45.4	117.6	418.7	66.7	649.2	82.6	68.8	42.6	.35	.24
5	.3495	48.5	115.5	332.3	67.1	606.8	84.4	69.9	42.2	.32	.17
6	.3499	47.8	112.3	266.5	65.9	652.8	84.1	68.7	42.3	.32	.12

AEF= .31

AQF=.175938E+06(BTU/HR)

AQNH=.54642E+05(BTU/HR)

AEFT= .30

AQFT=.141346E+06(BTU/HR)

AQNHT=.42189E+05(BTU/HR)

TEST NUMBER : 11-1

DATE : 1/12/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 60.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =12.59(LB/MIN)

MASS COMB AIR = 3.52(LB/MIN)

%CO₂ = .110

%CO = .010

%O₂ = .090

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .980

(R.H.)OUT = .480

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	36.8	49.2	225.7	45.9	203.6	51.5	66.9	40.4	.07	.09
1	.2173	36.9	54.2	408.7	45.7	402.6	51.9	66.8	41.2	.10	.18
2	.2173	36.8	51.5	151.4	47.2	609.5	53.7	66.7	42.6	.10	.05
3	.2052	36.8	60.1	160.1	47.8	472.1	55.2	67.3	41.0	.16	.06
4	.2184	36.9	62.2	160.3	48.5	414.0	56.6	67.1	42.1	.17	.06
5	.2166	37.3	72.6	375.3	49.3	517.3	58.8	67.3	51.3	.23	.19
6	.2170	37.1	70.9	210.2	50.4	457.6	60.3	67.0	44.9	.23	.09

AEF= .15

AQF=.108600E+06(BTU/HR)

AQNH=.16345E+05(BTU/HR)

TEST NUMBER : 11-2

DATE : 1/12/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 60.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 4.58(LB/MIN)

%CO2 = .110

%CO = .010

%O2 = .090

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .980

(R.H.)OUT = .480

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2871	37.1	70.9	210.2	50.4	457.6	60.3	67.0	44.9	.17	.08
1	.2819	36.9	75.5	389.0	50.9	497.5	61.6	67.1	47.5	.20	.19
2	.2827	37.6	94.2	418.6	51.8	505.5	63.0	67.3	43.1	.28	.23
3	.2819	37.5	88.9	438.7	53.0	593.1	65.6	67.5	42.2	.27	.23
4	.2819	37.5	94.4	405.6	53.3	577.6	65.9	67.4	42.6	.29	.22
5	.2863	38.1	98.1	329.3	54.1	549.2	66.9	69.6	43.9	.30	.17
6	.2827	37.8	90.7	238.2	54.2	492.5	67.1	69.4	44.1	.28	.11

AEF= .26

AQF=.142533E+06(BTU/HR)

AQNH=.36683E+05(BTU/HR)

TEST NUMBER : 11-3

DATE : 1/12/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 60.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.73(LB/MIN)

MASS COMB AIR = 5.64(LB/MIN)

%CO2 = .110

%CO = .010

%O2 = .090

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .980

(R.H.)OUT = .480

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3532	37.8	90.7	238.2	54.2	492.5	67.1	69.4	44.1	.22	.10
1	.3561	37.9	84.2	211.6	54.6	530.0	67.6	69.4	47.3	.20	.08
2	.3532	37.9	97.9	503.0	55.7	639.0	69.9	69.4	48.8	.25	.27
3	.3561	37.9	110.8	519.3	56.7	772.3	71.8	70.1	44.7	.30	.29
4	.3480	37.7	110.2	402.8	57.0	742.2	72.4	69.5	48.3	.31	.22
5	.3480	37.7	101.5	318.0	57.2	711.8	72.8	69.2	42.2	.28	.16
6	.3554	37.4	100.5	259.1	57.2	630.1	72.8	69.4	47.1	.27	.12

AEF= .26

AQF=.177388E+06(BTU/HR)

AQNH=.46549E+05(BTU/HR)

AEFT= .22

AQFT=.142840E+06(BTU/HR)

AQNHT=.33192E+05(BTU/HR)

TEST NUMBER : 14-1

DATE : 1/29/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 60.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 3.40(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .120

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .490

(R.H.)OUT = .800

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2129	34.8	53.3	123.5	51.8	726.7	51.8	66.4	40.5	.12	.04
1	.2115	35.6	68.6	386.2	53.1	803.1	53.1	66.1	43.1	.21	.19
2	.2144	35.8	74.6	406.1	54.1	779.5	54.1	65.5	41.8	.24	.21
3	.2162	35.8	78.1	413.7	55.0	720.4	55.0	66.3	43.7	.26	.22
4	.2203	36.1	81.2	396.6	55.8	700.3	55.8	66.3	44.6	.28	.22
5	.2166	36.3	83.3	326.4	56.5	679.3	56.5	65.5	43.4	.29	.17
6	.2170	37.2	84.5	256.2	57.5	708.4	57.5	66.3	44.4	.30	.13

AEF= .24

AQF=.108363E+06(BTU/HR)

AQNH=.26257E+05(BTU/HR)

TEST NUMBER : 14-2

DATE : 1/29/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 60.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 4.46(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .120

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .490

(R.H.)OUT = .800

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2797	37.2	84.5	256.2	57.5	708.4	57.5	66.3	44.4	.23	.12
1	.2757	37.0	85.8	450.5	58.3	751.0	58.3	66.3	42.6	.24	.24
2	.2827	36.9	89.9	473.3	59.1	748.9	59.1	66.1	45.2	.26	.26
3	.2808	37.5	90.8	440.8	60.4	731.0	60.4	66.9	45.0	.26	.24
4	.2790	38.0	93.4	394.2	61.4	727.5	61.4	66.4	45.4	.28	.21
5	.2805	38.2	91.6	473.1	61.6	751.6	61.6	66.5	45.3	.27	.26
6	.2761	37.5	95.1	268.4	61.7	720.8	61.7	66.9	44.1	.29	.13

AEF= .26

AQF=.140371E+06(BTU/HR)

AQNH=.36611E+05(BTU/HR)

TEST NUMBER : 14-3

DATE : 1/29/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 60.00(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.57(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .120

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .490

(R.H.)OUT = .800

(R.H.)ROOM = .400

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3488	37.5	95.1	268.4	61.7	720.8	61.7	66.9	44.1	.23	.12
1	.3469	37.6	95.3	505.2	62.7	762.7	62.7	66.7	45.2	.23	.26
2	.3488	38.4	98.0	524.8	63.9	856.6	63.9	66.1	44.6	.24	.28
3	.3436	39.0	98.7	528.1	64.8	825.6	64.8	66.3	46.1	.25	.28
4	.3451	38.3	101.4	479.1	65.1	800.2	65.1	67.0	44.4	.26	.26
5	.3488	38.4	103.6	340.6	66.0	879.9	66.0	66.3	47.5	.27	.17
6	.3414	40.1	104.4	319.3	67.3	869.7	67.3	67.1	47.1	.27	.16

AEF= .25

AQF=.174040E+06(BTU/HR)

AQNH=.43400E+05(BTU/HR)

AEFT= .25

AQFT=.140924E+06(BTU/HR)

AQNHT=.35423E+05(BTU/HR)

TEST NUMBER : 10-1

DATE : 12/18/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 67.50(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =11.45(LB/MIN)

MASS COMB AIR = 3.49(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .680

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2184	43.5	52.2	194.2	44.8	457.7	56.5	68.0	42.0	.05	.07
1	.2184	43.4	54.6	213.7	45.1	497.5	57.4	68.3	42.0	.07	.08
2	.2203	43.9	55.8	211.8	44.7	457.9	58.2	68.2	42.4	.08	.08
3	.2184	44.5	56.7	363.8	47.0	596.2	59.9	68.0	43.5	.09	.15
4	.2184	45.2	61.8	383.2	47.6	611.8	61.0	68.6	44.5	.11	.17
5	.2166	45.8	63.4	355.6	48.7	640.1	62.4	67.2	44.8	.12	.15
6	.2166	47.2	64.7	347.5	49.4	657.7	64.3	68.7	46.4	.12	.15

AEF= .09

AQF=.109681E+06(BTU/HR)

AQNH=.10138E+05(BTU/HR)

TEST NUMBER : 10-2

DATE : 12/18/78

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 67.50(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 4.46(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .680

(R.H.)ROOM = .420

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2794	47.2	64.7	347.5	49.4	658.0	64.3	68.7	46.4	.10	.14
1	.2794	47.2	74.0	260.8	47.9	650.9	65.2	68.4	46.8	.14	.10
2	.2830	47.4	69.5	365.8	49.2	601.0	66.0	70.5	47.3	.12	.16
3	.2849	47.0	66.6	268.1	49.3	611.9	66.5	71.1	46.7	.11	.10
4	.2852	47.2	70.1	377.9	48.2	604.2	67.2	70.8	46.6	.13	.16
5	.2801	47.1	73.3	440.5	49.1	802.0	67.6	68.4	46.4	.15	.20
6	.2856	46.0	76.7	499.6	48.7	736.4	67.6	68.6	45.6	.17	.24

AEF= .13

AQF=.142032E+06(BTU/HR)

AQNH=.18687E+05(BTU/HR)

TEST NUMBER : 10-3

DATE : 12/18/78

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 67.50(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.72(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .680

(R.H.)ROOM = .420

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3583	46.0	76.7	499.6	48.7	736.4	67.6	68.6	45.6	.14	.23
1	.3561	47.8	78.6	535.6	50.1	743.0	69.7	70.8	47.4	.14	.25
2	.3561	46.7	71.9	408.6	49.7	801.4	70.2	69.3	45.8	.12	.18
3	.3561	46.8	84.9	308.7	49.2	827.2	70.9	69.9	45.5	.17	.13
4	.3557	47.3	76.5	288.9	49.7	807.3	72.1	70.8	46.0	.14	.12
5	.3543	47.4	89.9	477.2	49.4	868.0	72.1	68.5	46.3	.19	.23
6	.3524	47.6	86.3	260.1	48.4	762.8	72.4	69.8	46.3	.17	.10

AEF= .15

AQF=.178759E+06(BTU/HR)

AQNH=.27203E+05(BTU/HR)

AEFT= .13

AQFT=.143491E+06(BTU/HR)

AQNHT=.18676E+05(BTU/HR)

TEST NUMBER : 12-1

DATE : 1/17/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 63.75(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS = 8.70(LB/MIN)

MASS COMB AIR = 3.62(LB/MIN)

%CO2 = .060

%CO = .020

%O2 = .120

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .440

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2269	56.9	61.1	86.1	53.0	136.6	61.5	69.8	56.9	.01	.01
1	.2232	57.7	62.6	347.7	52.5	285.4	61.9	70.5	57.7	.01	.13
2	.2232	58.7	65.6	376.3	53.1	514.8	65.1	71.4	58.7	.03	.15
3	.2239	59.2	82.7	393.2	53.6	497.7	67.6	72.2	59.2	.13	.17
4	.2206	58.8	70.0	402.2	54.0	401.5	68.3	71.1	58.8	.06	.16
5	.2203	59.1	75.1	399.0	54.4	418.1	69.5	71.2	59.1	.09	.17
6	.2203	59.5	92.0	240.7	54.8	363.0	71.5	72.0	59.5	.19	.10

AEF= .07

AQF=.111922E+06(BTU/HR)

AQNH=.83626E+04(BTU/HR)

TEST NUMBER : 12-2

DATE : 1/17/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 63.75(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 4.54(LB/MIN)

%CO2 = .060

%CO = .020

%O2 = .120

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .440

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2845	59.5	92.0	240.7	54.8	363.0	71.5	72.0	59.5	.16	.09
1	.2882	59.7	82.1	273.0	54.8	392.6	72.5	71.6	59.7	.11	.10
2	.2919	60.6	78.9	609.8	55.0	393.5	73.4	71.9	60.6	.10	.27
3	.2919	59.8	88.5	485.6	55.3	478.4	74.8	72.2	59.8	.15	.22
4	.2845	60.1	102.0	425.2	55.5	476.1	77.1	72.2	60.1	.21	.20
5	.2919	60.2	107.4	367.0	55.8	447.6	77.4	72.1	60.2	.23	.17
6	.2933	60.5	99.2	355.5	56.1	526.6	78.2	71.9	60.5	.20	.16

AEF= .16

AQF=.145512E+06(BTU/HR)

AQNH=.23950E+05(BTU/HR)

TEST NUMBER : 12-3

DATE : 1/17/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 63.75(LB/MIN)

MASS AIR OUT = 43.20(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.57(LB/MIN)

%CO₂ = .060

%CO = .020

%O₂ = .120

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .440

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3488	60.5	99.2	355.5	56.1	526.6	78.2	71.9	60.5	.17	.15
1	.3678	60.1	104.2	518.1	55.9	580.2	79.1	72.7	60.1	.18	.24
2	.3671	60.6	94.0	532.8	56.1	552.3	80.1	71.8	60.6	.15	.24
3	.3616	60.5	110.8	562.3	56.3	653.8	81.5	72.5	60.5	.21	.28
4	.3671	61.1	108.7	521.0	56.5	622.3	82.7	72.1	61.1	.20	.25
5	.3488	60.4	113.2	391.2	56.0	563.7	82.8	71.3	60.4	.23	.18
6	.3634	60.4	114.6	336.2	56.1	605.9	82.9	71.6	60.4	.23	.15

AEF= .19

AQF=.181316E+06(BTU/HR)

AQNH=.35139E+05(BTU/HR)

AEFT= .14

AQFT=.146250E+06(BTU/HR)

AQNHT=.22484E+05(BTU/HR)

TEST NUMBER : 4A-1

DATE : 6/27/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 96.75(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 3.52(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .590

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	74.4	78.5	100.0	77.9	273.0	77.9	75.4	86.8	.05	.01
1	.2214	74.2	80.2	231.9	78.0	319.6	78.0	75.2	88.7	.07	.08
2	.2221	75.0	84.2	404.9	79.5	346.5	79.5	75.1	89.6	.11	.17
3	.2203	75.5	88.2	375.4	80.5	367.3	80.5	75.7	88.2	.15	.16
4	.2250	74.6	86.6	198.7	80.3	361.9	80.3	75.5	86.8	.14	.06
5	.2221	76.4	84.0	406.3	79.7	411.2	79.7	74.7	81.5	.09	.16
6	.2203	75.0	88.7	403.3	79.7	446.3	79.7	74.9	80.8	.16	.18

AEF= .11

AQF=.111421E+06(BTU/HR)

AQNH=.12546E+05(BTU/HR)

TEST NUMBER : 4A-2

DATE : 6/27/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 96.75(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 4.52(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .590

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2830	75.0	88.7	403.3	79.7	446.3	79.7	74.9	80.8	.13	.17
1	.2823	74.8	93.6	413.6	80.6	473.6	80.6	75.1	83.0	.18	.18
2	.2852	74.2	105.1	439.0	83.7	511.9	83.7	75.4	80.3	.29	.23
3	.2827	75.5	97.5	434.5	83.8	515.2	83.8	75.2	82.1	.21	.20
4	.2838	76.3	100.5	422.4	85.5	562.9	85.5	76.3	81.5	.23	.20
5	.2834	77.4	96.9	331.3	86.1	564.1	86.1	75.8	81.9	.19	.14
6	.2808	76.4	97.8	285.0	86.2	552.9	86.2	75.9	82.3	.21	.11

AEF= .20

AQF=.142295E+06(BTU/HR)

AQNH=.29089E+05(BTU/HR)

TEST NUMBER : 4A-3

DATE : 6/27/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 96.75(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =12.13(LB/MIN)

MASS COMB AIR = 5.62(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .590

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3524	76.4	97.8	285.0	86.2	552.9	86.2	75.9	82.3	.17	.11
1	.3488	74.1	97.7	322.7	85.5	539.3	85.5	75.9	82.5	.19	.13
2	.3513	80.3	106.3	543.0	92.0	599.4	92.0	76.6	80.5	.21	.26
3	.3554	80.3	104.7	548.7	91.7	642.3	91.7	76.2	78.4	.19	.26
4	.3524	77.1	109.3	550.0	93.1	627.5	93.1	77.2	81.2	.25	.28
5	.3469	77.8	108.7	373.8	91.9	628.1	91.9	77.5	81.3	.25	.17
6	.3568	78.0	106.9	342.6	92.2	619.4	92.2	77.0	80.8	.23	.15

AEF= .21

AQF=.176966E+06(BTU/HR)

AQNH=.37337E+05(BTU/HR)

AEFT= .18

AQFT=.143561E+06(BTU/HR)

AQNHT=.26324E+05(BTU/HR)

TEST NUMBER : 6-1

DATE : 11/20/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =14.89(LB/MIN)

MASS COMB AIR = 3.50(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .750

(R.H.)OUT = .580

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2192	56.6	66.2	127.6	63.1	515.7	63.2	69.0	55.1	.12	.03
1	.2155	55.9	70.7	322.0	66.1	612.5	63.9	68.1	52.9	.18	.14
2	.2184	57.2	71.2	343.3	67.1	660.6	65.5	68.0	54.4	.18	.15
3	.2184	56.3	73.0	359.5	67.9	649.8	66.1	68.3	54.4	.21	.17
4	.2184	57.1	73.6	303.2	68.6	679.3	68.4	68.1	55.4	.22	.14
5	.2184	57.6	74.0	227.0	66.9	665.6	69.1	68.8	54.2	.22	.09
6	.2203	55.4	73.5	212.8	66.8	707.1	68.5	69.5	53.4	.24	.09

AEF= .19

AQF=.109787E+06(BTU/HR)

AQNH=.21366E+05(BTU/HR)

TEST NUMBER : 6-2

DATE : 11/20/78

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =16.61(LB/MIN)

MASS COMB AIR = 4.52(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .750

(R.H.)OUT = .580

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2830	56.8	74.3	143.7	66.2	622.9	68.2	68.9	55.0	.18	.04
1	.2834	57.3	71.0	318.6	68.7	631.5	69.1	68.6	55.0	.14	.13
2	.2823	57.3	76.4	247.7	68.2	628.0	69.7	68.4	55.3	.20	.10
3	.2823	59.1	78.8	420.0	71.5	668.8	71.8	68.4	55.9	.20	.20
4	.2808	58.2	79.8	302.1	71.2	694.7	73.1	68.8	55.0	.23	.14
5	.2827	60.6	81.4	244.4	71.3	690.5	75.0	68.6	57.3	.22	.10
6	.2819	59.1	79.4	227.8	71.2	706.4	74.4	68.4	56.0	.22	.09

AEF= .20

AQF=.141953E+06(BTU/HR)

AQNH=.28248E+05(BTU/HR)

TEST NUMBER : 6-3

DATE : 11/20/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =16.72(LB/MIN)

MASS COMB AIR = 5.62(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .750

(R.H.)OUT = .580

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3521	60.8	78.1	153.9	69.3	562.2	73.9	68.5	57.3	.15	.04
1	.3499	59.7	80.1	460.1	72.1	587.3	73.3	68.1	55.4	.17	.21
2	.3517	60.9	83.0	438.4	75.0	713.7	77.4	68.8	55.7	.19	.20
3	.3488	59.4	84.1	451.3	75.2	796.0	77.3	68.7	57.2	.22	.22
4	.3495	61.0	86.0	443.7	78.0	811.9	80.6	69.4	59.0	.22	.21
5	.3499	61.9	92.2	391.2	77.6	823.1	82.0	69.3	56.6	.27	.19
6	.3517	64.6	85.8	257.8	76.5	845.2	84.1	69.1	58.4	.20	.10

AEF= .20

AQF= .176202E+06(BTU/HR)

AQNH= .35750E+05(BTU/HR)

AEFT= .20

AQFT= .142647E+06(BTU/HR)

AQNHT= .28455E+05(BTU/HR)

TEST NUMBER : 7-1

DATE : 11/27/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =14.88(LB/MIN)

MASS COMB AIR = 3.52(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .690

(R.H.)OUT = .850

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	55.3	62.0	115.4	63.8	447.8	60.4	67.1	53.6	.07	.03
1	.2203	55.2	62.9	363.0	61.2	511.7	61.6	67.6	53.8	.09	.15
2	.2206	55.1	66.0	336.3	62.0	561.3	63.3	67.0	54.0	.14	.14
3	.2203	55.0	66.1	367.6	62.8	600.0	64.7	67.1	54.1	.14	.16
4	.2214	54.5	68.6	275.9	62.8	615.2	64.8	67.9	54.4	.18	.12
5	.2203	54.4	71.5	211.3	63.4	621.7	65.8	67.0	53.5	.22	.09
6	.2203	54.9	68.7	182.6	63.7	630.4	66.6	67.4	52.7	.18	.07

AEF= .15

AQF=.110841E+06(BTU/HR)

AQNH=.16389E+05(BTU/HR)

TEST NUMBER : 7-2

DATE : 11/27/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =15.11(LB/MIN)

MASS COMB AIR = 4.58(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .690

(R.H.)OUT = .850

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2867	54.9	68.7	182.6	63.7	630.4	66.6	67.4	52.7	.14	.06
1	.2845	57.4	69.0	382.5	64.4	617.6	68.9	67.2	52.6	.13	.16
2	.2838	56.8	73.8	393.6	64.9	690.1	69.8	67.0	53.2	.18	.18
3	.2827	54.8	76.4	392.4	64.9	665.4	69.6	67.3	52.9	.23	.19
4	.2882	55.0	72.1	342.6	65.7	660.8	71.2	66.9	53.1	.19	.15
5	.2834	55.4	71.7	225.4	66.9	663.1	72.3	67.1	54.0	.18	.09
6	.2830	55.4	74.0	203.9	66.6	695.9	72.4	67.4	53.7	.20	.08

AEF= .18

AQF=.143086E+06(BTU/HR)

AQNH=.25518E+05(BTU/HR)

TEST NUMBER : 7-3

DATE : 11/27/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =16.48(LB/MIN)

MASS COMB AIR = 5.76(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .690

(R.H.)OUT = .850

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3609	55.4	74.0	203.9	66.6	695.9	72.4	67.4	53.7	.16	.07
1	.3568	55.3	71.9	405.6	66.8	674.8	73.1	66.8	54.0	.15	.18
2	.3561	55.4	73.6	455.4	67.6	722.9	74.7	67.3	54.0	.17	.21
3	.3543	55.4	80.6	464.7	68.1	711.0	75.5	68.1	53.9	.22	.23
4	.3568	55.4	73.6	410.3	68.8	734.7	77.0	67.4	54.4	.17	.18
5	.3532	55.6	82.0	277.1	69.3	708.2	77.6	67.7	54.1	.24	.12
6	.3598	55.7	77.3	235.1	69.4	678.5	77.9	67.2	54.4	.20	.09

AEF= .19

AQF= .179392E+06(BTU/HR)

AQNH= .33424E+05(BTU/HR)

AEFT= .17

AQFT= .144440E+06(BTU/HR)

AQNHT= .25110E+05(BTU/HR)

TEST NUMBER : 15-1

DATE : 2/5/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 91.44(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 3.41(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .400

(R.H.)OUT = .700

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2137	34.9	43.8	107.3	47.0	280.0	47.0	66.8	45.8	.09	.03
1	.2166	35.9	43.5	278.6	47.8	437.1	47.8	67.3	46.0	.07	.11
2	.2140	35.3	45.2	367.6	49.2	512.0	49.2	67.4	45.9	.11	.16
3	.2133	36.2	47.1	382.8	50.2	522.1	50.2	68.0	47.8	.12	.17
4	.2140	36.4	47.7	400.4	52.0	617.0	52.0	67.5	45.7	.13	.18
5	.2170	36.1	49.1	302.1	52.6	588.1	52.6	67.9	47.9	.15	.13
6	.2166	36.7	47.4	251.9	53.8	575.6	53.8	68.0	46.3	.13	.10

AEF= .12

AQF=,108099E+06(BTU/HR)

AQNH=,12434E+05(BTU/HR)

TEST NUMBER : 15-2

DATE : 2/5/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 91.44(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 4.44(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .400

(R.H.)OUT = .700

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2779	36.7	47.4	251.9	53.8	575.6	53.8	68.0	46.3	.10	.10
1	.2790	36.5	49.2	343.8	53.1	647.2	53.1	68.3	44.9	.12	.15
2	.2849	37.2	50.1	375.0	55.3	649.7	55.3	68.2	43.4	.12	.17
3	.2801	37.1	50.6	463.2	55.6	640.0	55.6	68.1	47.9	.13	.21
4	.2753	37.3	53.1	443.9	56.5	705.5	56.5	69.0	48.4	.15	.21
5	.2838	36.8	51.6	356.5	57.9	670.5	57.9	67.8	47.4	.14	.16
6	.2823	36.8	57.2	304.1	57.9	631.9	57.9	68.5	46.7	.20	.14

AEF= .14

AQF=.141003E+06(BTU/HR)

AQNH=.19195E+05(BTU/HR)

TEST NUMBER : 15-3

DATE : 2/5/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 91.44(LB/MIN)

MASS DRY FLUE GAS =13.05(LB/MIN)

MASS COMB AIR = 5.61(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .400

(R.H.)OUT = .700

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3513	36.8	57.2	304.1	57.9	631.9	57.9	68.5	46.7	.16	.13
1	.3521	36.6	53.0	394.5	58.7	712.7	58.7	68.0	46.6	.13	.18
2	.3414	36.3	50.4	472.2	59.3	715.9	59.3	68.5	45.8	.12	.21
3	.3436	36.1	54.0	511.0	59.5	697.7	59.5	68.3	45.0	.15	.24
4	.3429	36.3	52.8	508.8	60.6	696.5	60.6	68.4	46.7	.14	.24
5	.3458	37.1	55.5	442.6	61.7	806.3	61.7	68.7	45.9	.15	.21
6	.3388	36.9	53.8	341.0	62.6	896.1	62.6	67.2	47.1	.15	.15

AEF= .14

AQF=.173512E+06(BTU/HR)

AQNH=.24324E+05(BTU/HR)

AEFT= .13

AQFT=.140872E+06(BTU/HR)

AQNHT=.18651E+05(BTU/HR)

TEST NUMBER : 5-1

DATE : 11/13/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =13.74(LB/MIN)

MASS COMB AIR = 3.47(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .780

(R.H.)OUT = .580

(R.H.)ROOM = .450

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2173	69.9	77.6	118.9	72.6	638.7	72.2	75.7	67.5	.09	.02
1	.2184	68.1	74.3	371.4	72.9	739.1	71.1	76.2	66.7	.07	.15
2	.2195	70.0	77.1	372.6	75.1	822.2	72.1	75.5	66.7	.08	.15
3	.2166	69.7	78.5	365.0	74.4	883.4	72.3	75.1	67.2	.10	.15
4	.2184	71.2	80.5	379.9	75.0	895.3	73.3	76.4	67.3	.11	.16
5	.2170	70.2	81.2	360.5	74.0	862.0	73.2	76.0	66.9	.13	.15
6	.2173	72.0	84.1	282.9	75.1	776.1	74.5	75.8	69.2	.15	.11

AEF= .10

ARF=.109496E+06(BTU/HR)

AQNH=.11462E+05(BTU/HR)

TEST NUMBER : 5-2

DATE : 11/13/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =16.26(LB/MIN)

MASS COMB AIR = 4.52(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .780

(R.H.)OUT = .580

(R.H.)ROOM = .450

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2834	72.0	84.1	282.9	75.1	776.1	74.5	75.8	69.2	.11	.11
1	.2856	71.7	83.4	358.3	74.2	833.7	74.8	75.7	67.9	.11	.15
2	.2845	72.1	85.0	442.5	76.9	897.4	75.3	75.4	66.3	.12	.19
3	.2845	72.2	89.1	497.2	79.1	945.8	76.3	75.3	69.0	.16	.23
4	.2856	72.6	88.4	465.0	79.0	837.3	76.6	76.2	68.2	.15	.21
5	.2845	73.6	85.5	329.2	75.9	830.5	77.5	76.3	68.6	.12	.13
6	.2845	74.6	89.0	280.5	76.6	815.6	78.4	75.2	68.8	.14	.11

AEF= .13

AQF=.143113E+06(BTU/HR)

AQNH=.18747E+05(BTU/HR)

TEST NUMBER : 5-3

DATE : 11/13/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =17.64(LB/MIN)

MASS COMB AIR = 5.69(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .780

(R.H.)OUT = .580

(R.H.)ROOM = .450

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3568	74.6	89.0	280.5	76.6	815.6	78.5	75.2	68.8	.12	.10
1	.3590	70.7	87.2	507.4	77.8	997.6	76.9	76.2	69.1	.13	.23
2	.3601	74.0	91.0	526.9	79.4	970.6	79.2	75.9	70.2	.13	.24
3	.3598	73.0	91.4	512.1	79.2	943.2	78.7	75.4	68.7	.14	.23
4	.3532	73.1	95.8	503.4	80.3	937.0	79.0	75.8	68.3	.18	.24
5	.3579	70.8	96.0	373.0	79.0	973.3	78.3	75.4	69.7	.20	.17
6	.3543	71.1	91.4	322.4	77.5	958.9	78.5	76.4	68.3	.16	.13

AEF= .15

AQF=.179629E+06(BTU/HR)

AQNH=.27059E+05(BTU/HR)

AEFT= .13

AQFT=.144079E+06(BTU/HR)

AQNHT=.19089E+05(BTU/HR)

TEST NUMBER : 8-1

DATE : 12/4/78

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =15.58(LB/MIN)

MASS COMB AIR = 3.52(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .650

(R.H.)OUT = .900

(R.H.)ROOM = .540

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	60.7	65.7	131.1	65.3	429.4	64.4	78.3	60.7	.04	.03
1	.2195	60.6	67.3	240.5	64.0	485.8	64.7	78.1	60.7	.07	.09
2	.2203	61.1	68.8	223.5	65.0	516.3	65.8	78.1	59.6	.08	.08
3	.2203	63.2	69.7	228.0	65.0	584.6	67.7	76.4	61.5	.07	.08
4	.2173	61.4	71.2	377.0	64.1	623.2	68.0	79.4	60.5	.11	.16
5	.2166	60.3	71.2	269.1	64.4	602.0	68.4	76.2	60.4	.14	.11
6	.2184	63.8	73.0	245.9	64.2	632.6	70.6	79.2	60.6	.11	.09

AEF= .09

AQF=.110077E+06(BTU/HR)

AQNH=.98043E+04(BTU/HR)

TEST NUMBER : 8-2

DATE : 12/4/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =17.18(LB/MIN)

MASS COMB AIR = 4.54(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .650

(R.H.)OUT = .900

(R.H.)ROOM = .540

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2845	63.8	73.0	245.9	64.2	632.6	70.6	79.2	60.6	.09	.09
1	.2830	60.5	71.5	422.6	64.6	611.8	69.6	76.7	60.9	.11	.18
2	.2775	60.7	72.4	452.8	65.4	629.5	70.4	79.5	60.2	.12	.20
3	.2838	60.6	73.7	465.4	64.4	618.7	71.4	77.0	60.5	.13	.21
4	.2834	60.2	73.4	398.5	64.2	642.8	71.9	78.4	60.2	.14	.17
5	.2823	60.2	74.3	297.8	64.2	667.3	72.2	77.3	60.3	.15	.12
6	.2808	60.3	72.6	275.9	64.3	680.5	72.6	79.5	59.8	.13	.11

AEF= .12

AQF=.141874E+06(BTU/HR)

AQNH=.17529E+05(BTU/HR)

TEST NUMBER : 8-3

DATE : 12/4/78

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =105.00(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =17.75(LB/MIN)

MASS COMB AIR = 5.68(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .650

(R.H.)OUT = .900

(R.H.)ROOM = .540

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3561	60.3	72.6	275.9	64.3	680.5	72.6	79.5	59.8	.10	.10
1	.3506	60.3	74.8	470.2	64.2	687.6	73.8	77.6	60.6	.13	.21
2	.3506	59.6	77.5	498.0	65.0	680.4	74.2	78.7	60.4	.15	.23
3	.3488	59.2	76.7	495.5	64.9	699.2	75.0	78.5	59.3	.15	.23
4	.3510	58.9	76.3	498.7	64.5	719.4	75.0	77.0	60.0	.15	.23
5	.3506	58.7	75.6	342.1	64.6	734.1	75.2	78.7	59.1	.15	.14
6	.3506	58.7	75.5	302.1	65.0	681.8	75.2	78.3	60.3	.15	.12

AEF= .14

AQF=.176544E+06(BTU/HR)

AQNH=.25051E+05(BTU/HR)

AEFT= .12

AQFT=.142831E+06(BTU/HR)

AQNHT=.17462E+05(BTU/HR)

TEST NUMBER : 20-1

DATE : 3/5/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =165.00(LB/MIN)

MASS AIR OUT =154.80(LB/MIN)

MASS DRY FLUE GAS =12.59(LB/MIN)

MASS COMB AIR = 3.39(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .580

(R.H.)OUT = .510

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2122	53.8	58.3	102.5	56.6	455.7	56.6	61.6	65.1	.09	.02
1	.2166	54.4	60.7	236.9	57.3	579.2	57.3	62.8	64.9	.12	.09
2	.2129	54.4	62.4	322.1	57.7	556.3	57.7	62.6	61.1	.16	.14
3	.2173	54.9	62.1	291.5	58.8	762.1	58.8	63.1	62.1	.14	.12
4	.2173	55.3	62.6	327.6	58.9	861.5	58.9	62.5	62.1	.15	.14
5	.2170	54.9	63.7	232.7	59.0	748.6	59.0	62.5	62.1	.18	.10
6	.2181	54.9	62.6	188.2	59.0	836.6	59.0	63.2	61.6	.15	.07

AEF= .14

AQF=.108547E+06(BTU/HR)

AQNH=.15334E+05(BTU/HR)

TEST NUMBER : 20-2

DATE : 3/5/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =165.00(LB/MIN)

MASS AIR OUT =154.80(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 4.55(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .580

(R.H.)OUT = .510

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2849	54.9	62.6	188.2	59.0	836.6	59.0	63.2	61.6	.12	.07
1	.2783	58.0	65.4	174.4	61.2	738.7	61.2	62.4	61.6	.12	.06
2	.2768	57.2	64.7	386.5	61.7	891.3	61.7	63.6	62.9	.12	.17
3	.2797	55.5	65.0	370.1	61.1	914.8	61.1	62.3	61.3	.15	.17
4	.2775	56.1	66.8	363.0	61.5	902.4	61.5	61.8	61.5	.17	.17
5	.2783	55.5	64.9	355.2	61.3	974.2	61.3	62.6	61.1	.15	.16
6	.2801	56.2	67.0	269.1	61.7	863.0	61.7	62.6	60.1	.17	.11

AEF= .14

AQF=.140450E+06(BTU/HR)

AQNH=.20246E+05(BTU/HR)

TEST NUMBER : 20-3

DATE : 3/5/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =165.00(LB/MIN)

MASS AIR OUT =154.80(LB/MIN)

MASS DRY FLUE GAS =13.96(LB/MIN)

MASS COMB AIR = 5.64(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .580

(R.H.)OUT = .510

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)							COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT									
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%
0	.3532	56.2	67.0	269.1	61.7	863.0	61.7	62.6	60.1	.14
1	.3532	56.3	67.1	222.6	62.0	891.5	62.0	62.4	61.2	.14
2	.3524	57.9	68.1	426.6	63.7	948.2	63.7	62.9	59.8	.13
3	.3539	58.1	69.5	446.3	65.0	770.5	65.0	62.3	61.6	.15
4	.3524	58.1	68.9	436.6	65.0	803.8	65.0	63.1	60.5	.14
5	.3554	57.6	69.0	405.8	65.5	881.3	65.5	62.9	59.5	.15
6	.3524	57.8	70.4	292.2	65.5	809.5	65.5	63.0	60.7	.17

AEF= .15

AQF=.177599E+06(BTU/HR)

AQNH=.25763E+05(BTU/HR)

AEFT= .14

AQFT=.142199E+06(BTU/HR)

AQNHT=.20447E+05(BTU/HR)

TEST NUMBER : 16-1

DATE : 3/28/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =148.50(LB/MIN)

MASS AIR OUT =136.80(LB/MIN)

MASS DRY FLUE GAS =12.59(LB/MIN)

MASS COMB AIR = 3.46(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .660

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2170	63.0	64.9	80.7	71.0	435.0	64.9	66.3	67.5	.03	.01
1	.2206	64.9	67.7	151.2	67.7	556.6	67.2	66.8	68.0	.05	.04
2	.2214	64.5	69.0	222.9	67.5	563.5	67.8	66.9	68.1	.08	.08
3	.2195	66.2	71.5	328.2	68.3	701.3	69.3	66.7	69.2	.10	.13
4	.2228	65.8	71.7	286.9	93.7	782.7	69.8	66.6	70.7	.10	.11
5	.2206	64.7	72.1	270.3	67.6	743.9	69.4	66.6	68.6	.14	.11
6	.2199	66.8	72.1	184.4	88.8	677.2	70.7	66.6	70.8	.09	.06

AEF= .09

AQF=.110736E+06(BTU/HR)

AQNH=.94783E+04(BTU/HR)

TEST NUMBER : 16-2

DATE : 3/28/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =148.50(LB/MIN)

MASS AIR OUT =136.80(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 4.57(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .660

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2863	66.8	72.1	184.4	88.8	677.4	70.7	66.6	70.8	.07	.06
1	.2871	65.8	73.1	368.9	69.0	674.8	71.1	66.7	68.6	.11	.15
2	.2885	67.1	75.0	411.8	69.6	699.4	72.6	67.3	70.1	.12	.18
3	.2863	66.4	76.5	401.1	70.1	665.5	72.6	67.1	69.6	.15	.18
4	.2863	67.7	78.3	355.5	71.3	693.2	76.0	67.1	69.2	.17	.15
5	.2863	67.4	79.9	288.9	71.9	873.9	77.1	67.5	70.6	.20	.12
6	.2882	68.3	79.3	280.3	72.5	902.3	77.8	67.3	72.4	.17	.11

AEF= .14

AQF=.144299E+06(BTU/HR)

AQNH=.20344E+05(BTU/HR)

TEST NUMBER : 16-3

DATE : 3/28/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =148.50(LB/MIN)

MASS AIR OUT =136.80(LB/MIN)

MASS DRY FLUE GAS =13.96(LB/MIN)

MASS COMB AIR = 5.73(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .660

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3590	68.3	79.3	280.3	72.5	902.3	77.8	67.3	72.4	.14	.11
1	.3590	68.5	81.2	466.3	73.9	905.7	80.0	67.7	73.3	.16	.21
2	.3554	67.5	79.3	491.5	73.6	796.3	77.8	67.5	71.5	.15	.22
3	.3616	71.7	83.4	456.9	76.1	780.4	83.3	67.7	72.9	.16	.20
4	.3568	70.3	84.7	381.7	75.7	771.9	82.7	68.2	71.0	.19	.17
5	.3598	70.8	84.4	363.0	75.6	775.8	83.0	67.8	70.7	.18	.16
6	.3616	72.9	84.9	378.1	77.7	766.2	85.7	68.5	70.4	.16	.16

AEF= .16

AQF=.180499E+06(BTU/HR)

AQNH=.29287E+05(BTU/HR)

AEFT= .13

AQFT=.145178E+06(BTU/HR)

AQNHT=.19703E+05(BTU/HR)

TEST NUMBER : 18-1

DATE : 2/23/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =161.25(LB/MIN)

MASS AIR OUT =144.00(LB/MIN)

MASS DRY FLUE GAS =12.59(LB/MIN)

MASS COMB AIR = 3.43(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .860

(R.H.)OUT = .960

(R.H.)ROOM = .600

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2148	60.0	62.7	80.9	65.0	137.2	63.0	71.7	60.9	.04	.01
1	.2155	60.4	63.2	352.1	64.5	259.7	62.9	70.5	61.4	.04	.14
2	.2188	60.5	65.4	331.4	67.0	344.8	63.4	71.4	60.4	.08	.13
3	.2162	60.6	66.1	323.6	69.0	442.0	63.6	70.5	64.0	.10	.13
4	.2173	60.9	69.0	301.2	70.1	504.8	64.5	71.7	63.0	.15	.13
5	.2151	61.6	69.4	289.4	70.9	594.5	65.3	71.6	62.8	.15	.12
6	.2170	61.6	70.2	201.9	71.8	380.1	65.2	70.9	62.4	.16	.07

AEF= .10

AQF=.108785E+06(BTU/HR)

AQNH=.11326E+05(BTU/HR)

TEST NUMBER : 18-2

DATE : 2/23/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =161.25(LB/MIN)

MASS AIR OUT =144.00(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 4.52(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .860

(R.H.)OUT = .960

(R.H.)ROOM = .600

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2830	61.6	70.2	201.9	71.8	380.1	65.2	70.9	62.4	.12	.07
1	.2827	61.9	69.7	273.9	72.1	468.8	65.5	72.1	63.1	.11	.11
2	.2834	61.6	68.6	401.3	71.4	751.8	65.5	70.7	63.0	.10	.17
3	.2830	61.3	70.7	409.1	73.3	573.4	65.9	72.4	63.1	.13	.18
4	.2827	62.0	71.3	363.8	75.3	691.1	66.9	70.6	63.5	.14	.16
5	.2845	61.9	72.1	258.3	75.0	818.4	66.5	71.8	62.9	.15	.10
6	.2856	61.8	71.5	236.6	75.4	515.6	66.6	70.1	63.8	.14	.09

AEF= .13

AQF=.142559E+06(BTU/HR)

AQNH=.18201E+05(BTU/HR)

TEST NUMBER : 18-3

DATE : 2/23/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =161.25(LB/MIN)

MASS AIR OUT =144.00(LB/MIN)

MASS DRY FLUE GAS =13.96(LB/MIN)

MASS COMB AIR = 5.68(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .860

(R.H.)OUT = .960

(R.H.)ROOM = .600

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3561	61.8	71.5	236.6	75.4	515.6	66.6	70.1	63.8	.11	.09
1	.3605	62.1	72.2	304.0	121.0	521.1	66.9	71.5	63.1	.11	.12
2	.3561	62.1	72.3	470.9	137.7	658.9	68.2	71.4	63.5	.11	.21
3	.3598	61.9	74.3	472.9	148.1	656.0	68.7	71.1	63.1	.13	.21
4	.3561	62.1	74.9	465.0	145.6	639.7	68.7	72.2	63.9	.14	.21
5	.3568	62.3	73.0	466.4	139.3	517.1	68.7	70.2	63.6	.12	.21
6	.3656	62.1	74.9	343.3	134.8	903.0	68.9	72.8	64.1	.14	.15

AEF= .12

AQF=.180341E+06(BTU/HR)

AQNH=.21842E+05(BTU/HR)

AEFT= .12

AQFT=.143895E+06(BTU/HR)

AQNHT=.17123E+05(BTU/HR)

TEST NUMBER : 21-1

DATE : 3/12/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =165.00(LB/MIN)

MASS AIR OUT =151.20(LB/MIN)

MASS DRY FLUE GAS =12.36(LB/MIN)

MASS COMB AIR = 3.43(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .440

(R.H.)ROOM = .480

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2151	58.2	63.4	132.2	64.2	482.4	64.2	69.3	69.4	.11	.03
1	.2159	59.2	62.8	352.3	63.1	527.5	63.1	70.9	67.2	.06	.14
2	.2166	57.1	62.6	267.4	61.1	540.8	61.1	71.8	67.2	.10	.10
3	.2181	57.3	63.7	391.7	60.9	568.9	60.9	71.5	66.8	.11	.17
4	.2148	58.2	63.2	368.5	61.1	594.8	61.1	72.5	64.5	.09	.15
5	.2166	60.1	65.1	261.2	62.5	589.3	62.5	69.9	63.5	.09	.10
6	.2166	59.6	65.1	231.0	62.2	568.5	62.2	72.2	67.4	.10	.09

AEF= .09

ARF=.108706E+06(BTU/HR)

ARQH=.10175E+05(BTU/HR)

TEST NUMBER : 21-2

DATE : 3/12/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =165.00(LB/MIN)

MASS AIR OUT =151.20(LB/MIN)

MASS DRY FLUE GAS =12.36(LB/MIN)

MASS COMB AIR = 4.43(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .440

(R.H.)ROOM = .480

FUEL		TEMPERATURE(F)								COMB AIR/	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2775	59.6	65.1	231.0	62.2	568.5	62.2	72.2	67.4	.08	.08
1	.2775	59.2	65.1	412.9	61.9	577.5	61.9	66.0	66.4	.09	.18
2	.2783	62.2	66.5	418.6	63.9	571.6	63.9	71.9	66.1	.06	.17
3	.2772	62.0	66.8	443.3	63.8	549.8	63.8	71.7	65.4	.07	.19
4	.2724	61.6	66.9	432.3	63.9	543.9	63.9	71.8	66.2	.08	.18
5	.2731	60.7	67.1	337.0	63.7	558.4	63.7	73.3	66.3	.09	.14
6	.2761	62.6	68.4	288.3	65.0	552.1	65.0	70.7	65.9	.09	.11

AEF= .08

AQF=.138762E+06(BTU/HR)

AQNH=.10728E+05(BTU/HR)

TEST NUMBER : 21-3

DATE : 3/12/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =165.00(LB/MIN)

MASS AIR OUT =151.20(LB/MIN)

MASS DRY FLUE GAS =12.36(LB/MIN)

MASS COMB AIR = 5.62(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .450

(R.H.)OUT = .440

(R.H.)ROOM = .480

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3524	62.6	68.4	288.3	65.0	552.1	65.0	70.7	65.9	.07	.11
1	.3473	62.5	68.9	462.9	65.2	588.3	65.2	73.1	66.0	.07	.20
2	.3510	63.1	69.3	458.0	65.9	596.1	65.9	71.9	65.8	.07	.19
3	.3480	62.2	70.0	487.1	65.7	579.2	65.7	73.4	65.9	.09	.21
4	.3484	62.8	70.7	457.3	66.1	569.9	66.1	74.4	66.4	.09	.20
5	.3491	63.4	70.7	461.1	66.7	585.2	66.7	72.3	63.4	.09	.20
6	.3502	63.1	70.2	323.9	66.5	579.3	66.5	74.2	65.2	.08	.13

AEF= .08

AQF=.175701E+06(BTU/HR)

AQNH=.14231E+05(BTU/HR)

AEFT= .08

AQFT=.141056E+06(BTU/HR)

AQNHT=.11711E+05(BTU/HR)

TEST NUMBER : 17-1

DATE : 3/19/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =161.25(LB/MIN)

MASS AIR OUT =147.60(LB/MIN)

MASS DRY FLUE GAS =13.05(LB/MIN)

MASS COMB AIR = 3.53(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .520

(R.H.)OUT = .680

(R.H.)ROOM = .380

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2210	73.2	74.5	99.0	73.9	210.7	73.9	77.0	79.5	.02	.01
1	.2181	75.3	76.8	232.2	75.5	385.9	75.5	76.7	77.5	.02	.07
2	.2236	78.0	79.7	240.4	77.5	430.6	77.5	76.7	78.7	.03	.08
3	.2232	76.0	79.6	266.5	76.8	471.2	76.8	77.7	79.8	.06	.09
4	.2214	77.9	80.4	248.6	77.8	499.3	77.8	77.4	78.9	.04	.08
5	.2258	78.3	81.3	242.7	78.7	483.1	78.7	77.9	78.0	.05	.08
6	.2214	77.2	80.9	191.1	77.9	404.9	77.9	77.7	78.8	.07	.06

AEF= .04

AQF=.111632E+06(BTU/HR)

AQNH=.47304E+04(BTU/HR)

TEST NUMBER : 17-2

DATE : 3/19/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =161.25(LB/MIN)

MASS AIR OUT =147.60(LB/MIN)

MASS DRY FLUE GAS =13.73(LB/MIN)

MASS COMB AIR = 4.49(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .520

(R.H.)OUT = .680

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2812	77.2	80.9	191.1	77.9	404.9	77.9	77.7	78.8	.05	.05
1	.2794	77.6	80.8	318.0	78.3	616.9	78.3	77.6	79.4	.05	.11
2	.2823	75.5	80.8	262.4	77.0	566.6	77.0	77.2	77.5	.08	.09
3	.2819	79.8	83.8	292.4	80.2	635.5	80.2	77.6	77.1	.06	.10
4	.2812	76.9	81.8	284.4	78.2	537.2	78.2	77.5	79.3	.07	.10
5	.2801	76.5	82.4	243.3	78.3	458.5	78.3	77.9	70.3	.09	.08
6	.2834	74.5	79.9	219.3	76.8	407.8	76.8	77.8	77.9	.08	.07

AEF= .07

AQF=.141452E+06(BTU/HR)

AQNH=.96549E+04(BTU/HR)

TEST NUMBER : 17-3

DATE : 3/19/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/

MASS AIR IN =161.25(LB/MIN)

MASS AIR OUT =147.60(LB/MI

MASS DRY FLUE GAS =14.88(LB/MIN)

MASS COMB AIR = 5.61(LB/MI

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .520

(R.H.)OUT = .680

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB	
TIME WEIGHT										EFF TOT	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	
0	.3517	74.5	79.9	219.3	76.8	407.8	76.8	77.8	77.9	.06	.
1	.3517	74.5	81.1	300.3	77.0	551.9	77.0	77.9	77.7	.08	.
2	.3488	77.4	83.2	361.3	78.8	687.6	78.8	77.6	78.7	.07	
3	.3465	77.0	83.5	362.4	78.8	704.4	78.8	77.8	79.4	.08	
4	.3590	76.0	82.7	309.0	78.3	662.0	78.3	78.9	78.3	.08	
5	.3535	75.0	82.6	249.0	78.1	530.0	78.1	78.8	79.7	.09	
6	.3561	76.1	82.8	226.8	78.7	474.7	78.7	78.8	79.7	.08	

AEF= .08

AQF=.177203E+06(BTU/HR)

AQNH=.13668E+05(BT

AEFT= .06

AQFT=.143429E+06(BTU/HR)

AQNHT=.93510E+04(

TEST NUMBER : 22-1

DATE : 4/2/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 88.50(LB/MIN)

MASS AIR OUT = 84.24(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 3.52(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .600

(R.H.)OUT = .720

(R.H.)ROOM = .660

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	68.8	71.6	137.5	71.8	524.7	71.0	72.3	71.2	.03	.03
1	.2184	69.2	72.2	416.0	72.1	638.5	71.5	71.8	71.6	.03	.16
2	.2199	68.7	73.1	414.1	72.6	828.9	71.7	72.5	70.0	.05	.16
3	.2162	68.8	72.9	399.7	73.2	811.7	71.9	72.4	69.6	.04	.16
4	.2206	68.7	73.6	387.8	74.1	800.2	72.2	72.7	69.7	.05	.15
5	.2210	68.7	73.7	341.0	74.3	754.4	72.2	72.6	69.6	.05	.13
6	.2203	69.4	74.5	278.2	75.3	786.0	73.2	72.4	70.6	.05	.10

AEF= .04

AQF=.110367E+06(BTU/HR)

AQNH=.46980E+04(BTU/HR)

TEST NUMBER : 22-2

DATE : 4/2/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 88.50(LB/MIN)

MASS AIR OUT = 84.24(LB/MIN)

MASS DRY FLUE GAS =12.13(LB/MIN)

MASS COMB AIR = 4.62(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .600

(R.H.)OUT = .720

(R.H.)ROOM = .660

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2893	69.4	74.5	278.2	75.3	786.6	73.2	72.4	70.6	.04	.10
1	.2863	69.3	74.1	426.9	75.5	806.3	73.6	72.7	70.0	.04	.17
2	.2882	69.4	74.7	459.2	74.5	938.1	75.6	72.7	69.8	.05	.18
3	.2919	69.3	75.7	478.1	74.3	911.3	75.7	72.7	69.7	.06	.20
4	.2882	69.5	74.7	467.2	77.4	880.6	76.4	72.8	70.1	.05	.19
5	.2863	69.3	77.7	327.1	74.4	893.9	77.6	72.7	70.2	.08	.12
6	.2819	69.3	76.0	301.6	75.4	902.2	76.7	72.7	69.9	.07	.11

AEF= .05

AQF=.144510E+06(BTU/HR)

AQNH=.79055E+04(BTU/HR)

TEST NUMBER : 22-3

DATE : 4/2/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 88.50(LB/MIN)

MASS AIR OUT = 84.24(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 6.02(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .600

(R.H.)OUT = .720

(R.H.)ROOM = .660

FUEL		TEMPERATURE(F)								COMB AIR/	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3774	69.3	76.0	301.6	75.4	902.2	76.7	72.7	69.9	.05	.11
1	.3818	69.0	75.2	494.7	78.3	870.2	75.6	73.0	69.7	.04	.20
2	.3726	69.1	75.8	512.0	79.0	793.1	75.4	72.5	70.9	.04	.21
3	.3565	69.9	76.9	538.9	79.1	755.4	75.9	72.9	71.4	.05	.22
4	.3598	70.0	77.3	544.0	79.8	765.9	76.3	73.0	71.2	.05	.22
5	.3579	68.8	76.2	473.4	80.6	726.7	75.7	73.2	70.2	.05	.19
6	.3594	69.0	77.7	366.3	79.3	836.0	76.6	73.0	70.2	.06	.14

AEF= .05

AQF=.184243E+06(BTU/HR)

AQNH=.87749E+04(BTU/HR)

AEFT= .05

AQFT=.146373E+06(BTU/HR)

AQNHT=.71261E+04(BTU/HR)

TEST NUMBER : 29-1

DATE : 5/14/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =12.36(LB/MIN)

MASS COMB AIR = 3.43(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .180

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .540

(R.H.)OUT = .580

(R.H.)ROOM = .460

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2148	65.2	73.1	178.8	70.3	422.0	70.3	72.8	81.7	.10	.05
1	.2129	64.8	75.7	251.0	70.3	469.8	70.3	72.5	81.0	.14	.10
2	.2129	65.3	86.8	419.1	73.1	534.2	73.1	72.7	85.5	.28	.22
3	.2111	65.8	83.6	427.9	72.3	576.9	72.3	72.9	83.0	.23	.21
4	.2137	66.2	83.5	362.0	74.1	599.8	74.1	73.2	85.2	.22	.17
5	.2166	66.4	81.1	272.4	73.6	548.7	73.6	72.7	86.1	.19	.11
6	.2148	66.5	84.3	250.1	74.2	503.0	74.2	73.4	89.6	.23	.10

AEF= .20

AQF=.107493E+06(BTU/HR)

AQNH=.21207E+05(BTU/HR)

TEST NUMBER : 29-2

DATE : 5/14/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 4.39(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .180

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .540

(R.H.)OUT = .580

(R.H.)ROOM = .460

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2753	66.5	84.3	250.1	74.2	503.0	74.2	73.4	89.6	.18	.10
1	.2341	67.4	81.8	488.6	75.0	476.2	75.0	73.2	84.1	.14	.22
2	.2735	67.0	86.2	509.4	75.4	531.8	75.4	72.8	81.1	.20	.25
3	.2845	66.9	93.2	463.5	76.5	592.9	76.5	72.8	88.8	.26	.24
4	.2790	68.3	92.0	452.5	78.3	652.4	78.3	73.2	85.9	.24	.23
5	.2790	68.1	92.5	338.5	78.3	630.3	78.3	73.3	83.8	.25	.16
6	.2772	67.9	88.4	285.4	77.7	570.1	77.7	72.7	82.5	.21	.12

AEF= .21

AQF=.140239E+06(BTU/HR)

AQNH=.29474E+05(BTU/HR)

TEST NUMBER : 29-3

DATE : 5/14/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.57(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .180

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .540

(R.H.)OUT = .580

(R.H.)ROOM = .460

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3488	67.9	83.4	285.4	77.7	570.1	77.7	72.7	82.5	.17	.11
1	.3451	68.3	90.3	550.3	78.9	610.8	78.9	73.0	81.8	.18	.26
2	.3462	68.1	108.0	555.1	83.2	677.0	83.2	72.9	83.8	.33	.32
3	.3454	69.7	99.5	534.8	85.8	690.2	85.8	73.3	85.2	.25	.27
4	.3462	68.8	98.1	443.6	83.6	732.7	83.6	73.0	82.9	.25	.22
5	.3344	68.8	87.3	364.1	83.0	592.0	83.0	73.1	84.3	.17	.15
6	.3425	68.8	94.3	316.3	83.1	596.4	83.1	73.2	83.7	.22	.14

AEF= .22

AQF=.172985E+06(BTU/HR)

AQNH=.38467E+05(BTU/HR)

AEFT= .21

AQFT=.140239E+06(BTU/HR)

AQNHT=.29716E+05(BTU/HR)

TEST NUMBER : 31-1

DATE : 5/21/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 3.45(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .620

(R.H.)OUT = .680

(R.H.)ROOM = .450

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2162	74.9	77.3	94.4	77.1	148.1	77.3	78.7	92.0	.03	.01
1	.2166	75.5	84.2	202.0	78.0	276.9	78.7	78.6	91.2	.11	.06
2	.2129	75.5	89.1	367.6	79.0	442.9	80.3	78.4	91.8	.18	.16
3	.2170	76.4	94.6	351.1	80.2	552.8	82.3	78.7	92.9	.24	.16
4	.2162	76.4	89.9	367.9	80.7	576.8	83.0	78.3	88.1	.18	.16
5	.2162	76.3	98.3	331.7	81.2	549.8	84.7	78.3	89.1	.29	.16
6	.2137	76.4	93.2	249.4	81.3	508.3	84.3	78.5	91.0	.23	.10

AEF= .18

AQF=.108363E+06(BTU/HR)

AQNH=.19500E+05(BTU/HR)

TEST NUMBER : 31-2

DATE : 5/21/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =11.45(LB/MIN)

MASS COMB AIR = 4.48(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .620

(R.H.)OUT = .680

(R.H.)ROOM = .450

FUEL		TEMPERATURE(F)								COMB AIR/	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2808	76.4	93.2	249.4	81.3	508.4	84.3	78.5	91.0	.18	.09
1	.2863	76.9	97.3	466.0	82.5	695.4	86.1	78.6	91.0	.21	.22
2	.2860	77.6	97.4	456.7	82.9	567.9	86.5	78.9	85.7	.20	.21
3	.2720	78.1	106.0	569.9	84.3	585.3	89.2	79.2	94.5	.30	.31
4	.2867	77.4	98.6	361.3	83.9	589.0	88.6	78.9	86.2	.22	.16
5	.2838	78.9	101.5	302.9	83.8	541.4	88.6	78.9	93.9	.24	.13
6	.2863	78.4	99.7	285.6	83.5	530.7	87.5	79.0	86.3	.22	.12

AEF= .22

AQF=.142348E+06(BTU/HR)

AQNH=.31837E+05(BTU/HR)

TEST NUMBER : 31-3

DATE : 5/21/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =12.25(LB/MIN)

MASS COMB AIR = 5.64(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .620

(R.H.)OUT = .680

(R.H.)ROOM = .450

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3535	78.4	99.7	285.6	83.5	530.7	87.5	79.0	86.3	.18	.11
1	.3524	79.3	112.7	516.2	86.0	584.3	92.0	79.0	86.8	.28	.27
2	.3524	78.9	102.7	509.5	86.1	568.4	92.3	79.3	86.0	.21	.24
3	.3561	79.3	106.6	515.4	87.0	589.5	93.8	79.2	91.0	.23	.25
4	.3495	78.5	108.1	447.9	86.7	664.4	93.0	79.3	84.4	.25	.22
5	.3517	78.5	107.9	357.0	87.2	644.4	94.7	79.6	86.1	.25	.16
6	.3543	78.9	102.4	320.9	86.8	591.1	93.8	79.5	84.4	.21	.13

AEF= .23

AQF=.177388E+06(BTU/HR)

AQNH=.40899E+05(BTU/HR)

AEFT= .21

AQFT=.142700E+06(BTU/HR)

AQNHT=.30745E+05(BTU/HR)

TEST NUMBER : 33-1

DATE : 5/24/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.53(LB/MIN)

MASS COMB AIR = 3.41(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .600

(R.H.)OUT = .660

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2137	71.9	79.2	143.2	75.6	377.0	76.2	77.1	78.9	.09	.03
1	.2137	71.5	81.2	216.1	75.3	436.6	76.2	77.1	78.3	.12	.07
2	.2195	71.7	83.4	371.3	75.7	525.4	77.0	76.8	78.0	.15	.16
3	.2195	71.7	87.3	419.7	76.0	531.2	77.4	76.9	77.4	.20	.19
4	.2166	72.2	87.2	357.4	76.5	674.0	77.9	76.7	78.3	.19	.16
5	.2137	72.6	89.4	294.0	77.3	544.7	79.4	76.7	78.6	.22	.13
6	.2170	72.3	89.0	261.4	77.1	558.2	79.0	77.1	77.5	.22	.11

AEF= .17

AQF=.108706E+06(BTU/HR)

AQNH=.18566E+05(BTU/HR)

TEST NUMBER : 33-2

DATE : 5/24/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.87(LB/MIN)

MASS COMB AIR = 4.39(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .600

(R.H.)OUT = .660

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2753	72.3	89.0	261.4	77.1	558.2	79.0	77.1	77.5	.17	.10
1	.2775	72.3	92.6	415.5	77.8	623.4	80.3	76.9	79.0	.21	.19
2	.2797	73.3	93.1	472.0	78.2	568.1	80.5	77.1	78.9	.20	.22
3	.2783	73.6	89.9	446.0	78.9	631.5	81.3	77.1	77.9	.17	.20
4	.2790	73.8	96.7	453.6	79.3	608.8	81.9	77.3	77.9	.23	.22
5	.2783	74.0	91.6	345.8	79.7	572.3	82.2	77.5	78.1	.18	.15
6	.2797	73.8	91.5	288.6	80.3	546.7	83.2	77.4	78.3	.19	.12

AEF= .19

AQF=.139896E+06(BTU/HR)

AQNH=.27011E+05(BTU/HR)

TEST NUMBER : 33-3

DATE : 5/24/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =11.10(LB/MIN)

MASS COMB AIR = 5.67(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .600

(R.H.)OUT = .660

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3554	73.8	91.5	288.6	80.3	546.7	83.2	77.4	78.3	.15	.11
1	.3491	73.6	96.1	503.3	80.8	678.3	84.2	77.6	77.9	.19	.24
2	.3561	73.3	95.2	521.1	81.6	849.6	85.5	77.6	76.5	.18	.24
3	.3517	73.1	101.9	546.0	82.0	753.8	86.6	77.6	76.2	.24	.28
4	.3524	72.6	105.9	538.0	82.7	717.1	87.7	77.2	75.8	.28	.28
5	.3521	69.6	94.1	382.0	81.7	775.8	85.1	77.6	73.5	.21	.17
6	.3488	64.7	96.1	322.5	79.4	771.1	82.6	77.1	70.9	.26	.15

AEF= .21

AQF=.177072E+06(BTU/HR)

AQNH=.38010E+05(BTU/HR)

AEFT= .19

AQFT=.141891E+06(BTU/HR)

AQNHT=.27862E+05(BTU/HR)

TEST NUMBER : 30-1

DATE : 6/13/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.30(LB/MIN)

MASS COMB AIR = 3.51(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .460

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2199	75.1	78.0	143.3	78.6	585.6	78.6	76.7	94.0	.04	.03
1	.2173	75.7	78.0	367.6	78.6	628.8	78.6	76.1	91.5	.03	.14
2	.2166	75.5	77.9	490.9	78.4	686.3	78.4	75.8	94.8	.03	.20
3	.2166	76.0	78.2	492.9	78.8	787.5	78.8	76.0	95.6	.03	.20
4	.2170	75.9	78.4	476.1	78.8	816.7	78.8	76.3	95.0	.03	.19
5	.2159	76.4	78.9	383.7	79.2	900.3	79.2	76.8	92.2	.03	.14
6	.2159	76.1	78.5	331.1	79.0	842.5	79.0	77.6	96.0	.03	.12

AEF= .03

AQF=.109101E+06(BTU/HR)

AQNH=.36395E+04(BTU/HR)

TEST NUMBER : 30-2

DATE : 6/13/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 4.46(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .460

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2797	76.1	78.5	331.1	79.0	842.5	79.0	77.6	96.0	.02	.12
1	.2827	79.7	80.6	421.7	81.2	788.7	81.2	77.7	91.0	.01	.16
2	.2797	79.2	80.9	547.3	81.3	836.1	81.3	78.1	95.7	.02	.22
3	.2761	79.4	81.9	566.9	81.7	846.8	81.7	78.2	93.3	.03	.23
4	.2801	79.4	81.6	556.6	81.8	977.8	81.8	78.3	92.4	.02	.22
5	.2808	79.4	82.0	519.9	82.0	926.3	82.0	78.3	95.8	.03	.21
6	.2827	79.0	81.7	494.6	82.1	844.8	82.1	78.3	94.5	.03	.19

AEF= .02

AQF=.140898E+06(BTU/HR)

AQNH=.33232E+04(BTU/HR)

TEST NUMBER : 30-3

DATE : 6/13/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.90(LB/MIN)

MASS COMB AIR = 5.57(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .460

(R.H.)ROOM = .400

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3488	79.0	81.9	494.6	82.1	844.8	82.1	78.3	94.5	.03	.19
1	.3590	78.8	81.9	598.6	82.3	832.2	82.3	78.5	94.1	.03	.24
2	.3517	82.3	83.9	697.1	84.3	850.5	84.3	78.6	90.9	.02	.28
3	.3546	81.4	84.6	686.9	84.4	994.6	84.4	78.8	93.0	.03	.28
4	.3601	83.0	85.7	675.1	85.7	911.9	85.7	79.0	89.5	.03	.28
5	.3488	83.1	89.4	533.4	86.2	877.5	86.2	78.9	90.1	.05	.22
6	.3557	80.9	87.8	512.5	85.1	855.1	85.1	79.6	83.9	.06	.21

AEF= .03

AQF=.178021E+06(BTU/HR)

AQNH=.59208E+04(BTU/HR)

AEFT= .03

AQFT=.142673E+06(BTU/HR)

AQNHT=.42945E+04(BTU/HR)

TEST NUMBER : 32-1

DATE : 5/29/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 88.56(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 3.43(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .780

(R.H.)OUT = .900

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2148	66.5	71.2	142.8	69.2	578.9	70.5	73.7	67.7	.05	.03
1	.2159	66.2	71.8	309.8	68.9	686.9	70.2	73.1	66.9	.06	.12
2	.2137	66.3	71.2	404.8	68.8	717.2	70.2	72.9	68.1	.06	.16
3	.2137	66.2	71.9	416.6	69.1	767.5	70.2	73.6	67.2	.07	.17
4	.2155	65.8	72.5	409.8	68.8	734.2	69.9	73.3	67.3	.08	.17
5	.2133	65.7	71.7	439.3	68.7	745.9	71.4	73.8	66.3	.07	.18
6	.2173	64.8	71.2	399.8	68.2	692.8	69.2	72.9	65.9	.07	.16

AEF= .07

AQF=.108020E+06(BTU/HR)

AQNH=.71543E+04(BTU/HR)

TEST NUMBER : 32-2

DATE : 5/29/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 88.56(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 4.39(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .780

(R.H.)OUT = .900

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2753	64.8	71.2	399.8	68.5	692.8	69.2	72.9	65.9	.06	.16
1	.2819	65.2	73.4	392.5	68.3	679.9	69.7	72.9	66.4	.07	.16
2	.2783	65.5	71.7	526.9	68.5	625.2	69.6	73.0	65.3	.06	.22
3	.2794	65.4	72.3	508.7	68.5	628.7	69.7	72.9	66.9	.06	.21
4	.2808	65.5	71.8	537.4	68.9	642.0	69.8	73.3	67.1	.06	.23
5	.2772	65.9	72.2	447.7	68.8	666.2	70.1	72.7	66.2	.06	.18
6	.2845	65.8	72.5	374.1	68.8	654.6	69.9	73.1	66.4	.06	.15

AEF= .06

AQF=.140582E+06(BTU/HR)

AQNH=.83986E+04(BTU/HR)

TEST NUMBER : 32-3

DATE : 5/29/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 88.56(LB/MIN)

MASS DRY FLUE GAS =12.36(LB/MIN)

MASS COMB AIR = 5.61(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .780

(R.H.)OUT = .900

(R.H.)ROOM = .500

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3517	65.8	72.5	374.1	68.8	654.6	69.9	73.1	66.4	.05	.15
1	.3488	66.1	73.7	533.2	68.8	677.9	70.3	73.3	66.5	.06	.22
2	.3488	65.6	73.1	584.0	68.5	695.8	70.3	72.9	65.8	.06	.25
3	.3506	65.4	74.3	599.9	68.5	675.5	70.4	72.6	66.2	.07	.26
4	.3513	65.6	74.0	602.3	68.8	678.3	70.7	73.1	66.2	.06	.26
5	.3451	65.7	74.0	529.9	69.1	673.1	70.9	72.9	66.8	.06	.22
6	.3495	65.5	75.0	421.8	68.8	667.0	71.0	72.9	66.7	.07	.17

AEF= .06

AQF=.175648E+06(BTU/HR)

AQNH=.10525E+05(BTU/HR)

AEFT= .06

AQFT=.141416E+06(BTU/HR)

AQNHT=.86926E+04(BTU/HR)

TEST NUMBER : 34-1

DATE : 6/8/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 3.37(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .700

(R.H.)OUT = .900

(R.H.)ROOM = .550

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2111	75.5	78.0	128.3	75.9	548.2	77.5	76.7	76.4	.03	.02
1	.2111	75.7	78.3	447.9	76.1	560.6	77.6	76.7	76.2	.03	.18
2	.2126	75.1	79.0	259.5	76.0	578.8	77.3	76.8	75.5	.05	.09
3	.2129	75.1	79.2	457.6	76.0	597.9	77.4	76.6	75.6	.05	.18
4	.2173	74.8	78.8	448.2	76.0	615.5	77.2	76.5	75.5	.05	.18
5	.2170	74.9	79.6	466.9	75.9	613.1	77.5	76.5	75.6	.06	.19
6	.2177	76.1	79.7	348.4	76.7	609.0	78.2	76.6	76.8	.05	.13

AEF= .05

AQF=.107704E+06(BTU/HR)

AQNH=.48588E+04(BTU/HR)

TEST NUMBER : 34-2

DATE : 6/8/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 4.44(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .700

(R.H.)OUT = .900

(R.H.)ROOM = .550

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2783	76.1	79.7	348.4	76.7	609.0	78.2	76.6	76.8	.04	.13
1	.2790	76.3	81.8	318.5	76.7	601.6	78.6	76.5	77.3	.05	.12
2	.2761	76.8	81.7	528.5	76.9	594.2	79.0	76.7	78.2	.05	.22
3	.2753	76.4	82.3	525.1	77.0	598.8	79.0	76.5	79.1	.06	.22
4	.2698	77.9	82.4	525.4	77.8	607.0	80.0	76.5	83.0	.05	.21
5	.2779	78.2	82.7	432.5	78.3	600.7	80.5	76.7	79.2	.05	.17
6	.2713	77.6	83.4	377.9	87.5	647.0	80.3	76.7	81.9	.05	.14

AEF= .05

AQF=.138446E+06(BTU/HR)

AQNH=.68574E+04(BTU/HR)

TEST NUMBER : 34-3

DATE : 6/8/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =11.22(LB/MIN)

MASS COMB AIR = 5.51(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .700

(R.H.)OUT = .900

(R.H.)ROOM = .550

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3451	77.6	83.4	377.9	78.5	647.0	80.3	76.7	81.9	.05	.14
1	.3407	76.9	84.8	508.1	78.0	658.2	80.1	76.6	79.3	.06	.21
2	.3370	77.2	83.2	593.8	78.4	645.6	80.5	76.5	79.7	.05	.25
3	.3454	76.9	83.6	629.1	78.7	651.4	80.5	76.3	78.1	.06	.27
4	.3443	77.4	83.9	610.2	78.8	660.2	81.0	76.6	78.1	.05	.26
5	.3443	76.9	84.6	511.3	78.8	662.8	81.1	76.8	78.1	.06	.21
6	.3484	76.9	84.9	431.7	79.0	699.3	81.2	76.6	77.7	.07	.17

AEF= .06

AQF=.172748E+06(BTU/HR)

AQNH=.99173E+04(BTU/HR)

AEFT= .05

AQFT=.139632E+06(BTU/HR)

AQNHT=.72112E+04(BTU/HR)

TEST NUMBER : 29A-1

DATE : 5/9/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : PINE

HEATING VALUE =8342.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.53(LB/MIN)

MASS COMB AIR = 3.67(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .720

(R.H.)OUT = .820

(R.H.)ROOM = .620

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2298	70.9	76.8	148.6	74.9	730.9	74.9	74.8	72.3	.07	.04
1	.2298	71.7	86.2	368.4	77.4	865.2	77.4	75.0	72.1	.17	.16
2	.2298	71.4	89.1	321.7	77.5	904.1	77.5	74.8	73.2	.21	.14
3	.2298	72.9	90.9	294.3	78.6	830.2	78.6	75.3	75.7	.22	.13
4	.2298	73.0	81.5	261.2	78.6	765.4	78.6	75.2	73.8	.11	.09
5	.2298	73.1	84.5	234.0	79.2	753.4	79.2	75.2	75.2	.14	.08
6	.2294	75.5	87.1	195.0	80.5	730.3	80.5	74.7	76.3	.15	.06

AEF= .15

AQF=.114998E+06(BTU/HR)

AQNH=.17493E+05(BTU/HR)

TEST NUMBER : 29A-2

DATE : 5/9/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : PINE

HEATING VALUE =8342.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.53(LB/MIN)

MASS COMB AIR = 3.38(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .720

(R.H.)OUT = .820

(R.H.)ROOM = .620

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR, EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2118	75.5	87.1	195.0	80.5	730.3	80.5	74.7	76.3	.16	.06
1	.2118	75.2	87.4	397.8	80.9	819.8	80.9	75.1	74.1	.17	.17
2	.2118	75.1	87.7	352.0	81.1	784.6	81.1	75.4	75.5	.17	.15
3	.2118	76.4	92.2	335.2	82.3	756.5	82.3	75.6	76.0	.21	.15
4	.2118	74.9	83.7	283.9	80.2	701.1	80.2	75.8	75.5	.12	.11
5	.2118	74.1	88.6	232.4	82.1	828.7	82.1	75.3	73.3	.20	.09
6	.2118	73.2	87.6	215.2	81.1	864.1	81.1	75.3	75.5	.20	.08

AEF= .17

AQF=.106021E+06(BTU/HR)

AQNH=.18493E+05(BTU/HR)

TEST NUMBER : 29A-3

DATE : 5/9/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : PINE

HEATING VALUE =8342.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 3.39(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .720

(R.H.)OUT = .820

(R.H.)ROOM = .620

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2126	73.2	87.6	215.2	79.4	864.1	79.4	75.3	75.5	.19	.08
1	.2126	75.5	88.9	412.0	82.4	906.9	82.4	75.3	75.5	.18	.19
2	.2126	77.0	90.6	378.5	83.7	925.7	83.7	75.5	77.5	.19	.17
3	.2126	76.3	89.0	342.8	84.3	876.6	84.3	75.8	75.7	.18	.14
4	.2126	75.0	89.0	289.8	82.6	847.4	82.6	75.6	76.0	.19	.12
5	.2126	75.7	89.9	230.0	83.3	769.5	83.3	75.8	75.3	.19	.08
6	.2126	75.3	86.1	205.4	82.8	695.6	82.8	75.8	75.3	.15	.07

AEF= .18

AQF=.106388E+06(BTU/HR)

AQNH=.19418E+05(BTU/HR)

AEFT= .17

AQFT=.109135E+06(BTU/HR)

AQNHT=.18468E+05(BTU/HR)

TEST NUMBER : 29B-1

DATE : 5/11/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : OAK

HEATING VALUE =8260.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.53(LB/MIN)

MASS COMB AIR = 4.33(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .180

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .630

(R.H.)OUT = .730

(R.H.)ROOM = .480

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2713	77.0	83.7	156.6	81.4	382.4	81.4	77.5	80.4	.07	.04
1	.2713	77.5	90.1	395.1	82.3	545.5	82.3	77.5	82.1	.13	.17
2	.2713	77.9	90.8	387.8	82.5	612.1	82.5	77.3	83.6	.14	.16
3	.2713	77.8	92.6	349.9	83.4	610.9	83.4	77.2	81.2	.16	.15
4	.2713	77.8	93.0	315.1	83.5	625.1	83.5	77.2	80.5	.16	.13
5	.2713	76.8	90.6	304.9	82.8	510.9	82.8	77.2	78.4	.15	.12
6	.2713	76.2	90.4	243.1	82.1	462.7	82.1	77.1	78.6	.15	.09

AEF= .14

AQF=.134452E+06(BTU/HR)

AQNH=.18342E+05(BTU/HR)

TEST NUMBER : 29B-2

DATE : 5/11/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : OAK

HEATING VALUE =8260.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.87(LB/MIN)

MASS COMB AIR = 4.65(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .180

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .630

(R.H.)OUT = .730

(R.H.)ROOM = .480

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2911	76.2	90.4	253.1	82.1	462.7	82.1	77.1	78.6	.14	.09
1	.2911	85.1	92.6	517.4	88.1	511.3	88.1	77.0	77.0	.08	.22
2	.2911	74.4	87.6	407.6	81.8	500.3	81.8	77.0	77.7	.13	.17
3	.2911	74.4	95.6	381.5	82.3	484.9	82.3	76.8	78.8	.21	.17
4	.2911	73.9	89.7	338.4	81.6	455.3	81.6	76.7	77.4	.16	.14
5	.2911	74.2	90.2	319.4	81.9	415.8	81.9	76.9	77.2	.16	.13
6	.2911	74.7	90.2	326.4	83.2	536.8	83.2	77.9	79.0	.15	.13

AEF= .15

AQF=.144277E+06(BTU/HR)

AQNH=.21172E+05(BTU/HR)

TEST NUMBER : 29B-3

DATE : 5/11/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : SIDES CLOSED

FUEL MATERIAL : WOOD

FUEL TYPE : OAK

HEATING VALUE =8260.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =11.22(LB/MIN)

MASS COMB AIR = 5.27(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .180

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .630

(R.H.)OUT = .730

(R.H.)ROOM = .480

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3304	74.7	90.2	326.4	83.2	536.8	83.2	77.9	79.0	.14	.13
1	.3304	75.5	101.7	537.2	86.4	747.8	86.4	78.1	79.2	.23	.27
2	.3304	76.1	106.0	493.0	87.9	726.6	87.9	78.7	80.8	.26	.25
3	.3304	79.8	100.0	413.8	89.6	698.9	89.6	78.9	81.0	.18	.18
4	.3304	79.2	98.6	367.9	89.3	668.7	89.3	79.5	84.8	.17	.16
5	.3304	81.4	97.5	331.6	90.4	571.2	90.4	79.4	82.0	.15	.13
6	.3304	80.1	93.7	309.2	89.9	536.8	89.9	79.6	84.1	.13	.12

AEF= .18

AQF=.163744E+06(BTU/HR)

AQNH=.29299E+05(BTU/HR)

AEFT= .15

AQFT=.147491E+06(BTU/HR)

AQNHT=.22938E+05(BTU/HR)

TEST NUMBER : 23A-1

DATE : 5/4/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 3.54(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .580

(R.H.)OUT = .620

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2221	77.3	79.3	87.3	78.7	121.3	78.7	75.6	82.2	.03	.00
1	.2203	77.9	83.0	207.1	79.4	464.5	79.4	75.9	83.3	.06	.06
2	.2203	79.4	89.8	395.8	81.7	640.1	81.7	76.5	85.4	.13	.17
3	.2177	80.8	93.3	406.7	84.0	659.0	84.0	76.6	85.3	.17	.18
4	.2232	78.1	94.5	378.1	83.7	687.6	83.7	76.7	83.2	.21	.17
5	.2177	78.1	96.8	297.2	85.5	653.3	85.5	76.0	81.5	.25	.13
6	.2173	77.3	91.8	248.8	84.9	586.8	84.9	76.2	80.6	.20	.09

AEF= .15

AQF=.110498E+06(BTU/HR)

AQNH=.16531E+05(BTU/HR)

TEST NUMBER : 23A-3

DATE : 5/4/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =103.50(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =12.51(LB/MIN)

MASS COMB AIR = 5.67(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .580

(R.H.)OUT = .620

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3554	80.6	106.5	274.7	94.8	738.2	94.8	77.1	83.2	.22	.11
1	.3543	80.2	101.3	519.9	95.9	696.5	95.9	77.0	82.8	.19	.24
2	.3561	81.1	108.5	534.7	100.1	989.9	100.1	77.5	82.2	.24	.26
3	.3524	79.4	108.5	528.5	100.9	969.5	100.9	77.6	81.7	.26	.26
4	.3488	79.0	111.1	457.6	98.0	918.2	98.0	77.5	81.2	.28	.23
5	.3521	78.8	106.6	382.6	101.2	841.5	101.2	77.6	81.2	.25	.17
6	.3561	79.4	105.1	324.4	99.7	820.5	99.7	77.8	82.6	.23	.13

AEF= .24

AQF=.177757E+06(BTU/HR)

AQNH=.42246E+05(BTU/HR)

AEFT= .21

AQFT=.143789E+06(BTU/HR)

AQNHT=.31124E+05(BTU/HR)

TEST NUMBER : 25A-1

DATE : 6/25/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 99.00(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.99(LB/MIN)

MASS COMB AIR = 3.46(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .520

(R.H.)OUT = .820

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2166	67.6	76.7	109.6	80.8	651.4	74.5	78.9	79.9	.10	.02
1	.2170	67.9	86.7	313.5	74.8	607.8	77.6	78.9	69.5	.23	.14
2	.2137	67.3	87.8	345.4	74.1	569.2	76.1	78.9	69.3	.25	.16
3	.2129	67.7	84.4	357.4	74.5	667.1	76.7	78.9	69.4	.20	.16
4	.2129	67.8	87.8	175.1	74.3	633.9	76.4	78.7	70.0	.24	.06
5	.2166	67.5	89.5	375.6	74.8	766.3	77.4	78.9	69.6	.26	.19
6	.2184	67.8	89.3	238.1	75.0	775.9	77.8	78.9	69.1	.26	.10

AEF= .22

AQF=.108310E+06(BTU/HR)

AQNH=.23863E+05(BTU/HR)

TEST NUMBER : 25A-2

DATE : 6/25/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 99.00(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =12.36(LB/MIN)

MASS COMB AIR = 4.45(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .520

(R.H.)OUT = .820

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2790	67.8	89.3	238.1	75.0	775.9	77.8	78.9	69.4	.20	.09
1	.2772	67.1	93.7	355.2	75.5	807.4	79.1	79.0	69.1	.25	.17
2	.2827	67.1	89.8	429.2	76.1	754.2	79.9	79.0	68.6	.22	.20
3	.2753	67.1	102.5	430.9	76.8	718.5	81.6	78.9	70.2	.34	.24
4	.2753	67.7	94.1	410.4	76.3	780.9	80.8	79.1	68.9	.26	.20
5	.2764	67.1	93.0	352.1	76.7	729.2	81.2	79.0	69.0	.25	.17
6	.2808	66.7	90.2	289.7	76.6	696.1	81.2	78.9	68.8	.23	.12

AEF= .25

AQF=.139817E+06(BTU/HR)

AQNH=.35056E+05(BTU/HR)

TEST NUMBER : 25A-3

DATE : 6/25/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 99.00(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =13.05(LB/MIN)

MASS COMB AIR = 5.51(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .520

(R.H.)OUT = .820

(R.H.)ROOM = .440

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3451	66.7	90.2	289.7	76.6	696.1	81.2	78.9	68.8	.19	.12
1	.3480	66.1	91.4	382.0	76.5	680.6	81.2	78.9	67.8	.20	.17
2	.3480	66.1	102.7	507.6	78.2	674.5	84.3	78.9	68.3	.29	.27
3	.3499	66.8	96.2	507.9	78.4	759.9	84.0	79.3	68.8	.23	.25
4	.3488	67.2	99.8	505.3	78.4	757.6	84.2	79.2	67.4	.26	.26
5	.3484	66.9	96.4	440.8	79.3	750.7	86.4	79.3	68.2	.24	.21
6	.3491	65.7	113.9	335.7	79.5	756.8	87.5	78.9	67.4	.38	.18

AEF= .25

AQF=.175041E+06(BTU/HR)

AQNH=.44493E+05(BTU/HR)

AEFT= .24

AQFT=.141056E+06(BTU/HR)

AQNHT=.34471E+05(BTU/HR)

TEST NUMBER : 27-1

DATE : 4/27/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =11.45(LB/MIN)

MASS COMB AIR = 3.45(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .700

(R.H.)OUT = .750

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2159	58.8	65.9	95.7	66.5	355.2	65.2	70.5	70.0	.08	.02
1	.2203	58.2	66.9	356.8	65.1	449.7	64.9	70.7	68.0	.10	.15
2	.2140	59.2	70.6	354.5	66.2	453.1	66.5	70.7	70.5	.14	.15
3	.2170	59.5	73.1	356.5	66.8	397.1	67.4	70.8	69.3	.17	.16
4	.2203	59.2	74.0	362.7	67.3	380.8	67.8	70.7	70.2	.18	.16
5	.2115	59.1	74.6	274.5	67.7	372.4	68.4	70.5	76.8	.20	.12
6	.2173	59.6	75.1	237.5	68.3	366.7	69.0	70.3	72.1	.19	.10

AEF= .15

AQF=.108890E+06(BTU/HR)

AQNH=.16464E+05(BTU/HR)

TEST NUMBER : 27-2

DATE : 4/27/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =12.82(LB/MIN)

MASS COMB AIR = 4.48(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .700

(R.H.)OUT = .750

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2808	59.6	75.1	237.5	68.3	366.7	69.0	70.3	72.1	.15	.09
1	.2790	59.0	75.4	400.4	68.5	391.3	69.5	70.3	71.0	.16	.18
2	.2845	60.5	77.7	410.4	69.5	407.7	71.3	70.5	77.6	.17	.19
3	.2863	60.2	82.5	423.2	70.3	447.2	72.3	70.0	73.5	.22	.21
4	.2790	59.9	82.8	424.4	71.0	510.2	73.7	70.0	69.9	.23	.21
5	.2827	59.9	81.9	345.0	71.0	595.3	73.2	70.1	74.8	.22	.16
6	.2856	61.2	82.5	266.0	71.7	536.1	74.3	70.0	72.5	.21	.11

AEF= .20

AQF=.142058E+06(BTU/HR)

AQNH=.27829E+05(BTU/HR)

TEST NUMBER : 27-3

DATE : 4/27/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : OPEN

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =101.25(LB/MIN)

MASS AIR OUT = 93.60(LB/MIN)

MASS DRY FLUE GAS =13.28(LB/MIN)

MASS COMB AIR = 5.67(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .700

(R.H.)OUT = .750

(R.H.)ROOM = .380

FUEL		TEMPERATURE(F)								COMB AIR	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3554	61.2	82.5	266.0	71.7	536.1	74.3	70.0	72.5	.17	.11
1	.3587	61.0	84.9	312.1	72.6	626.4	76.2	70.0	71.1	.19	.13
2	.3601	61.0	83.4	453.4	73.0	668.7	75.9	70.3	68.7	.18	.21
3	.3565	61.2	83.0	502.7	74.1	714.6	78.5	70.3	67.5	.18	.24
4	.3506	61.1	83.1	492.6	75.4	710.0	80.5	70.4	67.9	.19	.23
5	.3543	61.3	89.0	381.6	76.0	765.9	80.9	70.2	66.1	.23	.18
6	.3532	62.0	82.6	301.6	76.4	781.2	82.0	70.3	68.2	.18	.12

AEF= .19

AQF=.178733E+06(BTU/HR)

AQNH=.34192E+05(BTU/HR)

AEFT= .18

AQFT=.143227E+06(BTU/HR)

AQNHT=.26162E+05(BTU/HR)

TEST NUMBER : 24-1

DATE : 6/15/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 90.00(LB/MIN)

MASS DRY FLUE GAS =10.30(LB/MIN)

MASS COMB AIR = 3.44(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .560

(R.H.)OUT = .580

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2155	72.0	77.6	117.7	77.4	347.2	77.4	77.5	85.6	.07	.02
1	.2184	75.5	81.7	202.4	79.1	456.0	79.1	77.4	80.8	.07	.06
2	.2170	75.5	83.0	392.5	79.4	556.6	79.4	77.5	83.4	.09	.16
3	.2173	72.1	82.1	433.8	77.8	729.6	77.8	77.4	83.0	.12	.18
4	.2133	72.1	84.6	456.1	78.4	767.3	78.4	77.1	77.2	.15	.20
5	.2173	71.2	84.6	415.1	78.1	802.5	78.1	77.2	79.0	.16	.18
6	.2184	71.8	84.2	432.8	78.2	833.5	78.2	77.1	80.2	.15	.19

AEF= .12

AQF=.108969E+06(BTU/HR)

AQNH=.12774E+05(BTU/HR)

TEST NUMBER : 24-2

DATE : 6/15/79

=====

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

=====

COMBUSTION AIR : ROOM

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 90.00(LB/MIN)

MASS DRY FLUE GAS =10.53(LB/MIN)

MASS COMB AIR = 4.51(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .560

(R.H.)OUT = .580

(R.H.)ROOM = .420

=====

FUEL		TEMPERATURE(F)								COMB AIR	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2827	71.8	84.2	432.8	78.2	833.6	78.2	76.6	80.2	.12	.18
1	.2863	74.0	85.7	496.6	79.8	958.5	79.8	77.0	82.2	.11	.21
2	.2860	74.3	89.3	535.8	80.5	974.6	80.5	77.1	79.8	.14	.24
3	.2863	75.7	89.2	521.4	81.3	1005.8	81.3	77.3	79.1	.13	.23
4	.2871	72.3	89.1	542.3	80.1	898.9	80.1	77.5	79.5	.16	.25
5	.2856	73.0	91.2	534.6	81.0	826.8	81.0	77.2	78.7	.17	.25
6	.2823	71.9	89.0	465.0	80.6	830.9	80.6	77.5	76.4	.16	.21

=====

AEF= .14

AQF=.143376E+06(BTU/HR)

AQNH=.20147E+05(BTU/HR)

=====

TEST NUMBER : 26-1

DATE : 6/20/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 89.28(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 3.49(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .480

(R.H.)OUT = .760

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT										
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2184	77.4	81.9	128.1	78.9	658.8	80.9	80.2	79.2	.05	.02
1	.2159	77.1	84.2	334.2	79.2	678.6	81.1	80.1	79.9	.09	.13
2	.2173	77.9	86.6	388.9	79.6	698.3	81.5	80.3	79.4	.10	.16
3	.2184	77.8	86.9	436.6	79.5	710.2	81.8	80.1	78.2	.11	.18
4	.2170	76.9	90.0	412.1	79.3	731.5	81.7	80.2	78.3	.16	.18
5	.2159	76.4	87.6	374.7	79.4	740.7	81.5	80.4	78.2	.14	.16
6	.2173	77.8	88.4	320.0	79.3	710.0	82.7	79.7	77.5	.13	.13

AEF= .11

AQF=.109180E+06(BTU/HR)

AQNH=.12259E+05(BTU/HR)

TEST NUMBER : 26-2

DATE : 6/20/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 89.28(LB/MIN)

MASS DRY FLUE GAS =11.22(LB/MIN)

MASS COMB AIR = 4.47(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .480

(R.H.)OUT = .760

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2801	77.8	88.4	320.0	79.3	710.1	82.7	79.7	77.5	.10	.12
1	.2790	76.9	94.5	506.3	79.6	690.5	82.3	80.1	81.9	.17	.23
2	.2764	77.3	91.1	488.4	79.7	688.1	83.0	80.1	79.3	.13	.21
3	.2783	77.5	94.8	535.9	79.5	675.1	83.3	80.0	78.3	.17	.25
4	.2794	76.3	91.4	513.0	79.6	699.4	83.1	79.8	79.6	.15	.23
5	.2794	76.3	92.5	525.9	79.2	723.7	83.5	80.0	79.3	.16	.24
6	.2790	75.7	95.6	341.4	79.1	781.4	83.2	80.6	78.8	.19	.15

AEF= .15

AQF=.140160E+06(BTU/HR)

AQNH=.21415E+05(BTU/HR)

TEST NUMBER : 26-3

DATE : 6/20/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : REAR

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN = 97.50(LB/MIN)

MASS AIR OUT = 89.28(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 5.64(LB/MIN)

%CO2 = .030

%CO = .010

%O2 = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .480

(R.H.)OUT = .760

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3532	75.7	95.6	341.4	79.1	781.4	83.2	80.6	78.8	.15	.14
1	.3488	75.3	93.6	535.8	78.9	760.2	83.5	80.6	77.6	.14	.24
2	.3473	76.3	93.2	310.0	78.9	736.4	84.5	80.3	79.7	.14	.12
3	.3451	76.3	93.7	604.9	79.4	734.1	84.6	79.9	78.6	.14	.28
4	.3484	75.3	95.3	627.4	79.5	757.7	85.0	80.9	77.9	.16	.29
5	.3557	76.1	97.1	477.9	79.1	759.6	83.9	80.5	78.8	.16	.21
6	.3543	75.3	99.0	400.5	79.2	742.6	85.0	81.1	78.1	.18	.18

AEF= .15

AQF=.176149E+06(BTU/HR)

AQNH=.26976E+05(BTU/HR)

AEFT= .14

AQFT=.141830E+06(BTU/HR)

AQNHT=.20216E+05(BTU/HR)

TEST NUMBER : 28-1

DATE : 6/21/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =102.00(LB/MIN)

MASS AIR OUT = 90.00(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 3.52(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .640

(R.H.)OUT = .680

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	75.4	82.7	148.1	79.4	697.0	80.8	80.3	79.6	.09	.03
1	.2170	75.1	85.0	319.6	78.7	727.5	80.4	80.1	79.3	.12	.12
2	.2177	76.0	87.6	424.0	78.3	697.4	81.1	80.5	81.3	.14	.18
3	.2203	75.9	89.1	430.3	78.6	698.5	81.2	80.7	82.2	.16	.19
4	.2195	75.9	90.1	452.8	78.7	729.5	81.4	80.7	83.3	.17	.21
5	.2210	77.3	91.8	397.6	78.8	718.5	82.5	80.7	83.4	.18	.17
6	.2203	77.9	92.2	307.6	79.1	753.7	83.0	80.9	84.6	.18	.12

AEF= .15

AQF=.110314E+06(BTU/HR)

AQNH=.16375E+05(BTU/HR)

TEST NUMBER : 28-2

DATE : 6/21/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =102.00(LB/MIN)

MASS AIR OUT = 90.00(LB/MIN)

MASS DRY FLUE GAS =11.22(LB/MIN)

MASS COMB AIR = 4.46(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .640

(R.H.)OUT = .680

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR	
TIME WEIGHT										EFF	TOT LOSS
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2797	77.9	92.2	307.6	79.1	753.7	83.0	80.9	84.6	.14	.12
1	.2827	76.4	89.8	259.7	79.3	764.1	82.6	80.5	82.1	.13	.09
2	.2830	77.6	93.3	514.7	79.3	770.5	83.6	81.0	83.2	.15	.23
3	.2827	77.2	96.4	518.9	79.7	757.5	83.7	80.8	85.3	.18	.24
4	.2819	79.0	96.7	498.1	79.8	752.3	85.0	81.3	81.9	.17	.23
5	.2845	78.3	95.6	425.5	79.8	791.1	84.8	81.0	83.1	.17	.19
6	.2819	77.4	101.6	348.9	80.1	790.8	85.5	81.3	85.3	.23	.16

AEF= .17

AQF=.141953E+06(BTU/HR)

AQNH=.23891E+05(BTU/HR)

TEST NUMBER : 29-3

DATE : 6/21/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : FRONT

GLASS DOOR : CLOSED

CIRCULATION FANS : TWO

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =8379.0(BTU/LB)

MASS AIR IN =102.00(LB/MIN)

MASS AIR OUT = 90.00(LB/MIN)

MASS DRY FLUE GAS =11.67(LB/MIN)

MASS COMB AIR = 5.64(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .640

(R.H.)OUT = .680

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
TIME	WEIGHT									%	%
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV		
0	.3532	77.4	101.6	348.9	80.1	790.8	85.5	81.3	85.3	.19	.15
1	.3480	78.6	96.5	475.1	80.3	785.5	85.7	81.2	84.2	.14	.21
2	.3506	77.9	101.7	587.3	80.7	738.1	85.7	81.5	84.8	.19	.28
3	.3506	78.0	95.3	579.6	80.6	773.2	86.2	81.5	84.4	.14	.26
4	.3484	78.8	98.5	583.7	81.2	805.7	87.1	81.4	84.5	.16	.27
5	.3451	78.2	106.3	491.4	80.9	825.1	87.6	81.8	84.9	.22	.24
6	.3480	78.3	99.3	382.4	81.2	791.1	87.4	81.9	84.4	.17	.16

AEF= .17

AQF=.175516E+06(BTU/HR)

AQNH=.30351E+05(BTU/HR)

AEFT= .16

AQFT=.142594E+06(BTU/HR)

AQNHT=.23539E+05(BTU/HR)

LOW HEATING VALUE TEST

TEST NUMBER : 4A-1

DATE : 6/27/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =7719.6(BTU/LB)

MASS AIR IN = 96.75(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =10.76(LB/MIN)

MASS COMB AIR = 3.62(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .590

(R.H.)ROOM = .420

FUEL TIME WEIGHT		TEMPERATURE(F)								COMB AIR/ EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.2203	74.4	78.5	100.0	77.9	273.0	77.9	75.4	86.8	.06	.01
1	.2214	74.2	80.2	231.9	78.0	319.6	78.0	75.2	88.7	.08	.08
2	.2221	75.0	84.2	404.9	79.5	346.5	79.5	75.1	89.6	.12	.18
3	.2203	75.5	88.2	375.4	80.5	367.3	80.5	75.7	88.2	.17	.18
4	.2250	74.6	86.6	198.7	80.3	361.9	80.3	75.5	86.8	.16	.07
5	.2221	76.4	84.0	406.3	79.7	411.2	79.7	74.7	81.5	.10	.18
6	.2203	75.0	88.7	403.3	79.7	446.3	79.7	74.9	80.8	.18	.20

AEF= .12

ARF=.102653E+06(BTU/HR)

AQNH=.12782E+05(BTU/HR)

TEST NUMBER : 4A-2

DATE : 6/27/79

FIREPLACE SIMULATION STUDIES
CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =7719.6(BTU/LB)

MASS AIR IN = 96.75(LB/MIN)

MASS AIR OUT = 87.84(LB/MIN)

MASS DRY FLUE GAS =11.87(LB/MIN)

MASS COMB AIR = 4.92(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%C = .560

%H = .070

%MC =0.000

(R.H.)LAB = .500

(R.H.)OUT = .590

(R.H.)ROOM = .420

FUEL		TEMPERATURE(F)								COMB AIR/ EFF TO LOSS	
TIME	WEIGHT	IN	OUT	STACK	COMB	FIRE	CALR	LAP	ENV	%	%
0	.2830	75.0	88.7	403.3	79.7	446.3	79.7	74.9	80.8	.14	.19
1	.2823	74.8	93.6	413.6	80.6	473.6	80.6	75.1	83.0	.19	.20
2	.2852	74.2	105.1	439.0	83.7	511.9	83.7	75.4	80.3	.31	.26
3	.2827	75.5	97.5	434.5	83.8	515.2	83.8	75.2	82.1	.23	.23
4	.2838	76.3	100.5	422.4	85.5	562.9	85.5	76.3	81.5	.25	.22
5	.2834	77.4	96.9	331.3	86.1	564.1	86.1	75.8	81.9	.21	.15
6	.2808	76.4	97.8	285.0	86.2	552.9	86.2	75.9	82.3	.23	.13

AEF= .22

AQF= .131097E+06(BTU/HR)

AQRH= .29325E+05(BTU/HR)

TEST NUMBER : 4A-3

DATE : 6/27/79

FIREPLACE SIMULATION STUDIES

CHARACTERISTICS AND EFFICIENCY ANALYSIS

COMBUSTION AIR : ROOM

GLASS DOOR : OPEN

CIRCULATION FANS : NONE

FUEL MATERIAL : WOOD

FUEL TYPE : DOUGLAS FIR

HEATING VALUE =7719.6(BTU/LB)

MASS AIR IN = 96.75(LB/MIN)

MASS AIR OUT = 87.94(LB/MIN)

MASS DRY FLUE GAS =12.13(LB/MIN)

MASS COMB ACP = 5.62(LB/MIN)

%CO₂ = .030

%CO = .010

%O₂ = .100

%H₂ = .560

%H = .070

%HC = 0.000

(R.H.)LAB = .500

(R.H.)OUT = .590

(R.H.)ROOM = .420

FUEL		TEMPERATURE (F)								COMB AIR/	
TIME WEIGH										EFF TOT LOSS	
MIN	LB/MIN	IN	OUT	STACK	COMB	FIRE	CALR	LAB	ENV	%	%
0	.3524	76.4	97.8	285.0	86.2	552.9	86.2	75.9	82.4	.18	.12
1	.3488	74.1	97.7	322.7	85.5	539.3	85.5	75.9	82.5	.20	.15
2	.3513	80.3	106.3	543.0	92.0	599.4	92.0	76.6	80.5	.23	.29
3	.3554	80.3	104.7	548.7	91.7	642.3	91.7	76.2	78.4	.21	.29
4	.3524	77.1	109.3	550.0	93.1	627.5	93.1	77.2	81.2	.20	.31
5	.3469	77.8	108.7	373.8	91.9	628.1	91.9	77.5	81.3	.27	.19
6	.3568	78.0	106.9	342.6	92.2	619.4	92.2	77.0	80.8	.25	.16

AEF= .23

AOE = .163040E+06 (BTU/HR)

AOHH = .37572E+05 (BTU/HR)

AEFT = .19

AOE1 = .132263E+06 (BTU/HR)

AOHHT = .26560E+05 (BTU/HR)

APPENDIX C
HEATING VALUE TEST RESULTS



ENGINEERING EXPERIMENT STATION
GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

March 23, 1979

MEMORANDUM

TO: Mr. Bill Bullpitt
FROM: L. W. Elston ([REDACTED])
SUBJECT: Project A-2180, Results of Analysis

The required cylinder of oxygen was delivered yesterday afternoon, so your samples were analyzed today. The results of analysis are as follows:

Sample	Percent Moisture	Btu/lb (Dry Bases)
Wood	5.66	1. 7,598 2. 7,576 Av. 7,587
Ash	10.83	1. 12,950 2. 12,875 Av. 12,912

The "Ash" sample appeared to contain mainly charcoal with only a few visible light colored flecks.

LWE:gp

cc: J. A. Knight



ENGINEERING EXPERIMENT STATION
GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

April 6, 1979

MEMORANDUM

TO: Mr. Bill Bullpitt
FROM: L. W. Elston [REDACTED]
SUBJECT: Project A-2180, Analysis of Second Wood Sample

The several small blocks furnished were split, coarsely ground (6 mm screen), and finely ground (2 mm screen) in a Model 4 Wiley Mill. All of the material furnished was included in the finely ground sample used for analysis. The finely ground sample was thoroughly mixed.

The results of analysis are as follows:

<u>Sample</u>	<u>Percent Moisture</u>	<u>BTU/lb. (dry basis)</u>
Wood Blocks	1. 9.58	1. 8,337
	2. 9.66	2. 8,364
	Av. 9.62	3. 8,435
		Av. 8,379

The differences between the results reported for the two wood samples indicate that laboratory results are dependent on the composition of the sample furnished.

LWE:gp

cc: J. A. Knight

Chaffari



ENGINEERING EXPERIMENT STATION
GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

May 29, 1979

MEMORANDUM

TO: Mr. Bill Bulpitt [REDACTED]
FROM: L. W. Elston [REDACTED]
SUBJECT: Project A-2180 Wood Analysis

The requested analyses on the two wood samples have been completed. Results are as follows:

	Oak	Pine
Percent Moisture	8.9	9.1
BTU/lb (dry bases)	(1) 8,299	8,315
	(2) 8,220	8,368
	Av. 8,260	8,342

LWE:gp