

GEORGIA INSTITUTE OF TECHNOLOGY
OFFICE OF CONTRACT ADMINISTRATION
SPONSORED PROJECT INITIATION

Date: 8/28/80

Project Title: Supplemental Grounding of Extended EMP Collectors

Project No: A-2649

Project Director: Hugh Denny

Sponsor: Defense Nuclear Agency

Agreement Period: From 5-01-80 Until 1-31-82

Type Agreement: Contract No. DNA001-80-C-0294

Amount: \$199,524
Incremental funding of \$75,000 through 10/31/80

Reports Required: Progress, Final, DNA Computer Program Summary

Sponsor Contact Person (s):

Technical Matters

~~Captain Michael King~~
Vulnerability Directorate/VLIS
Defense Nuclear Agency
Washington, D.C. 20305

Contractual Matters

(thru OCA)

John W. Watson
Acquisition Management Directorate
Defense Nuclear Agency
Washington, D.C. 20305

Defense Priority Rating: DO-C9 under DMS Reg 1

Assigned to: ETL/EC

(S&K)/Laboratory

COPIES TO:

Project Director
Division Chief (EES)
School/Laboratory Director
Dean/Director-EES
Accounting Office
Procurement Office
Security Coordinator (OCA)
Reports Coordinator (OCA)

Library, Technical Reports Section
Office of Computing Services
Director, Physical Plant **EES R+P**
EES Information Office
Project File (OCA)
Project Code (GTRI)
Other F.L. Cain



SPONSORED PROJECT TERMINATION SHEETDate 3/1/83Project Title: Supplemental Grounding of Extended EMP CollectorsProject No: A-2649Project Director: Hugh DennySponsor: Defense Nuclear AgencyEffective Termination Date: 1/31/82Clearance of Accounting Charges: 1/31/82 (approximate)*

Grant/Contract Closeout Actions Remaining:

- ☒ Final Invoice and Closing Documents
- ☐ Final Fiscal Report
- ☒ Final Report of Inventions
- ☐ Govt. Property Inventory & Related Certificate (subm. 10/21/82)
- ☐ Classified Material Certificate (subm. 10/21/82)
- ☐ Other _____

*Draft Final Report submitted December '81, returned to GIT November '82,
may have report related costs after 1/31/82.

Assigned to: ECSL/ECD (School/Laboratory)COPIES TO:

Administrative Coordinator
Research Property Management
Accounting
Procurement/EES Supply Services

Research Security Services
Reports Coordinator (OCA)
Legal Services (OCA)
Library

EES Public Relations (2)
Computer Input
Project File
Other Project Director



ENGINEERING EXPERIMENT STATION

GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

August 26, 1980

Headquarters,
Defense Nuclear Agency
Washington, D. C. 20305

Attention: Maj. Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 1, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period of 1 May 1980 to 15 August 1980.

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum location for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

The program was initiated on May 1, 1980. On May 21, E. E. Donaldson and H. W. Denny visited Maj. Michael King and Mr. Paul Fleming of DNA. At this meeting, the overall objectives of the program were reviewed and other previous and on-going efforts serving to place the program in perspective were discussed.

Activities to date have emphasized a search and cataloging of existing literature sources for applicable coupling models, pickup characteristics of selected collectors, and scale modeling techniques. Several applicable sources have been identified and reviewed. These are providing the basis for selection of particular models and techniques to use in evaluating the effectiveness of grounding techniques in reducing EMP pickup levels within a facility.

Respectfully submitted,

H. W. Denny
Projector Director, A2649

Approved:

D. W. Robertson, Director
Electronics Technology Laboratory

HWD/nb



ENGINEERING EXPERIMENT STATION

GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

September 29, 1980

Headquarters,
Defense Nuclear Agency
Washington, D. C. 20305

Attention: Maj. Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 2, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period of 16 August 1980 to 15 September 1980.

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum location for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

An intensive literature review is underway to identify EMP modeling approaches and tools applicable to typical communications support facilities. Coupled with this review is a critical examination of the various classes of collectors in such facilities. This examination is aimed at defining elements of the problem so as to allow meaningful assessments to be made without involving overly complex computer models. Initial indications are that appropriate delineations between external and internal collectors can be made which will allow engineering approximations to be made of the relative pickup efficiency. In particular, the exter-

Maj. Blair Williams
September 29, 1980
Page 2

nal collectors can be evaluated in terms of supplemental grounding, effects of multiple electrodes, electrode configuration, and soil properties. More detailed examination of these assessment techniques is currently underway.

Respectfully submitted,

H. W. Denny
Projector Director, A2649

Approved:

D. W. Robertson, Director
Electronics Technology Laboratory

HWD/nb



ENGINEERING EXPERIMENT STATION

GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

October 21, 1980

Headquarters,
Defense Nuclear Agency
Washington, D. C. 20305

Attention: Maj. Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 3, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period of 16 September 1980 to 15 October 1980.

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum location for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

The activities this reporting period have been directed at the formulation of a computer program to evaluate the short circuit current at one end of overhead and buried transmission lines. (These external conductors are being initially considered as the primary collectors of EMP energy for a facility.) The FORTRAN IV program is based on making the assumptions of:

- (1) the EMP waveform can be approximated by a single exponential function;
- (2) the ground has finite and uniform conductivity; and

-Maj. Blair Williams
October 21, 1980
Page 2

- (3) the transmission line has ideal surge suppressors at each grounding point.

Worst-case induced currents are to be calculated under various angles of incidence and for variably located ground points. To date, an appropriate algorithm has been selected and programmed. Computer evaluations will be begun during the next reporting period.

As an adjunct activity, analytical and scale modeling techniques for assessing EMP coupling into buildings are being surveyed. Initial emphasis is being placed on Method of Moments techniques and thin wire scale modeling.

A literature search of techniques for determining earth electrode impedance behavior and for performing in situ electrode impedance measurements is also underway. Techniques which permit characterization of performance at RF frequencies high enough to define grounding effectiveness for EMP waveforms are being emphasized.

Respectfully submitted,

H. W. Denny
Projector Director, A-2649

Approved:

D. W. Robertson, Director
Electronics Technology Laboratory

HWD/sjp



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

November 25, 1980

Headquarters,
Defense Nuclear Agency
Washington, D. C. 20305

Attention: Maj. Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 4, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period 16 October 1980 to 15 November 1980.

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum location for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

The activities during the reporting period have been associated with the accomplishment of Tasks 1 and 2. A candidate model that is purported to describe EMP coupling to an overhead power transmission line was programmed. Test computer runs for horizontally and vertically polarized incident fields failed to converge. Efforts to verify the accuracy of the equation used were not successful due to inadequate documentation being available.

Because of these difficulties, an alternate modeling approach is being investigated. This alternate approach seeks to evolve a generalized, but segmented, transmission line model. The model incorporates soil resistivity and capacitance effects. It is structured so as to

Maj. Blair Williams
November 25, 1980
Page 2

allow initially very simple calculations to be performed and then to be expanded to permit increasingly detailed analyses to be made. Further evaluation of the merits of the approach are to be conducted during the next reporting period.

The literature search for methods for determining soil parameters over the EMP spectrum indicates that in situ methods can be classified as either Surface or Drill Hole. Surface techniques include the Four Probe, Two Loop, Wave Tilt, Antenna Input Impedance, Power Reflectivity, and Field-Variation-with-Distance Methods. Drill hole techniques also include the Four Probe, Two Loop, and Antenna Input Impedance Methods along with Surface-to-Hole, Hole-to-Hole, Axial Electric Field Decay, Transmission Line, and Interference Methods. The Surface methods are more convenient to use. However, they are more subject to inaccuracies arising from surface irregularities and soil stratification. The relative merits of the various approaches are continuing to be evaluated.

It is expected that emphasis will continue to be placed on pursuing the above studies during the next reporting period.

Respectfully submitted,

H. W. Denny
Project Director, A-2649

Approved:

D. W. Robertson, Director
Electronics Technology Laboratory

HWD/nb



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

December 19, 1980

Headquarters,
Defense Nuclear Agency
Washington, D. C. 20305

Attention: Maj. Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 5, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period 16 November 1980 to 15 December 1980.

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum location for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

In connection with the accomplishment of Task 1, methods and tools for calculating the relative currents and voltages induced in both external and internal collectors are being identified. Relative to the external collectors, multiple conductor transmission line algorithms are being reviewed to determine their applicability to the coupling of an incident EMP to overhead power transmission lines. These algorithms incorporate an imperfect earth return, can be done in per unit line section, and involve chain parameter matrices to link the power induced on one section of line to an adjacent section of line. Each section of line is modeled by self and mutual circuit parameters. The voltage and current induced on each line section by the incident field are modeled as voltage and current sources. This method yields a frequency domain representation

Major Blair Williams
December 19, 1980
Page 2

which can be converted to the time domain by a Fast Fourier transform method. The end result of this study will yield a FORTRAN program to predict the voltage and current induced on a finite length, multiconductor transmission line with multiple ground points and imperfect earth returns.

The advantage of modeling the effects of nuclear EMP on the internal collectors of a building using a time domain computer code (e.g., WT-MBA-LLLLB) is being weighed over the use of a frequency domain computer code (e.g., LL N.E.C. code), where the frequency domain solution is transformed to the time domain by a Fast Fourier transform. Traditionally, EMP problems have been solved using a frequency domain solution; however, a time domain solution may be more cost effective. Numerical accuracy, cost, and generalizability of specific codes are all being considered. Either a time domain or a frequency domain solution of the EMP effects requires that the building's internal collectors, structural frame wiring harness, conduit, etc., be modeled by a complex array of conductors. These conductors may be totally buried in the ground, some may be above the ground, while a few may be partially penetrating into the ground. One method of modeling the three different types of collectors is to model the collectors above the ground as antennas in the presence of a lossy ground, and to model the partial and totally buried collectors as loaded antennas. Another method, which at this time seems more feasible, is to calculate the currents induced on the buried conductors, including the buried portion of the partially buried conductors, and model the remaining structure in the presence of a lossy ground, with injected current sources at the points of intersection with the ground. Both methods are being considered.

Respectfully submitted,

0
H. W. Denny
Project Director, A-2649

APPROVED:

for D. W., Robertson //
Electronics Technology Laboratory

HWD/nb
HWD/nbHWD/nb



ENGINEERING EXPERIMENT STATION

GEORGIA INSTITUTE OF TECHNOLOGY • ATLANTA, GEORGIA 30332

January 30, 1981

Headquarters,
Defense Nuclear Agency
Washington, D. C. 20305

Attention: Maj. Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 6, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period 16 December 1980 to 15 January 1981.

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum location for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

In accordance with Tasks 1 and 2, an appropriate transmission line model has been selected. The model is based on transmission line theory developed by Dr. C. R. Paul of the University of Kentucky. The model utilizes state variable chain parameter matrices of a per unit length of transmission line. The technique iteratively computes the voltage and current in a transmission line section from the voltages and currents induced in that section by an incident EMP wave and from the voltages and currents induced in a preceding line section.

The technique is to be initially evaluated using as an example a 7.2kv, 3-phase distribution line with a wire ground to lossy earth. The ground earth connection is to be a ground stake with an arbitrary impedance. The equations

Defense Nuclear Agency

Attention: Maj. Blair Williams, RAEE

- 2 -

January 30, 1981

for the EMP-induced voltage and current terms will assume finite earth conductivity which means ground plane reflections will not be perfect.

For the evaluation of collectors inside a structure, time domain calculations will be attempted. In the event that time domain calculations accrue excessive computer time, frequency domain calculations will be performed with successive conversions to the time domain.

The survey of candidate soil impedance determination techniques has been completed and is in the process of being documented. The next step of this task is to evaluate the techniques for the determination of earth electrode performance at EMP frequencies.

Respectfully submitted,

H. W. Denny
Project Director, A-2649

Approved:

F. L. Cain, Director
Electronics and Computer Systems Laboratory



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

February 26, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 7, Contract No. DNA001-80-C-0294,
"Supplemental Grounding of Extended EMP Collectors,"
covering the period 16 January 1981 to 15 February 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of internal collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

Continuing the efforts under Task 1, the time domain computer code developed by Lawrence Livermore Lab (LLL) (wt-MBA/LLL1B) has been implemented on an in-house VAX-11780 computer system. This code is used in modeling the coupling of the high altitude electromagnetic pulse (HEMP) to the internal collectors of a given structure. Validations are currently being carried out.

In order to compare the relative efficiencies of the collection of HEMP energy by the external collectors to the collected energy by the

internal collectors, the frequency domain solution developed by Dr. C. R. Paul must be converted to the time domain via a Fourier conversion. This will be done by a method developed by LLL, namely Filon's Method. Efforts are now being carried out to determine the optimum number of discrete frequency points that will be required to best reproduce the correct time domain waveform. Pending the results of this study, a more realistic evaluation of the cost effectiveness of the methodology will be determined.

In regard to Task 2, the evaluation of the possible reduction of HEMP induced currents on external collectors by using supplemental grounds requires an accurate model of a driven ground rod. The equivalent circuit model for ultrahigh frequencies presented in the IEEE Guide for Safety in AC Substation Grounding was selected. This circuit model has an inductance, which models the inductance of the down conductor, in series with a parallel R-C network. The resistance and capacitance terms are both frequency - dependent due to the frequency dependence of the constituent earth parameters (σ and ϵ). This model is intuitively gratifying and will initially be incorporated into the transmission line model. Near term plans are to design some experiments to (1) evaluate earth electrode measurements techniques and (2) examine the frequency behavior of simple types of earth electrodes.

Respectfully submitted,

H. W. Denny U
Project Director

Approved:

F. L. Cain, Director
Electronics and Computer Systems Laboratory



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

March 18, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 8, Project A-2649, Contract No. DNA001-80-C-0294, "Supplemental Grounding of Extended EMP Collectors," covering the period 16 February 1981 to 15 March 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

Relative to Task 1, efforts are being continued to validate the time domain computer code (WT-MBA/LLL1B), which is also known as the Thin Wire Time Domain code (TWTD). The TWTD code is planned to be used to model the internal collectors of the facility; however, if TWTD proves unsuitable for analyzing the structure, a frequency domain code will be used.

Also as a part of Task 1, a frequency domain solution for multiconductor transmission lines in the presence of a lossy ground is being implemented. A Fortran computer code to solve for the induced currents on the external collectors has been started. To model the effects of the lossy earth return, computer routines implementing Carson's formulas have been created, and are currently being tested. Carson's formulas require knowledge of the soil conductivity and the relative dielectric constant, over the frequency range of interest. The dependence of soil conductivity and dielectric constant on frequency was originally

studied by Scott; however, his equations are valid only in the frequency range from 1 kHz to 1 MHz. For HEMP analysis, the frequency range from 10 kHz to 100 MHz is of major concern and, consequently, extrapolation of Scott's curves is necessary. This extension was done graphically by Mission Research Corporation; this graphical representation has been expressed using a polynomial curve fitting method.

If necessary, the internal collectors and the external collector currents will be determined in the frequency domain rather than in the time domain. If time domain analysis is required, conversion to the time domain will be done using 37 discrete frequencies between 10 kHz and 100 MHz via Filon's method. Since this is a relatively small number of frequency points, the frequency domain approach is practical for the external collectors, and possibly for the internal collectors as well.

The Method of Moments Workshop held in Orlando, Florida from February 17-19, 1981 was attended by G. Bruce Melson. The most current method of moments techniques for solving scattering and coupling problems were presented at the workshop. Many of these techniques add perspective and additional capabilities for evaluating the response of both internal and external conductors to EMP.

Respectfully submitted,

Hugh W. Denny
Project Director

oved:

F. L. Cain, Director
Electronics and Computer Systems Laboratory



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

April 8, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 9, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
10 March 1981 to 9 April 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

On Tasks 1 and 2, the computer algorithm to be used to determine the effects of supplemental grounding of a multiconductor transmission line in the presence of a lossy ground when impinged upon by an incident field is progressing. A state variable chain parameter matrix method was chosen to model the transmission line. This method was selected to allow the arbitrary grounding of certain sections of the line. The code required to calculate the chain parameter matrices has been implemented. Several special routines were required for these calculations. These routines included a matrix inversion routine, which inverts a diagonally dominant symmetric matrix, and a routine to compute the frequency dependent soil impedance using Carson's Formulas. These routines have been implemented and tested.

The next step in the development of the transmission line solution will be to calculate the incident field coupling to the transmission line. The incident field coupling problem requires a redevelopment of Paul's coupling equations. These equations must be rederived taking into account the presence of a lossy ground; however, they must also be derived so that they will be amenable to implementation on a digital computer. The coupling equations are currently being derived and implemented.

Once the induced currents have been calculated, the total currents can be determined by applying the terminal conditions and solving the n^{th} order system of linear equations.

Relative to Tasks 3 and 4, an extensive literature search revealed a lack of data for the high frequency surge impedance of ground rods. The general theory for calculating the surge impedance of a conducting rod in the earth is an extension of the perfectly conducting hemispherical electrode sunk into an extended region of space the conductivity of which is nonzero but finite. The rod is assumed to be made of many spheres each of which contributes to the overall surge impedance of the rod. Using this theory the equation for the surge impedance is:

$$Z = \sqrt{\frac{L}{C}} = 60 \sqrt{\frac{\mu}{\epsilon}} \ln \left(\frac{2L}{a} \right) \text{ ohms,}$$

where μ and ϵ are the relative permeability and dielectric constants of the soil, L is the length of the rod and a is its radius.

The actual measurement of surge impedance at high frequencies is very complicated because the measuring apparatus will distort the measurements. Several measuring techniques were chosen from the literature for further study. Among these are: (1) resonant-antenna technique, (2) 100 μsec wide square wave current tests, and (3) measuring lightning stroke rise time. The first technique, resonant-antenna, looks to be the most promising. An experimental implementation of this technique has been designed and is currently under construction.

Respectfully submitted,

H. W. Denny, Director
Project A-2649

Approved:

A. L. Cain, Director
Electronics and Computer Systems Laboratory



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

May 8, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 10, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
10 April 1981 to 9 May 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

On Task 1, the incident field coupling analysis for a three-phase transmission line multiply grounded to lossy earth has been completed. The resulting algorithms have been programmed on a VAX 11/780 computer. Because of the magnitude of the program and the expected running time, detailed checking and testing of the code is being performed. Special care is being taken to check out each separate section of the program. Since no data currently exists against which program results can be compared, validation is being pursued with thoroughness. The validation is being performed module by module rather than in totality. It is expected that trial runs to initially check out the program and then to begin to examine the effects of transmission line, soil, and grounding parameters on relative EMP pickup (i.e. Task 2) will be begun next month.

For Task 3, a literature survey of techniques for determining ground conductivity, permittivity and permeability has been completed. An interim report on the results of the survey is being prepared.

Also related to Task 3 as well as to Task 4, construction continued on candidate test apparatus for measuring the surge impedance of buried ground rods. The apparatus consists of a tapered coaxial line section which establishes an appropriate transition between the top of the ground rod and an RF network analyzer. The dimensions of the coaxial transition were chosen so as to allow direct indication of the impedance characteristics of the ground-rod-earth combination. Initial measurements indicated that the technique has considerable promise. Additional refinements include the need to provide a larger soil contact probe and to establish an impedance reference from which true impedance values may be determined. In general, however, the first data runs indicated plausible behavior. In view of the encouraging results with the technique, additional investigations are planned.

Respectfully submitted,

H. W. Denny, Director
Project A-2649

Approved:

F. L. Cain, Director
Electronics and Computer Systems Laboratory



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

June 4, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 11, Project A-2649, Contract No.
DNA001-80-C-0294, "Supplemental Grounding of Extended EMP
Collectors," covering the period 10 May 1981 to 9 June 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

As noted last month, a transmission line model appropriate for the analysis of grounding effects on EMP pickup has been developed and programmed on a Vax 11/780 computer. Validation checks on the software have been completed. An initial verification run of the case of a transmission line over a perfectly conducting ground plane gave promising results in the frequency domain. Transformation to the time domain, however, did not produce the expected pulse-leading-edge behavior, i.e., the risetime and shape of the induced pulse indicated inadequate transformation of high frequency components. Steps are underway to utilize Fast Fourier Transform (FFT) techniques for the conversion in lieu of Filon's method (see Progress Report No. 7). These steps are expected to produce the required improvement in the shape of the leading edge of the induced pulse. Additional activities to be conducted next month include computer runs of the model with realistic sets of line and soil parameters.

On Tasks 3 and 4, a soil impedance testing probe was constructed and evaluated. A sketch of the probe is attached as Figure 1. This probe was used in various setups to investigate the frequency behavior of the electrode and the surrounding soil. The high frequency setup depicted in Figure 2 employed a General Radio RF Network Analyzer to examine behavior from 0.5 MHz to 500 MHz. Typical results are shown in Figure 3 (a-h). These displays indicate that above 0.5 MHz the net response of the probe is capacitive which reinforces the choice previously made for the equivalent network for a ground rod. The successive decrease in the number of resonances in the response with the addition of more ground rods reflects the benefits of greater soil contact and reduced path inductance in improving the high frequency response of a ground electrode.

Low frequency (< 100 Hz) evaluation of the probe was performed with the setup shown in Figure 4. Results with this setup were as expected.

The mid frequency (100 Hz - 0.5 MHz) range is important for determining the Q of the RLC circuit model for the ground electrode. Measurements in this frequency range are proving to be a challenge. The frequencies are too high for conventional earth electrode testers and too low for network analyzers. The test setup shown in Figure 5 was used as an initial trial. Difficulties with instrumentation loading effects and stray noise currents have thus far caused ambiguities in the data. Steps are underway to refine the test setup through the addition of pickup loops for the measurement of current. Efforts next month are expected to emphasize refinement of the mid-frequency measurement setup.

Respectfully submitted,

H. W. Denny, Director
Project A-2649

Approved:

F. L. Cain, Director
Electronics and Computer Systems Laboratory

Ground Electrode Configuration





Figure 1. Soil Impedance Testing Probe.

Figure 2. High Frequency Ground Impedance Measurement






Figure 3d.




Figure 3e.




Figure 3f.




Figure 3a.




Figure 3b.





Figure 3c.

Ground Rod,
4 auxiliary
Grounds, and
Ground Plate

26
ohms
95




32°
-29° phase

.5 MHz 500

Figure 3g.

Ground Rod,
4 auxiliary
Grounds, and
Buried Ground
Plate

30
ohms
110



30°
-20° phase

.5 MHz 500

Figure 3h.

Figure 3. High Frequency Measurement Results.

Figure 4. Low Frequency Ground Impedance Measurement





Figure 5. Mid Frequency Ground Impedance Measurement





Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

July 1, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 12, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
10 June 1981 to 9 July 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

On Tasks 1 and 2, several trial runs of transmission line analyses were conducted. Plausible results were obtained for induced peak pulse amplitudes and for late time pulse amplitudes and for late time pulse behavior. However, the early time (i.e. leading edge) response of the induced pulse does not appear realistic, particularly for long (>10 m) or high (>10 m) transmission lines. Intensive efforts are underway to identify the cause of this unexpected response. Plans are to proceed to use the model to analyze the effects on peak pulse amplitudes of various transmission line parameters and different grounding points.

For Tasks 3 and 4, testing of the impedance ground test probe continued in the midfrequency (100 Hz - 0.5 MHz) range. An HP 1110A current probe and an HP 1111A current amplifier (see Figure 1) were used to assist in the

determination of impedance in this range. The graph of Figure 2 was derived from these measurements; it agrees well at the end points with the results obtained with the General Radio RF Network Analyzer (above 0.5 MHz) and with the Biddle Ground Test Bridge (< 100 Hz). These results will be analyzed to determine the equivalent circuit (R, L, C) of the test ground rod.

In addition to these activities, work commenced on the development of a ground scale model. A mixture of sand and powdered graphite will allow a scaling of 1000:1 at 70 KHz. These tests will be carried out in the laboratory Shielded Room. Plans are to measure the variation in impedance from various ground rod configurations.

H. W. Denny, G. B. Melson, and D. P. Millard visited DNA on 1 July for the purpose of reviewing the activities and accomplishments to date under the program.


Respectfully submitted,

H. W. Denny
Project Director, A-2649


Approved:


F. L. Cain, Director
Electronics and Computer Systems Laboratory

Mid Frequency Ground Impedance Measurement



MID-FREQUENCY GROUND IMPEDANCE MEASUREMENTS





Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

31 July 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 13, Project A-2649,
Contract No. DNA001-80-C-0294, "Supplemental
Grounding of Extended EMP Collectors," covering
the period 1 July 1981 to 31 July 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

Relative to Tasks 1 and 2, difficulties have previously been reported in obtaining what was considered realistic early time response behavior of the time waveform produced by EMP on external collectors, specifically overhead transmission lines. Intensive efforts this month have resolved this problem, and realistic wave shapes are now produced by the computer code. To illustrate, Figure 1 compares the time response of Georgia Tech's

transmission line coupling model (upper graph) with those previously reported by Marable, Barnes, and Nelson* (lower graph). The results agree closely both in relative magnitudes and in general waveshape.

Several test cases were run, and the results are illustrated in Figures 2 through 7. Figure 2 shows the computed current response of a 50 m line over a perfectly conducting ground plane short circuited at both ends, while Figure 3 shows the response of the same line over a lossy ground plane. It can be seen from these two figures that the current induced in the line is greater over a lossy ground plane than over a perfect ground plane; this effect can be attributed to the influence of reflections from the ground plane.

Figure 4 shows the response of a 50 m line over a lossy ground with a short circuit at the output and a 100 ohm input, while Figure 5 shows the same line with an additional ground point at the center. For this case, the additional ground has no effect on the induced current pulse amplitude and only slightly alters the pulse shape.

Figures 6 and 7 compare the responses of a 10 m long line with that of a 500 m line, both over lossy ground with 100 ohms input impedance and short circuited at the output. It can be seen that a slight increase in pulse current amplitude does occur in going from 10 m to 500 m in length.

As a result of the efforts this month, confidence now exists in the ability of our transmission line code to analyze the EMP response of external conductors. The overall time response intuitively satisfies the appropriate physical constraints and agrees well with the independently-derived results of other investigators. The preliminary results produced by the code indicate that supplemental ground connections do not exert a primary influence on either the amplitude or the wave shape of the induced EMP. The next planned activities are to utilize the code to examine the behavior of the induced pulse under varying conditions of terminating impedances, line lengths, line elevations, and number of ground points.

*Marable, James H., Barnes, Paul R., and Nelson, David B., "Power System EMP Protection," Interaction Note 246.

Progress Report No. 13
31 July 1981
Page Three

Additional activities this month included continued work on the scale modeling of earth electrode systems and investigations into the electromagnetic shielding properties of typical structures. A sand-graphite mixture was prepared, and a series of various ground electrode configurations were constructed. A study of the impedance properties of these configurations as a function of frequency is to be conducted. The shielding study is being conducted as part of an attempt to construct an equivalent filtering function potentially usable for estimating the response internal conductors to incident EMP.

Respectfully submitted,


H. W. Denny
Project Director, A-2649

HWD:gh

Approved:


Fred L. Cain, Director
Electronics and Computer Systems Laboratory

Attachments



(a)

ORNL-DWG 74-7720



(b)

Figure 1. a) Calculated results. (b) Marable's results. For a infinitely long wire 10 meters above the ground.




Figure 2. A 50 meter line over a perfect conducting ground, shorted at both ends.




Figure 3. A 50 meter line over a lossy ground, shorted at both ends.




Figure 4. A 50 meter line over a lossy ground, with a 100Ω input impedance and terminated with a short.




Figure 5. A 50 meter line over a lossy ground, with a 100Ω input impedance and terminated with a short. The line is grounded at the center.




Figure 6. A 10 meter line over a lossy ground, with a 100Ω input impedance and terminated with a short.




Figure 7. A 500 meter line over a lossy ground plane, with a $100\ \Omega$ input impedance and terminated with a short.



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

September 9, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 14, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
1 August 1981 to 31 August 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

The primary effort this month was directed to Task 2, namely an assessment of the impact of multiple grounds on EMP-induced currents on external collectors. The previously described transmission line analysis program was utilized to examine the behavior of the induced current on overhead transmission lines grounded at various points. The peak amplitudes of the induced currents were determined for several conditions of line length, height above ground, and number of grounding points. For each condition examined, line parameters of wire radius, input impedance and output impedance were maintained constant at 200 mils, 100 Ω and 500 Ω respectively.

Figure 1 shows the behavior of peak pulse amplitude as a function of transmission line length. (For this series of calculations, no ground connections were assumed.) Note that for this particular case of a 10 meter high line over a lossy ground the peak current increases rapidly with length up to about 50 meters. Beyond 50 m and on to 1000 m, the peak current remains essentially constant except for an additional rise of approximately 25 percent in the vicinity of 500 m. Although this "peak" has not yet been thoroughly analyzed, it probably is related to a pseudo-resonant length of the transmission line.

Figure 2 shows the impact of number of ground points equally spaced over a 50 meter length of line at various line heights from 1 meter to 15 meters. It can be observed from this figure that the effects of supplemental grounds are more pronounced as the height of the line above the earth increases; for normal (<10 m) heights, the effects of the grounding points are somewhat limited.

Figure 3 examines the role of a fixed number of grounding points evenly distributed over varying lengths of lines. The behavior of the 10 meter long line (height also equal to 10 meters) implies that grounding points 1 meter apart (10 meters long divided by 10 grounding points) may be required to make a noticeable impact on the amplitude of the EMP-induced current.

The early implications of these results are that control of the EMP-related current on external collectors at the facility penetration point is perhaps most receptive to the installation of supplemental grounds within the first 50 meter portion of the line adjacent to the facility. We wish to emphasize the very tentative nature of this observation and that it is subject to change upon further analysis of the transmission line behavior.

In addition to the analysis work, experimental investigations of the high frequency (fast time) behavior of various earth electrodes were performed on appropriately scaled models. Through the use of these models, the impedance of the electrodes was shown to be related to their geometric mean areas at high frequencies thus confirming the relationship previously shown to exist at low (power) frequencies. The results also showed that ground rod length becomes increasingly less important as frequency rises.

Respectfully submitted,

H. W. Denny
Project Director, A-2649

Approved:

F. L. Cain, Director
Electronics and Computer Systems Laboratory




Figure 1. Transmission Line Peak EMP-Induced Current As A Function of Line Length (0 Grounds).




Figure 2. Peak EMP-Induced Transmission Line Current Versus Number of Ground Points Along A 50 m Line.




Figure 3. Peak EMP-Induced Transmission Line Current Versus Number of Ground Points Along Varying Lengths of Line.

A-2649



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

October 9, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 15, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
1 September 1981 to 30 September 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

Activities this month were devoted to Tasks 1 and 2, and to the initiation of the final report.

On Task 1, preliminary efforts are underway to assess the EMP coupling to collectors internal to an imperfectly shielded structure. The initial approach being taken is to utilize Lawrence Livermore Labs WT-MBA/LLL1B (Time Domain Electromagnetic Response of Thin Wire Structures) computer program to evaluate the responses of certain test cases. In order to perform the evaluation, however, it is necessary to modify the program to accept an incident EMP waveform defined as a four-term exponential rather than Gaussian. This modification was made and a series of test cases were

designed; the test cases are designed to determine the EMP coupling to a single wire surrounded by a wire mesh of varying complexities. Examples of the test cases are illustrated in the accompanying figure. For each of the test cases, the wire of concern is vertically centered and is not physically connected to any of the mesh conductors. The incident EMP waveform is assumed to have the E-field vector parallel to the internal conductor. The computer program has been implemented on a VAX 11/780 computer and the test cases are currently being examined. The results from the test cases will guide the evaluation of more realistic (and more complicated) structural configurations.

Relative to Task 2, last month's status report noted some potential impact of multiple ground points on the EMP-induced peak current levels on external transmission lines, particularly on short-to-moderate length lines. To more fully examine the trends implied by the earlier analyses, it was decided to analyze the pickup behavior of various types of lines with more grounding points. The VAX 11/780 computer, however, proved unable to handle the large number of line segments involved. Thus, the transmission line model is now being transferred to the Georgia Tech CYBER 74. This transfer is expected to be completed shortly and the expanded analyses will be conducted.


Documentation of the activities and results of all the tasks to date for the final report has been begun. These efforts are expected to accelerate next month along with continued efforts, as described above, on Tasks 2 and 3.

Respectfully submitted,

Hugh W. Denny, Director
Project A-2649

Approved:


Fred L. Cain, Director
Electronics and Computer Systems Laboratory




Incident EMP Orientation



Case I



Case II



Case III

Test Cases For The Analysis of EMP Coupling To Internal Collectors.



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

November 9, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 16, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
1 October 1981 to 30 October 1981

Gentlemen:

The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.

Relative to Task 1, efforts were primarily devoted to completion of the conversion of the transmission line coupling computer program from the VAX 11/780 to the CYBER 74. This conversion has been completed and steps are underway to analyze the effects of various numbers of grounds on that portion of an external collector closest to the facility. It is expected that the results will be available shortly.

Investigations into analytical means for assessing the EMP response of internal collectors are continuing. Results this month indicate that perhaps some computer models other than Lawrence Livermore Labs' TWTD need to be evaluated. Success with TWTD has been somewhat limited.

The primary effort this month has gone into the preparation of the draft final report. Most major sections have been drafted and are currently in typing.

Respectfully submitted,

Hugh W. Denny, Director
Project A-2649

Approved:

Fred L. Cain, Director
Electronics and Computer Systems Laboratory



Georgia Institute of Technology
ENGINEERING EXPERIMENT STATION
ATLANTA, GEORGIA 30332

December 9, 1981

Headquarters,
Defense Nuclear Agency
Washington, DC 20305

Attention: Major Blair Williams, RAEE
EMP Effects Division

Subject: Progress Report No. 17, Project A-2649, Contract
No. DNA001-80-C-0294, "Supplemental Grounding
of Extended EMP Collectors", covering the period
1 November 1981 to 30 November 1981

Gentlemen:


The particular tasks to be performed on this effort are:

1. Perform appropriate modeling and review to assess the relative EMP collection efficiency of the internal and external collectors of a facility.
2. Examine the possible reduction in EMP-induced currents on facility external conductors and shields and in the primary earth electrode system achievable through the grounding of the collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes).
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey to determine the optimum locations for the auxiliary earth electrode systems.
4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation.


The activities this month were devoted to preparing the draft final technical report describing the activities undertaken and the results

obtained on the above four tasks. As of the end of the month, final editorial changes were being made with the expectation that the draft for review would be forwarded near the first of December.

Respectfully submitted,


Hugh W. Denny, Director
Project A-2649

Approved:


Fred L. Cain, Director
Electronics and Computer Systems Laboratory

SUPPLEMENTAL GROUNDING OF EXTENDED EMP COLLECTORS

Georgia Institute of Technology
Engineering Experiment Station
Electronics and Computer Systems Laboratory
Atlanta, Georgia 30332

31 January 1982

Final Report for Period 1 May 1980—31 January 1982

CONTRACT No. DNA 001-80-C-0294

| |
|--|
| <p>APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED.</p> |
|--|

THIS WORK WAS SPONSORED BY THE DEFENSE NUCLEAR AGENCY
UNDER RDT&E RMSS CODE B363080462 G52AAXEX40602 H2590D.

Prepared for
Director
DEFENSE NUCLEAR AGENCY
Washington, DC 20305

Destroy this report when it is no longer needed. Do not return to sender.

PLEASE NOTIFY THE DEFENSE NUCLEAR AGENCY,
ATTN: STTI, WASHINGTON, D.C. 20305, IF
YOUR ADDRESS IS INCORRECT, IF YOU WISH TO
BE DELETED FROM THE DISTRIBUTION LIST, OR
IF THE ADDRESSEE IS NO LONGER EMPLOYED BY
YOUR ORGANIZATION.



SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

| REPORT DOCUMENTATION PAGE | | READ INSTRUCTIONS BEFORE COMPLETING FORM |
|--|-----------------------|--|
| 1. REPORT NUMBER DNA 5940F | 2. GOVT ACCESSION NO. | 3. RECIPIENT'S CATALOG NUMBER |
| 4. TITLE (and Subtitle) SUPPLEMENTAL GROUNDING OF EXTENDED EMP COLLECTORS | | 5. TYPE OF REPORT & PERIOD COVERED Final Report for Period 1 May 80 to 31 Jan 82 |
| | | 6. PERFORMING ORG. REPORT NUMBER |
| 7. AUTHOR(s) H. W. Denny, D. W. Acree, G. B. Melson, D. P. Millard | | 8. CONTRACT OR GRANT NUMBER(s) DNA 001-80-C-0294 |
| 9. PERFORMING ORGANIZATION NAME AND ADDRESS Georgia Institute of Technology Engineering Experiment Station Electronics and Computer Systems Laboratory Atlanta, Georgia 30332 | | 10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS Subtask G52AAXEX406-02 |
| 11. CONTROLLING OFFICE NAME AND ADDRESS Director Defense Nuclear Agency Washington, DC 20305 | | 12. REPORT DATE 31 January 1982 |
| | | 13. NUMBER OF PAGES 182 |
| 14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) | | 15. SECURITY CLASS. (of this report) UNCLASSIFIED |
| | | 15a. DECLASSIFICATION/DOWNGRADING SCHEDULE N/A since unclassified |
| 16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited. | | |
| 17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report) | | |
| 18. SUPPLEMENTARY NOTES This work was sponsored by the Defense Nuclear Agency under RDT&E RMSS Code B363080462 G52AAXEX40602 H2590D. | | |
| 19. KEY WORDS (Continue on reverse side if necessary and identify by block number) EMP Grounding Transmission Lines Earth Electrodes Shielding Computer Modeling | | |
| 20. ABSTRACT (Continue on reverse side if necessary and identify by block number) The external conductors of a facility, particularly long, above ground types, pose a severe EMP threat. A primary purpose of this program was to investigate the premise that supplemental ground connections in these types of conductors could serve to reduce this threat. To support this investigation an External Collector Analysis Model (ECAM) was developed. ECAM was applied to analyzing the EMP-induced current levels appearing at a facility under various conditions of line length, line height, and number of grounds. From the | | |

20. ABSTRACT (Continued)

results, approaches to the treatment of external collector penetrations are suggested.

In addition to the external collector assessments, preliminary studies of internal collector responses are reported. Supplemental studies of techniques for measuring the responses of earth electrode systems over the EMP power spectrum are described. A successful technique utilizing currently available instrumentation was used to validate a test probe and to evaluate scaled models of various commonly used earth electrode geometries. From the measurements, observations relating to the behavior of various geometries up to 500 MHz are made.

SUMMARY

The purpose of this program was to investigate the premise that supplemental grounds on external EMP collectors could serve to reduce the threat levels appearing at equipment terminals inside a facility. The investigation consisted of:

The development of an External Collector Assessment Model (ECAM) which permitted the EMP response of long overhead collectors to be evaluated under varying conditions of line height, line length, and number of grounds;

A limited evaluation of the response of collectors internal to an unshielded facility to suggest the severity of pickup by these collectors relative to that arising from external collectors; and

The development of techniques for characterizing the response of an earth electrode (ground) to an EMP-type waveform.

ECAM was used to evaluate the amplitudes of EMP-induced currents at the termination (facility penetration) of variously configured overhead lines. The results indicate that supplemental grounds exert a primary influence on the induced current only when they are located within some 30-50 m of the penetration point. This effect suggests that the interface between the facility and its external collectors be remotely located with intervening conductors routed underground in noninsulated, metal conduit. A suggested layout is provided for both power lines and signal lines.

The results from the preliminary investigation of internal collector coupling using an available method of moments code strongly suggest that considerably more developmental work is going to be required if an analytical approach is to be used. The limited results that were achieved suggest that internal collector pickup should more thoroughly be evaluated relative to potential effects from external collector pickup. A more promising approach for quantifying the levels of internal collector pickup is that of experimental determination of the nominal shielding effectiveness of a typical, "unshielded" facility. Preliminary results suggest that indeed the inherent protective properties of typical construction may be usable and may be quantifiable. Data on two buildings of standard commercial construction indicate that over the range of frequencies containing most of the energy of an EMP, a general level of protection of from 20 to 40 dB may be realizable without extraordinary effort.

An earth electrode system was verified to behave like a second order, parallel, RLC network. It's low frequency (DC and power frequencies) impedance is predominantly determined by the resistivity of the soil and the length of the conductors. The high frequency (up to 500 MHz) impedance of the electrode is governed primarily by the soil's dielectric properties. The presence of rods appears to be unimportant in so far as the behavior of an electrode system at these higher frequencies is concerned. The contact of the electrode with the soil appears to be the primary factor in determining effectiveness.

For determining the best location for an earth electrode, a resonant antenna method is the most promising candidate for performing rapid ground conductivity and dielectric surveys. This method is portable, does not disturb the site, and accurately indicates performance over the frequency range occupied by the EMP power spectrum. This method can be supplemented with the standard Fall-of-Potential method to determine the low frequency (or DC) resistance of an electrode. High frequency measurements can be made with an RF network analyzer.

PREFACE

This report presents the results of a study to assess the EMP protection benefits of providing supplemental grounds on the extended external collectors associated with electronics facilities. This study was performed for the Defense Nuclear Agency under RDT&E RMSS CODE B363080462 G52AAXEX40602 H2590D as Contract DNA 001-80-C-0294. The program was monitored by Major Blair Williams, RAEE.

The work described in this report was performed by the Electromagnetic Compatibility (EMC) Division, Electronics and Computer Systems Laboratory (ECSL), Georgia Tech Engineering Experiment Station. The described work was directed by Mr. H. W. Denny, Chief of the EMC Division under the general supervision of Mr. F. L. Cain, Director of ECSL. The report was authored by Mr. Denny and by Mr. D. W. Acree, Mr. G. B. Melson, and Mr. D. P. Millard.

TABLE OF CONTENTS

| <u>Section</u> | <u>Page</u> |
|---|-------------|
| I. INTRODUCTION | 11 |
| 1.1 Background | 11 |
| 1.2 Technical Approach. | 17 |
| 1.3 Report Organization | 20 |
| II. EXTERNAL COLLECTOR ASSESSMENT MODEL(ECAM). | 21 |
| 2.1 Introduction. | 21 |
| 2.2 Model Development | 24 |
| 2.3 Use of ECAM to Evaluate the Effects of Supplemental Grounds on External Collectors. | 38 |
| III. INTERNAL COLLECTOR INVESTIGATION | 54 |
| 3.1 Introduction. | 54 |
| 3.2 Analytical Assessment of Internal Collector Coupling. | 55 |
| 3.3 Experimental Investigation of Structural Shielding at EMP Frequencies | 62 |
| IV. EARTH ELECTRODES FOR EMP GROUNDING | 73 |
| 4.1 Introduction. | 73 |
| 4.2 Standard Test Probe | 74 |
| 4.2.1 High Frequency Measurements. | 79 |
| 4.2.2 Low Frequency Measurements | 85 |
| 4.2.3 Mid-Frequency Measurements | 90 |
| 4.3 Evaluation of Ground Electrodes | 93 |
| 4.3.1 Scale Models | 93 |
| 4.3.2 Configuration Tests and Results. | 95 |
| 4.4 Observations. | 115 |
| V. CONCLUSIONS AND RECOMMENDATIONS | 117 |
| VI. REFERENCES | 119 |
| Appendix | A-1 |
| A. Filon's Method For Time-Frequency Domain Conversions | A-1 |
| B. Description of Multiconductor Transmission Line Behavior when Illuminated by an Incident Field in the Presence of a Lossy Ground | B-1 |
| C. Determination of the Earth Return Parameters | C-1 |
| D. Determination of the Similarity Transform T and its Inverse T^{-1} | D-1 |

TABLE OF CONTENTS (Concluded)

Appendix

| | | |
|----|--|-----|
| E. | Determination of the Induced Voltages Source $V_s(x)$ and the Induced Current Source $I_s(x)$ for the Overhead Transmission Line Model | E-1 |
| F. | Soil Parameter Identification Techniques | F-1 |

LIST OF ILLUSTRATIONS

| <u>Figure</u> | <u>Page</u> |
|---|-------------|
| 1. External lightning protection network conforming to the Lightning Protection Code. | 12 |
| 2. Common earth electrode configurations. | 13 |
| 3. Typical internal EMP collectors | 14 |
| 4. Facility grounding networks | 15 |
| 5. Supplemental grounding concept | 18 |
| 6. EMP coupling scenario. | 22 |
| 7. Per unit transmission line equivalent circuits. | 23 |
| 8. EMP time waveform and power spectrum representations | 25 |
| 9. Filter analogy of transmission line analysis problem | 26 |
| 10. Equivalent circuit of a segment of a grounded multiconductor transmission line in an incident field | 29 |
| 11. Equivalent circuit model of a ground rod and down conductor . | 33 |
| 12. Grounded transmission line model segment | 34 |
| 13. Comparative results of computed induced currents for an infinitely long wire, 10 meters high | 39 |
| 14. Computed EMP current response of a 50 meter line short circuited at both ends | 40 |
| 15. Computed EMP current response of a 50 meter line over lossy ground (line input terminated in 100 ohms and output short circuited) | 42 |
| 16. Computed EMP current response of two lengths of line over lossy ground (line input terminated in 100 ohms and output short circuited) | 43 |
| 17. Peak EMP-induced current as a function of line length (no supplemental grounds). | 44 |
| 18. Details of 0-50 meter portion of Figure 17 | 45 |

LIST OF ILLUSTRATIONS (Continued)

| <u>Figure</u> | <u>Page</u> |
|---|-------------|
| 19. Peak EMP-induced current as a function of number of supplemental grounds on a 50 meter line | 46 |
| 20. Peak EMP-induced current as a function of number of supplemental grounds for various lengths of transmission line | 47 |
| 21. Peak EMP-induced current as a function of uniformly distributed grounds | 48 |
| 22. Peak EMP-induced current versus line length for uniformly spaced supplemental grounds | 50 |
| 23. Candidate power line penetration treatment | 51 |
| 24. Candidate signal line penetration treatment | 52 |
| 25. Test cases for the analysis of internal collectors | 56 |
| 26. Calculated current response of a 1.5 m internal collector . . . | 58 |
| 27. Calculated current response of 0.05 m internal collector for three different shielding conditions | 60 |
| 28. Calculated (center zone) current response of a shielded versus an unshielded 0.5 m conductor | 61 |
| 29. Relative source locations for structural shielding effectiveness measurements | 65 |
| 30. Measured shielding effectiveness at selected locations in Building No. 1 | 67 |
| 31. Floor plan of Building No. 1 showing relative locations for measurements shown on Figure 30 | 69 |
| 32. Comparison of shielding effectiveness properties of the two measured buildings | 70 |
| 33. Shielding effectiveness versus floor level for Building No. 1. . | 71 |
| 34. Ground rod model | 75 |
| 35. Standard test probe details | 76 |
| 36. Photograph of standard test probe | 77 |
| 37. Connector input impedance | 78 |
| 38. Connector output impedance for calibrated 100 ohm load | 80 |

LIST OF ILLUSTRATIONS (Continued)

| <u>Figure</u> | <u>Page</u> |
|--|-------------|
| 39. Simple ground rod impedance | 80 |
| 40. Test set-up for high frequency measurements | 81 |
| 41. Impedance of ground rod and one auxiliary ground | 82 |
| 42. Impedance of ground rod and two auxiliary grounds | 82 |
| 43. Impedance of ground rod and three auxiliary grounds | 83 |
| 44. Impedance of ground rod and four auxiliary grounds | 83 |
| 45. Impedance of ground rod, four auxiliary grounds, and an aluminum ground plate. | 84 |
| 46. Impedance of ground rod, four auxiliary grounds, and a buried aluminum ground plate | 84 |
| 47. Computer simulation of impedance of ground electrode model. . | 86 |
| 48. Test setup for low frequency measurements | 87 |
| 49. Test probe resistance characteristic | 88 |
| 50. Soil resistivity measurement setup | 89 |
| 51. Test setup for mid-frequency measurement | 91 |
| 52. Mid-frequency ground electrode impedance behavior | 92 |
| 53. Test box for ground electrode model - cutaway view. | 96 |
| 54. Test box for ground electrode model - top view. | 97 |
| 55. Single ground rod model | 98 |
| 56. Two parallel rod model | 98 |
| 57. Three parallel rod model | 99 |
| 58. Eight parallel rod (star) model | 99 |
| 59. Eight parallel rod (loop) model | 100 |
| 60. Test setup for model impedance measurement | 101 |
| 61. Behavior of electrode resistance with relative area | 102 |

LIST OF ILLUSTRATIONS (continued)

| <u>Figure</u> | <u>Page</u> |
|---|-------------|
| 62. Single ground rod impedance behavior | 103 |
| 63. Two parallel rod impedance behavior | 103 |
| 64. Three parallel rod impedance behavior | 104 |
| 65. Eight parallel rod (star) impedance behavior | 104 |
| 66. Eight parallel rod (loop) impedance behavior | 105 |
| 67. Behavior of model impedances at various frequencies | 106 |
| 68. Marginal impedance per geometric mean distance of model | 107 |
| 69. Model 6 - Star with no ground rods | 110 |
| 70. Model 7 - Loop with no ground rods | 110 |
| 71. Model 6 impedance behavior | 111 |
| 72. Model 7 impedance behavior | 111 |
| 73. Comparison of Model 4 and Model 6 impedances at various frequencies | 112 |
| 74. Comparison of Model 5 and Model 7 impedances at various frequencies | 113 |
| 75. Model 8 - Model 6 with shorted ground connections | 114 |
| 76. Model 9 - Model 7 with shorted ground connections | 114 |
| 77. Model 8 impedance behavior | 116 |
| 78. Model 9 impedance behavior | 116 |
| A-1. Piecewise-linear approximation of a time function, $F(t)$ | A-2 |
| B-1. Incremental transmission line model. | B-2 |
| C-1. Conductor-earth geometry | C-2 |
| E-1. Definition of the uniform plane wave parameters | E-5 |
| F-1. Conductivity of soil versus frequency for various volume percent of water | F-3 |

LIST OF ILLUSTRATIONS (concluded)

| <u>Figure</u> | <u>Page</u> |
|--|-------------|
| F-2. Soil dielectric constant versus frequency for various volume percent of water | F-4 |
| F-3. Soil resistivity versus salt content | F-5 |
| F-4. Transmission line method for determining soil properties . | F-10 |
| F-5. Resonant cavity method for determining soil parameters . . | F-12 |
| F-6. Commonly used four-probe arrays | F-13 |
| F-7. Electrode resistance versus probe spacing | F-14 |
| F-8. Two-loop method for determining soil parameters. | F-16 |
| F-9. Loop orientations for two-loop method for determining soil parameters | F-17 |
| F-10. Illustration of wave tilt method of determining soil parameters | F-18 |
| F-11. Coaxial in-situ method for measuring soil parameters . . . | F-20 |
| F-12. Illustration of electrode layout of the linear antenna method for determining soil parameters | F-21 |

LIST OF TABLES

| <u>Table</u> | |
|---|-----|
| 1. Signal Attenuation in dB as Measured at Selected Locations in Building No. 1 | 63 |
| 2. Signal Attenuation in dB as Measured at Selected Locations in Building No. 2 | 64 |
| F-1. Low Frequency Electrical Characteristics of Various Types of Soils | F-7 |
| F-2. Dielectric and Conductivity Properties of Various Terrain at selected Wavelengths | F-8 |
| F-3. Dielectric Properties of Earth Media at Selected Frequencies | F-8 |

I. INTRODUCTION

1.1 BACKGROUND

Many facilities associated with important elements of the nation's defense system are potentially susceptible to damage and disruption from electromagnetic pulse (EMP) events arising from nuclear weapons detonations. The large and rapidly changing electromagnetic fields associated with an EMP are capable of inducing large currents in conducting objects. Such currents present a serious threat to electrical and electronic components and equipments. For example, consider the typical facility containing sensitive electronic apparatus such as a communications center, message switching center, computer center, etc. When supplied with utilities such as water, fuel, and sewage lines, and with electric power; when provided with external communications links, such as phone and data lines; and when protected against lightning with an appropriate lightning protection system (to include its earth electrode system), a complex array of potential EMP collectors exists. The EMP threat due to the longer collectors external to the facility, e.g., power lines, signal lines, and utility pipes, is well recognized. Other external collectors, such as the lightning downconductor network, have not been as adequately addressed. However, topologically these other conductor networks would also appear to be important contributors to the total EMP current environment against which protection must be provided. For example, Figure 1 shows a code-compatible [1] lightning air-terminal-downconductor network appropriate for a moderate to large size structure. Even simplified earth electrode systems like those shown in Figure 2 (whether outside or inside structural boundaries) appear to offer attractive pickup mechanisms for EMP energy. Either of these facility-related networks (and certainly the total combination) acts as an antenna to intercept the EMP pulse and, as a result, potentially damaging voltages and currents are produced on and between the network elements.

As shown by Figure 3, many occasions also arise where there are internal collections of equipment interconnected with power conductors, signal and control lines, ducts and raceways, and grounding cables. For example, the combined lightning protection, electrical safety/fault protection, and equipment EMI control networks frequently appear like the one shown in Figure 4. Each of these internal conductors is a possible EMP collector which may cause damaging potentials to be produced at critical points within individual pieces of equipment.




Figure 1. External lightning protection network conforming to the Lightning Protection Code.




Figure 2. Common earth electrode configurations.




Figure 3. Typical internal EMP collectors.




Figure 4. Facility grounding networks.

Many of the internal collectors are short to moderate in length, extending only from equipment rack to equipment rack, from room to room, or from floor to floor and are totally contained within a given volume (cabinet, room, or structure). A commonly suggested approach for protecting these conductors and associated terminating equipment from external electromagnetic fields is to enclose the entire volume in a metal shield, preferably one constructed of heavy gauge steel. Applied to an individual circuit or equipment, total enclosure in a metal shield is compatible with usual practices and, though requiring care in design and construction, does not extravagantly inflate the per unit costs of the protected circuit or equipment. However, where the volume to be protected is large, as, for example, a room or an entire structure, the cost of an adequate EMP shield markedly increases the normal cost of construction [2]. For maximum effectiveness from the shield, particular efforts must be taken to treat the apertures where signals, power, and other conductors enter the shielded region to prevent the EMP energy on these collectors from entering the shielded area. This required treatment places additional constraints upon construction which further raise costs.

The net threat appearing at any particular equipment port is the vector combination of the effects arising from the penetrating EMP field, the conducted voltages and currents resulting from induced currents on exo-equipment (and exo-facility) collectors, and the secondary EM fields produced by the induced collector currents. At the present time, the relative contribution of each of these effects is not clearly established. Intuitively, however, the long external collectors would appear to be the major contributor if for no other reason than typically they present a large effective antenna aperture.

The earth offers a convenient "sink" for dissipating the energy associated with the currents induced in the conductors leading to the facility. Therefore, major emphasis is usually placed on providing a low resistance connection to earth as close as possible to the point of entrance of collectors into the protected region. A low impedance path is established between the collector and the earth electrode. Then, to protect internal equipment against secondary fields and to minimize current concentration, a heavy shield is placed around the susceptible equipments. If, indeed, the primary contributors to voltages and currents at equipment terminals are the long external conductors, a significant reduction in these fields could be effected by reducing the level of the induced current at the point of entry into the sensitive region. A postulated way of reducing this

current would be to provide alternative, supplemental paths to "drain" the excess collected EMP energy to earth for dissipation prior to reaching the facility. This concept is illustrated by Figure 5. If effective, such a practice could reduce the overall shielding requirements of the facility and thus potentially promises to reduce the cost of EMP hardening. In addition to potential savings in direct costs, i.e., that associated with reducing the need for a heavy metal enclosure, the possible savings in indirect costs may be much greater. These indirect costs refer to those necessary to accommodate conflicts in philosophies, needs and practices between the EMP communities and the lightning protection and EMI communities. Any measures which will make these philosophies, needs and practices more compatible will reduce the total costs of facilities, particularly those in which all three considerations are involved, such as Defense Communications Service facilities.

In view of these possible benefits, an evaluation of supplemental grounding of long external EMP collectors through the use of auxiliary earth electrodes was undertaken. This evaluation considered: (1) the degree of effectiveness of auxiliary earth grounds in reducing the EMP currents induced on long external collectors; (2) the relative EMP energy picked up by external collectors versus that picked up by structural members and internal collectors (in an unshielded facility); (3) the soil and earth electrode system parameters necessary to realize effective auxiliary grounds; (4) methods for establishing preferred locations for the auxiliary grounds; and (5) means for measuring the installed electrodes to confirm that they met the established criteria.

1.2 TECHNICAL APPROACH

Within the context of the above background, an analytical and experimental program was undertaken to accomplish the following goals:

1. Perform appropriate modeling and analysis to assess the relative EMP collection efficiency of internal collectors versus the external collectors of a facility. For the external collectors, ascertain relative effective lengths for both above ground and buried installations.
2. Examine the possible reduction in EMP-induced currents on facility conductors and shields and in the primary earth electrode system achievable through the grounding of collectors at points prior to entering the facility (i.e., at auxiliary earth electrodes). In this assessment, consider:




Figure 5. Supplemental grounding concept.

- a. The necessary relative resistance and impedance to earth of the primary and auxiliary earth electrode systems;
 - b. The required earth resistivity parameters and electrode configurations;
 - c. The degree of reduction in the currents in facility shields, structural members, and primary earth electrode conductors achievable through supplemental grounding of external conductors; and
 - d. The optimum separation distances between the facility's primary electrode system and the auxiliary grounds.
3. Evaluate candidate techniques for rapidly performing a ground conductivity survey at a site to determine the optimum location for the auxiliary earth electrode systems.
 4. Determine the techniques necessary to measure the electrode impedance properties of the auxiliary electrodes after installation. Particular emphasis will be placed on methods usable in the vicinity of pre-existing electrode systems.

In pursuit of these goals, initially, a comprehensive literature survey was made for: (1) existing computer algorithms potentially applicable to the assessment of EMP coupling to collectors, both external and internal, (2) potential approaches to scale modeling for the assessment of collector coupling and the high frequency behavior of buried electrodes, and (3) techniques appropriate for the evaluation of earth electrode systems over frequency ranges compatible with the EMP spectrum. Based on the findings of the literature search, the following specific efforts were undertaken:

1. Development of a computer model capable of permitting an assessment of the EMP response of an extended overhead collector with multiple ground points. An above ground collector was emphasized because it was considered to represent a more severe threat than buried collectors (which enjoy some added protection from the absorbing properties of soil). In order to perform the necessary tradeoff studies, mathematical derivation of an improved algorithm was necessary. This algorithm was implemented on a pair of computers (VAX 11/780 and CYBER 74) and parametric studies were performed.
2. Assessment of techniques for evaluating EMP coupling to internal collectors. The techniques used were analytical modeling using method of moments techniques and experimental determination of the equivalent shielding effectiveness of actual structures over the EMP power spectrum.

3. Identification of an appropriate technique for characterizing the behavior of an earth electrode system (rod, grid, or array) at frequencies sufficient to define its effectiveness for suppression of an EMP. Experimental validation of the selected technique suggests its applicability to field utilization for surveying potential electrode configurations and for evaluating their performance once installed.

1.3 REPORT ORGANIZATION

The activities undertaken and the results achieved on the above efforts are described in the remaining sections of this report. Specifically, Section II discusses the development and utilization of the External Collector Assessment Model (ECAM) while Section III reviews the accomplishments of the internal collector evaluation study. Section IV describes the development of the technique for measuring earth electrode systems at high (to UHF) frequencies and discusses the behavior of various electrode configurations over the frequency range covered by the accepted EMP power spectrum. Overall conclusions and recommendations are set forth in Section V. Supporting analyses and supplementary information are contained in the appendices.

II. EXTERNAL COLLECTOR ASSESSMENT MODEL (ECAM)

2.1 INTRODUCTION

The scenario assumed for the assessment of EMP pickup by external collectors is depicted in Figure 6. An imperfectly shielded facility supplied with electric power from an overhead power line is assumed to represent a worst-case situation in terms of the amplitude of the induced current pulse at the point of penetration into the facility. Other collector configurations, such as those involving twisted or shielded conductors (i.e. signal lines or buried or conduit-encased power lines), are not expected to experience any greater degree of pickup than the overhead, grounded power line. The ground wire commonly associated with overhead power lines, the sheath surrounding armored cable, or the shields of signal cables are all expected to behave similarly under multiple grounding. Thus, the overhead power line with a ground wire was selected as the example on which the influence of supplemental ground connections on EMP pickup was evaluated.

An incremental section (Δx) of transmission line with a perfect ground return can be represented with the circuit diagram shown in Figure 7(a). In this figure, r represents the per unit series resistance, ℓ , the per unit series inductance, g , the per unit shunt conductance and, c , the per unit shunt capacitance. Even where the return is not perfect, i.e., actual earth, the equivalent circuit elements (principally series resistance with a shunt capacitance) can be integrated into these four parameters. However, with the addition of an intentional connection to earth, i.e., ground, the circuit diagram must be modified as shown in Figure 7(b). (Upon evaluation of the relative influence of the various transmission line parameters, it was concluded that the shunt conductance term, g could be deleted without a significant impact on the results.) A reasonable expectation for the equivalent circuit for the down lead and the earth electrode is that of an inductance in series with a parallel resistance and capacitance [3]. Experimental studies [4] have shown that the resistance and capacitance terms representing the earth connection are frequency dependent. This frequency dependency suggests a frequency domain approach as opposed to a time domain approach in spite of the time-limited nature of the incident field, i.e., the EMP. An analytical approach based upon conversion of the EMP waveform to a frequency domain representation, solving for the coupled currents and voltages in the frequency domain, and converting back to a time equivalent waveform was selected as






Figure 6. EMP coupling scenario.



(a) UNIFORM LINE SEGMENT



(b) LINE SEGMENT WITH EARTH CONNECTION

Figure 7. Per unit transmission line equivalent circuits.

the most direct. With this approach the transmission line was modeled in the presence of a lossy earth, grounded at various points, and excited by the incident electromagnetic field. This transmission line approach assumes that the TEM mode of propagation primarily determines the amount of current appearing at the end point of the line.

The time waveform and power spectrum for a representative EMP [36] are shown in Figure 8. Notice that frequency components extending into the microwave range are produced by the very fast rise and fall times of the pulse. Because of the exceedingly large bandwidth of the pulse spectrum, forward and inverse Fourier transforms can not be readily performed using a conventional Fast Fourier Transform (FFT). Consequently, an alternate technique, called Filon's method [5], for Fourier transforms was used. This method employs a piecewise linear approximation of the argument function in performing the transform. (For further details on this method, see Appendix A.) The technique was implemented and several test runs were performed to verify its validity for these analyses. The derivation and description of the External Collector Assessment Model (ECAM) which resulted from this approach is described in the following section.

2.2 MODEL DEVELOPMENT

The method for determining the time domain current at the termination of the transmission line when illuminated by an EMP, using the frequency domain transmission line model, may best be illustrated by considering the transmission line as an analogy to an ideal low pass filter, as illustrated in Figure 9. To find the impulse response of the filter, the Fourier transform of the input response is first obtained and multiplied by the filter frequency response, and then the result is inverse transformed to obtain the output time domain response of the filter. A similar approach is taken in the solution of the induced currents on the transmission line. The input time domain EMP field is transformed to the frequency domain using Filon's method, and the induced current on the transmission line is then computed for each given frequency. Finally, the composite of all the discrete frequencies are then inverse Fourier transformed back to the time domain, yielding the time domain representation of the induced current on the line.

The TEM mode formulation for multiconductor transmission lines in the presence of a lossy ground when illuminated by an incident field can be derived from Faraday's Law. If it is assumed that all conductors are perfectly conducting,




Figure 8. EMP time waveform and power spectrum representations.




Figure 9. Filter analogy of transmission line analysis problem.

(i.e., $r=0$) and that the axis of the line is parallel to the x-axis in the rectangular coordinate system, the transmission line equations for an N-conductor uniform line illuminated by an incident field become

$$\frac{\partial \underline{V}(x)}{\partial x} + \underline{Z}(\omega) \underline{I}(x) = \underline{V}_s(\hat{x}) \quad (1)$$

and

$$\frac{\partial \underline{I}(x)}{\partial x} + \underline{Y}(\omega) \underline{V}(x) = \underline{I}_s(\hat{x}) \quad (2)$$

(The derivation of these equations is given in Appendix B.) In Equations (1) and (2), $\underline{Z}(\omega)$ and $\underline{Y}(\omega)$ are impedance and admittance matrices, respectively, where the element of the i^{th} row and j^{th} column is denoted by $[\underline{Z}]_{ij}$. A vector is denoted by \underline{V} , where $[\underline{V}(x)]_i = V_i(x)$ and $V_i(x,t) = V_i(x)e^{j\omega t}$ are the complex valued potentials associated with the i^{th} conductor. The $\underline{Z}(\omega)$ and $\underline{Y}(\omega)$ matrices are symmetric per-unit-length impedance and admittance matrices, respectively, and can be decomposed into the following matrices:

$$\underline{Z}(\omega) = \underline{R}_e(\omega) + j\omega (\underline{L}_e(\omega) + \underline{L}) \quad (3)$$

$$\underline{Y}(\omega) = j\omega \underline{C} \quad (4)$$

where each matrix is real and symmetric. $\underline{R}_e(\omega)$ and $\underline{L}_e(\omega)$ represent the losses introduced by an imperfect (lossy) ground return. \underline{L} and \underline{C} are independent of frequency and are the per-unit-length external inductance and capacitance matrices, respectively, for a lossless homogeneous medium with perfect earth return and lossless conductors. The $\underline{R}_e(\omega)$ and $\underline{L}_e(\omega)$ terms are obtained using Carson's Formulas [6] as shown in Appendix C.

Finally, the terms $\underline{V}_s(x)$ and $\underline{I}_s(x)$ are the distributed sources along the line induced by the spectral components of the incident field and are given by:

$$[\underline{V}_s(x)]_i = j\omega\mu \int_0^{d_{io}} [\underline{H}_z^{\text{inc}}(y,x)]_i dy \quad (5)$$

$$[\underline{I}_s(x)]_i = -Y \int_0^{d_{io}} [\underline{E}_y^{\text{inc}}(y,x)]_i dy \quad (6)$$

The lumped circuit model describing the TEM mode of propagation for an incremental (Δx) section of any multiconductor line in a homogeneous medium is shown in Figure 10. Since the ungrounded line is uniform, all of the Δx length models of the line will be identical.

In Figure 10, the voltage and current at the input end of the Δx section of line are $\underline{V}_i(x)$ and $\underline{I}_i(x)$, respectively. The output voltage and current are represented by $\underline{V}_i(x + \Delta x)$ and $\underline{I}_i(x + \Delta x)$, respectively. The shunt capacitance terms c_{ij} , c_{ii} , c_{jj} , account for the mutual capacitance between the conductors and the ground, and the mutual inductances between conductors are denoted by ℓ_{ij} , ℓ_{jj} . The effects of the incident field are accounted for by the $\underline{V}_s(x)$ and $\underline{I}_s(x)$ terms, where they are distributed sources along the line induced by the incident field. The $\underline{Z}_{ci}(\omega)$ and $\underline{Z}_{cj}(\omega)$ terms represent the losses introduced by an imperfect earth return. The earth loss term, $\underline{Z}_e(\omega)$, can be written as

$$\underline{z}_e(\omega) = r_e(\omega) + j\omega\ell_e(\omega) \quad (7)$$

where $r_e(\omega)$ is the real part of the earth-correction term and $\ell_e(\omega)$ is the imaginary part.

All parameters are per-unit-length quantities. Therefore, the total value of each parameter for a Δx length model in Figure 10 is the per-unit-length value multiplied by the section length, Δx .




Figure 10. Equivalent circuit of a segment of a grounded multiconductor transmission line in an incident field.

The per-unit-length external inductance matrix for solid, round conductors can be approximated by

$$[L]_{ii} = \frac{\mu_o}{2\pi} \ln \left[\frac{2H_i}{r_{wi}} \right] \quad \text{H/m} \quad (8)$$

$$[L]_{ij} = \frac{\mu_o}{2\pi} \ln \left[\frac{(D_{ij}^2 + 4H_i H_j)^{1/2}}{D_{ij}} \right] \quad \text{H/m} \quad (9)$$

where D_{ij} is the center to center separation of the conductors, H_i is the height of the i^{th} conductor, and r_{wi} is the radius of the i^{th} conductor. It is well known for the case of a homogeneous, free space medium with perfect earth return and lossless conductors that

$$\underline{C} \underline{L} = \underline{L} \underline{C} = \mu_o \epsilon_o \underline{1}_n \quad (10)$$

thus the per-unit-length external capacitance matrix can be found by

$$\underline{C} = \mu_o \epsilon_o \underline{L}^{-1} \quad (11)$$

where the inverse of the matrix \underline{M} is denoted by \underline{M}^{-1} .

Equations (1) and (2) can be rewritten in matrix form as follows:

$$\begin{bmatrix} \frac{\partial \underline{V}(x)}{\partial x} \\ \frac{\partial \underline{I}(x)}{\partial x} \end{bmatrix} = \begin{bmatrix} \underline{0}_{n \times n} & \underline{Z} \\ \underline{Y} & \underline{0}_{n \times n} \end{bmatrix} \begin{bmatrix} \underline{V}(x) \\ \underline{I}(x) \end{bmatrix} + \begin{bmatrix} \underline{V}_s(x) \\ \underline{I}_s(x) \end{bmatrix} \quad (12)$$

where $\underline{0}_{n \times n}$ is a $n \times n$ matrix with zeros in every position.

The set of $2n$ first-order, complex-valued, ordinary differential equations in Equation (12) are in the form of state variable equations [7]. The solution to this equation which describes the TEM mode of propagation in the transmission line is

$$\begin{bmatrix} \underline{V}(x) \\ \underline{I}(x) \end{bmatrix} = \underline{\Phi}(x, x_0) \begin{bmatrix} \underline{V}(x_0) \\ \underline{I}(x_0) \end{bmatrix} + \int_{x_0}^x \underline{\Phi}(x, \hat{x}) \begin{bmatrix} \underline{V}_{-s}(\hat{x}) \\ \underline{I}_{-s}(\hat{x}) \end{bmatrix} d\hat{x} \quad (13)$$

where $\underline{\Phi}(x, x_0)$ is the $2n \times 2n$ complex-valued state transition matrix that is the solution to Equations (1) and (2) when $\underline{V}_{-s} = \underline{I}_{-s} = \underline{0}_n$ and x_0 is an arbitrary fixed point along the line. If the line is "abruptly nonuniform," i.e., consists of uniform subsections cascaded together, then Equation (11) for a cascade of N sections becomes

$$\begin{aligned} \begin{bmatrix} \underline{V}(x_N) \\ \underline{I}(x_N) \end{bmatrix} &= \left\{ \underline{\Phi}_N(x_N, x_{N-1}) \underline{\Phi}_{N-1}(x_{N-1}, x_{N-2}) \dots \underline{\Phi}_2(x_2, x_1) \underline{\Phi}_1(x_1, x_0) \right\} \begin{bmatrix} \underline{V}(x_0) \\ \underline{I}(x_0) \end{bmatrix} \\ &+ \sum_{i=1}^{N-1} \left\{ \underline{\Phi}_N(x_N, x_{N-1}) \underline{\Phi}_{N-1}(x_{N-1}, x_{N-2}) \dots \underline{\Phi}_{i+1}(x_{i+1}, x_i) \int_{x_{i-1}}^x \underline{\Phi}_i(x_i, \hat{x}) \right\} \begin{bmatrix} \underline{V}_{-si}(\hat{x}) \\ \underline{I}_{-si}(\hat{x}) \end{bmatrix} d\hat{x} \\ &+ \int_{x_{N-1}}^{x_N} \underline{\Phi}_N(x_N, \hat{x}) \begin{bmatrix} \underline{V}_{-sN}(\hat{x}) \\ \underline{I}_{-sN}(\hat{x}) \end{bmatrix} d\hat{x} \end{aligned} \quad (14)$$

where each uniform section between $x = x_i$ and x_{i-1} is described by

$$\begin{bmatrix} \underline{V}(x_i) \\ \underline{I}(x_i) \end{bmatrix} = \underline{\Phi}_i(x_i, x_{i-1}) \begin{bmatrix} \underline{V}(x_{i-1}) \\ \underline{I}(x_{i-1}) \end{bmatrix} + \int_{x_{i-1}}^{x_i} \underline{\Phi}_i(x_i, \hat{x}) \begin{bmatrix} \underline{V}_{-si}(\hat{x}) \\ \underline{I}_{-si}(\hat{x}) \end{bmatrix} d\hat{x} \quad (15)$$

and $\Phi(x_n, x_0)$ is the overall chain parameter matrix for the cascade of line sections between $x = x_0$ and $x = x_n$. Lumped-element networks at discrete points along the line can also be incorporated by writing their chain parameter matrices and properly placing them in Equation (14). The lumped network shown in Figure 11 was used to model the down conductor and ground rod for the reasons given earlier. This network was placed between two uniform sections of transmission line to model the grounding of the line at various points as shown in Figure 12.

For the line between grounds, the transmission line is uniform and the per-unit-length impedance $\underline{Z}(\omega)$ and admittance $\underline{Y}(\omega)$ matrices are independent x . In these regions, the state transition matrix, $\Phi(x_i, x_{i-1})$, can be shown to be a function of only one variable, the difference quantity $(x_i - x_{i-1})$ [7] and thus the chain parameter matrix may be denoted as $\Phi(x_i - x_{i-1})$. In order to evaluate Equation (14), and thereby solving Equations (1) and (2), the chain parameter matrix $\Phi(x_i - x_{i-1})$, must be determined for each uniform line section. For multi-conductor lines, Equations (1) and (2) are strongly coupled differential equations, and therefore $\Phi(x_i, x_{i-1})$ may be found in the following manner: Assume that $\underline{V}_s(x)$ and $\underline{I}_s(x)$ are both zero, then differentiate Equation (2) with respect to x and substitute into Equation (1) to produce the following second order differential equation:

$$\ddot{\underline{I}}(x) = \underline{Y} \underline{Z} \underline{I}(x) \quad (16)$$

A solution to Equation (16) may be obtained by a similarity transformation. The particular transform to be used is "modal decomposition" [8]. To use this technique, define a change of variable, $\underline{I}(x) = \underline{T} \underline{I}_m(x)$, where \underline{T} is a nonsingular, complex matrix and $\underline{I}_m(x)$ is a complex-valued vector of mode currents, and substitute into Equation (16) to obtain

$$\ddot{\underline{I}}_m(x) = \underline{T}^{-1} \underline{Y} \underline{Z} \underline{T} \underline{I}_m(x) \quad (17)$$

(The dots over the variable represent derivatives with respect to the variable in parentheses.)

$$L_w = \frac{\ell\mu}{2\pi} \ln\left(\frac{2\ell}{a}\right) \text{ H}$$

$$R_e = \frac{1}{2\pi\ell\sigma} \ln\left(\frac{2\ell}{a}\right) \Omega$$

$$C_e = \frac{2\pi\epsilon\ell}{\ln\left(\frac{2\ell}{a}\right)} \text{ F}$$




Figure 11. Equivalent circuit model of a ground rod and down conductor.




Figure 12. Grounded transmission line model segment.

Next, suppose that there exists a similarity transform, \underline{T} , that diagonalizes the matrix product $\underline{Y} \underline{Z}$, i.e.,

$$\underline{T}^{-1} \underline{Y} \underline{Z} \underline{T} = \underline{\gamma}^2 \quad (18)$$

where $\underline{\gamma}^2$ is a diagonal matrix. In this case, Equation (17) becomes a set of N uncoupled differential equations with solutions

$$\underline{I}(x) = \underline{T} \underline{I}_m(x) = \underline{T}(e^{-\underline{\gamma}x} \underline{I}^+ - e^{\underline{\gamma}x} \underline{I}^-) \quad (19)$$

where $e^{\underline{\gamma}x}$ is a diagonal matrix with

$$[e^{\underline{\gamma}x}]_{ii} = e^{\gamma_i x} \quad (20)$$

$$[e^{\underline{\gamma}x}]_{ij} = 0 \quad i \neq j \quad (21)$$

\underline{I}^+ and \underline{I}^- are vectors of complex undetermined constants. These constants will be determined by considering the termination networks of the ends of the line. Since from Equations (1) and (2), $I(x) = -Y V(x)$, the voltage may be determined by

$$\begin{aligned} \underline{V}(x) &= -\underline{Y}^{-1} \underline{I}(x) \\ &= \underline{Y}^{-1} \underline{T} \underline{\gamma} (e^{-\underline{\gamma}x} \underline{I}^+ + e^{\underline{\gamma}x} \underline{I}^-) \\ &= \underline{Y}^{-1} \underline{T} \underline{\gamma} \underline{T}^{-1} \{ \underline{T}(e^{-\underline{\gamma}x} \underline{I}^+ + e^{\underline{\gamma}x} \underline{I}^-) \} \\ &= \underline{Z} \underline{T} \underline{\gamma}^{-1} \underline{T}^{-1} \{ \underline{T}(e^{-\underline{\gamma}x} \underline{I}^+ + e^{\underline{\gamma}x} \underline{I}^-) \} \end{aligned} \quad (22)$$

where $\underline{\gamma}$ is a diagonal complex-valued matrix with

$$[\underline{\gamma}]_{ii} = \sqrt{\gamma_i^2} \quad (23)$$

$$[\underline{\gamma}]_{ij} = 0 \quad i \neq j \quad (24)$$

The state transition matrix or chain parameter matrix $\underline{\Phi}(x_i, x_{i-1})$ which relates voltages and currents at the two ends of a section of line, in Equation (15), can be obtained by eliminating \underline{I}^+ and \underline{I}^- from Equations (19) and (22), yielding

$$\begin{aligned} \begin{bmatrix} \underline{V}(x_i) \\ \underline{I}(x_i) \end{bmatrix} &= \underline{\Phi}(x_i, x_{i-1}) \begin{bmatrix} \underline{V}(x_{i-1}) \\ \underline{I}(x_{i-1}) \end{bmatrix} \\ &= \begin{bmatrix} \underline{\Phi}_{11}(x_i, x_{i-1}) & \underline{\Phi}_{12}(x_i, x_{i-1}) \\ \underline{\Phi}_{21}(x_i, x_{i-1}) & \underline{\Phi}_{22}(x_i, x_{i-1}) \end{bmatrix} \begin{bmatrix} \underline{V}(x_{i-1}) \\ \underline{I}(x_{i-1}) \end{bmatrix} \end{aligned} \quad (25)$$

where $\underline{\Phi}_{ij}(x_i, x_{i-1})$, $i, j = 1, 2$ are given by

$$\underline{\Phi}_{11}(x_i, x_{i-1}) = 1/2 \underline{Y}^{-1} \underline{T} (e^{\underline{\gamma}(x_i - x_{i-1})} + e^{-\underline{\gamma}(x_i - x_{i-1})}) \underline{T}^{-1} \underline{Y} \quad (26)$$

$$\underline{\Phi}_{12}(x_i, x_{i-1}) = -1/2 \underline{Y}^{-1} \underline{T} \underline{\gamma} (e^{\underline{\gamma}(x_i - x_{i-1})} - e^{-\underline{\gamma}(x_i - x_{i-1})}) \underline{T}^{-1} \quad (27)$$

$$\underline{\Phi}_{21}(x_i, x_{i-1}) = -1/2 \underline{T} (e^{\underline{\gamma}(x_i - x_{i-1})} - e^{-\underline{\gamma}(x_i - x_{i-1})}) \underline{\gamma}^{-1} \underline{T}^{-1} \underline{Y} \quad (28)$$

$$\underline{\Phi}_{22}(x_i, x_{i-1}) = 1/2 \underline{T} (e^{\underline{\gamma}(x_i - x_{i-1})} - e^{-\underline{\gamma}(x_i - x_{i-1})}) \underline{T}^{-1} \quad (29)$$

(The details on the similarity transform matrix \underline{T} which diagonalizes the matrix product $\underline{Y} \underline{Z}$ given in Equations (3) and (4) can be found in Appendix D). Using the chain parameter matrices in Equation (13) with the $\underline{\Phi}_{ij}$ defined in Equations (26) - (29), Equation (13) becomes

$$\begin{bmatrix} \underline{V}(L) \\ \underline{I}(L) \end{bmatrix} = \begin{bmatrix} \underline{\phi}_{11}(L) & \underline{\phi}_{12}(L) \\ \underline{\phi}_{21}(L) & \underline{\phi}_{22}(L) \end{bmatrix} \begin{bmatrix} \underline{V}(x_0) \\ \underline{I}(x_0) \end{bmatrix} + \int_0^L \begin{bmatrix} \underline{\phi}_{11}(L, \hat{x}) & \underline{\phi}_{12}(L, \hat{x}) \\ \underline{\phi}_{21}(L, \hat{x}) & \underline{\phi}_{22}(L, \hat{x}) \end{bmatrix} \begin{bmatrix} \underline{V}_s(\hat{x}) \\ \underline{I}_s(\hat{x}) \end{bmatrix} d\hat{x} \quad (30)$$

For multiconductor lines, the termination networks can be considered to be linear N-port networks and are characterizable by "Generalized Thevenin Equivalents" as

$$\underline{V}(0) = \underline{V}_0 - \underline{Z}_0 \underline{I}(0) \quad (31)$$

$$\underline{V}(L) = \underline{V}_L + \underline{Z}_L \underline{I}(L) \quad (32)$$

where \underline{V}_0 and \underline{V}_L are complex-valued vectors of equivalent open-circuit port excitation voltages and \underline{Z}_0 and \underline{Z}_L are complex-valued symmetric matrices which represent the termination network at the input and output of the line, respectively.

Expanding Equation (30) and substituting into Equations (31) and (32), the chain parameter matrix formulation incorporating the incident electromagnetic fields becomes the algorithm for the External Collector Assessment Model (ECAM):

$$\begin{aligned} & \left[\underline{Z}_L \underline{\phi}_{22}(L) - \underline{Z}_L \underline{\phi}_{21}(L) \underline{Z}_0 + \underline{\phi}_{11}(L) \underline{Z}_0 \right] \underline{I}(0) \\ & = \left[\underline{\phi}_{11}(L) - \underline{Z}_L \underline{\phi}_{21}(L) \right] \underline{V}(0) - \underline{\hat{V}}_s(L) - \underline{Z}_L \underline{\hat{I}}_s(L) \end{aligned} \quad (33)$$

$$\underline{I}(L) = \underline{\phi}_{21}(L) \underline{V}_0 + \left[\underline{\phi}_{22}(L) - \underline{\phi}_{21}(L) \underline{Z}_0 \right] \underline{I}(0) + \underline{\hat{I}}_s(L) \quad (34)$$

where

$$\hat{\underline{V}}_s(L) = \int_0^L \Phi_{11}(L, \hat{x}) \underline{V}_s(\hat{x}) + \Phi_{12}(L, \hat{x}) \underline{I}_s(\hat{x}) d\hat{x} \quad (35)$$

$$\hat{\underline{I}}_s(L) = \int_0^L \Phi_{21}(L, \hat{x}) \underline{V}_s(\hat{x}) + \Phi_{22}(L, \hat{x}) \underline{I}_s(\hat{x}) d\hat{x} \quad (36)$$


(See Appendix E for details on the calculation of $\hat{\underline{V}}_s(L)$ and $\hat{\underline{I}}_s(L)$).

To use ECAM to calculate the current at the output termination of a multiconductor transmission line excited by an incident field, first determine $\underline{I}(0)$ in Equation (33) and substitute into Equation (34) and solve for $\underline{I}(L)$. Thus, at each frequency given by Filon's decomposition of the EMP, the termination current may now be determined. Upon determination of these various currents, the time domain representation of the termination current is calculated by performing the inverse Fourier transform with Filon's method.


2.3 USE OF ECAM TO EVALUATE THE EFFECTS OF SUPPLEMENTAL GROUNDS ON EXTERNAL COLLECTORS

ECAM was programmed on a VAX 11/780 computer. (Special care was taken to check out each separate section of the program because no data existed against which program results could be compared.) Initial verification runs of the behavior of a transmission line over a perfect ground plane were promising in terms of the relative peak currents and the late time (trailing edge) response. Early time (leading edge) induced pulse shapes were incorrect, however. Subsequent refinement in the frequency-to-time domain conversion process yielded plausible pulse shapes. To illustrate, Figure 13 compares the time response produced by ECAM (upper graph) with those reported by others [9]. The results agree closely both in relative magnitudes and in general waveshape.

Several test cases were run and the results examined. Figure 14(a) shows the computed current response of a 50 m line over a perfectly conducting ground plane short circuited at both ends, while Figure 14(b) shows the response of the same line over a lossy ground plane. It can be seen from these two figures that the current induced in the line is greater over a lossy ground plane than over a perfect ground plane; this effect can be attributed to the influence of reflections from the imperfect ground plane.




(a) ECAM RESULTS.




(b) MARABLE, et al., RESULTS.

Figure 13. Comparative results of computed induced currents for an infinitely long wire, 10 meters high.



(a) OVER PERFECT GROUND



(b) OVER LOSSY GROUND

Figure 14. Computed EMP current response of a 50 meter line short circuited at both ends.


Figure 15(a) shows the response of a 50 m line over a lossy ground with a short circuit at the output and a 100 ohm input, while Figure 15(b) shows the same line with an additional ground point at the center. For this case, the additional ground has no effect on the induced current pulse amplitude and only slightly alters the pulse shape.

Figures 16(a) and 16(b) compare the responses of a 10 m long line with that of a 500 m line, both over lossy ground with 100 ohms input impedance and short circuited at the output. It can be seen that a slight increase in pulse current amplitude does occur in going from 10 m to 500 m in length.


Next, the peak amplitudes of the induced currents were determined for several conditions of line length, height above ground, and number of grounding points. For each condition examined, line parameters of wire radius, input impedance and output impedance were maintained constant at 200 mils, 100 ohms and 500 ohms, respectively. Figure 17 shows the behavior of peak pulse amplitude as a function of transmission line length. (For this series of calculations, no ground connections were assumed.) Note that for this particular case of a 10 meter high line over a lossy ground the peak current increases rapidly with length up to about 50 meters. (Figure 18 shows the detailed behavior below 50 m.) Beyond 50 m (and up to 1000 m), the peak current remains in the vicinity of 1200 A except for an additional rise of 300A at approximately 500 m. (This "peak" is probably related to a pseudo-resonant length of the transmission line.)

Figure 19(a) shows the impact of a number of ground points equally spaced over a 50 meter length of line at various line heights from 1 meter to 15 meters. It can be observed from this figure that the effects of supplemental grounds are more pronounced as the height of the line above the earth increases. Figure 19(b) details the effects on peak induced current from increasing the number of grounding points on the 50 m long, 10 m high line. A reduction in peak current of approximately 2:1 is achieved in going from 0 grounds to 50 grounds.

Figure 20 shows the influence of a fixed number of grounding points evenly distributed over varying lengths of lines. The behavior of the 10 meter long line (height also equal to 10 meters) implies that grounding points 1 meter apart (10 meters long divided by 10 grounding points) may be required to make a noticeable impact on the amplitude of the EMP-induced current. Specifically, Figure 21 shows the behavior of the induced peak current with various numbers of grounds uniformly distributed over a 50 meter length. Notice that 50 grounds 1 meter apart produce a 53 percent reduction in the peak current amplitude induced on the line with 5




(a) NO SUPPLEMENTAL GROUND




(b) ONE GROUND CONNECTION AT CENTER

Figure 15. Computed EMP current response of a 50 meter line over lossy ground (line input terminated in 100 ohms and output short circuited).



(a) 10 METERS LONG



(b) 500 METERS LONG

Figure 16. Computed EMP current response of two lengths of line over lossy ground (line input terminated in 100 ohms and output short circuited).




Figure 17. Peak EMP-induced current as a function of line length (no supplemental grounds).




Figure 18. Details of 0-50 meter portion of Figure 17.




Figure 19. Peak EMP-induced current as a function of number of supplemental grounds on a 50 meter line.




Figure 20. Peak EMP-induced current as a function of number of supplemental grounds for various lengths of transmission line.




Figure 21. Peak EMP-induced current as a function of uniformly distributed grounds.

grounds 10 meters apart. Figure 22 extends this evaluation to consider the effects of realistically separated grounding points on longer lines. Ground connections separated by 10 meters and 20 meters over a 350 meter length and a 500 meter length, respectively, are compared in this figure. Note that the differences in the peak induced current levels are less than 10 percent for lengths greater than 50 meters.

These results imply that control of the EMP-related current on external collectors at the facility penetration point is most receptive to the installation of supplemental grounds within the first 50 meter portion of the line adjacent to the facility. They suggest that the penetrations of long, overhead collectors (power lines, signal lines, etc.,) should be handled in the manner illustrated in Figures 23 and 24. Figure 23 shows the implied manner of treating a power line penetration. The essential features of this method are:

- o The physical entrance point is located some 30 to 50 m from the main facility.
- o The power transformer is enclosed in a solid metal shield (which could be the intrinsic housing).
- o Power conductor routing from the transformer to the facility is inside buried solid metal conduit/pipe. Intimate contact between the conduit and the soil should be maintained throughout its length. The facility's shielding boundary is continued to the remote entrance point via the metallic conduit and transformer enclosure.
- o A low impedance ground (preferably a grid or counterpoise) should be provided for the transformer.
- o The cable conduit should be well bonded to the transformer and building grounding networks.
- o Surge arrestors appropriate for lightning and EMP should be provided on the primary and secondary sides of the transformer.

Figure 24 shows a similar treatment for signal line entrances. Installation principles are the same as for power line penetrations. Effective lightning and EMP protection including surge arrestors along with inductive and capacitive filters must be applied to each collector.

In summary, the preliminary results of the external EMP collector analysis effort indicate that:

- (1) A direct relationship between induced current amplitude and line length holds only up to lengths of 50 m or so. Beyond 50 m, only secondary relationships with length were observed.




Figure 22. Peak EMP-induced current versus line length for uniformly spaced supplemental grounds.




Figure 23. Candidate power line penetration treatment.




Figure 24. Candidate signal line penetration treatment.

- (2) Except possibly for short line lengths, multiple grounds exhibit only a secondary influence on the level of EMP pickup by overhead power lines.
- (3) Remote locations of external collector penetrations into a protected facility may be desirable.

III. INTERNAL COLLECTOR INVESTIGATION

3.1 INTRODUCTION

Protection against failure due to EMP-induced currents only on external collectors leading into the structure may not be sufficient. The building itself, with its internal wiring, can also act as a collector of EMP-induced currents. These currents can inductively couple to sensitive equipment with sufficient magnitude to lead to failure or upset. Indeed, the internally-produced currents could (a) be of much greater magnitude than those induced externally so that the external sources are of lesser significance, (b) be of such magnitude that the total effect of the external and internal collectors must be considered, or (c) be of insignificant magnitude.

The EMP pickup of internal collectors versus that of external collectors was addressed because extensive efforts may be applied to the formulation and implementation of hardening measures for external collectors only to find that the levels of EMP-related energy appearing at equipment terminals from pickup by internal collectors are greater than those from external collectors, even without hardening. The relative severity of the EMP threat from external collectors versus that from internal collectors is of particular concern to many types of facilities. Those types of facilities that do not normally incorporate an intrinsic metal shield as part of their construction pose a unique challenge. This is not to say that the typical "unshielded" structures provide no protection whatsoever. In fact, considerable experience exists to show that normal commercial/industrial buildings do attenuate those radio frequency signals which fall within the EMP spectrum. Thus, even without the presence of a solid metal shield, internal collectors in most facilities can expect to enjoy some protection from an EMP. Unfortunately, the extent of this protection cannot yet be quantified. Such quantification is necessary for effective utilization of the "zonal" approach to hardening [10], [11]. Zonal hardening depends upon certain degrees of protection being assignable to particular barriers. Thus, two major reasons for seeking to gain a greater understanding of the EMP response of internal collectors are:

- (1) To examine the relative pickup between internal and external collectors in order to see where suppression emphasis needs to be placed, and
- (2) To quantify the relative protection offered by the intrinsic facility.

For these reasons, a preliminary investigation into the problem of EMP coupling to internal collectors was conducted. This investigation employed both an analytical effort and an experimental effort. The analytical effort sought to evaluate the EMP response of a straight conductor inside a simplified array^{*} of conductors with the aid of an existing computer model based on the method of moments technique. The experimental effort focused on measuring the shielding effectiveness of two available structures at selected frequencies within the EMP spectrum.

3.2 ANALYTICAL ASSESSMENT OF INTERNAL COLLECTOR COUPLING

A search of the literature produced two computer models seemingly applicable to the analysis of EMP coupling to internal collectors. These two models are:

- (1) Time Domain Electromagnetic Response of Thin Wire Structures (TWTD) [12], and
- (2) Three Dimensional EMP Time-Domain Finite Difference Code (THREDE) [13]

The first of these was chosen for use because it had been reportedly applied to the analysis of large structures [12], was readily obtainable, and was compatible with available computers (a DEC VAX 11/780 and a CDC CYBER 74). As described in the reference, TWTD utilizes a Gaussian waveform. Thus, the first step in the implementation of the model was to modify it to accept an incident EMP waveform defined as a four-term exponential (see Equation (A-8) in Appendix A). The next steps were to implement the model on the VAX 11/780 computer and to design a series of test cases for evaluation.

The test cases are shown in Figure 25. The representation of a collector inside a facility is that of a single wire inside a wire mesh cage. This internal wire is not physically connected to any other part of the mesh. The number of

*Any mathematical model of field penetration into structures must necessarily represent a simplified version of what is otherwise a very complicated problem. Because of the complexity and variation of the internal structure of buildings, it is extremely difficult to develop an all-encompassing mathematical theory that accounts for all circumstances. However, the approach taken assumed that the fundamental collector properties of such structures could be analyzed.




Figure 25. Test cases for the analysis of internal collectors.

wires forming the mesh can be increased or decreased so that different levels of shielding can be examined. The shielding effectiveness of the mesh is determined by comparing the magnitude of current induced on the internal wire to the current induced on the same wire with no mesh present.

For verification of the modified TWTD code, an initial experiment was designed to determine the current induced on a single wire with no wire mesh present. A wire, 1.5 m in length, and 0.0029 m in radius, was illuminated by the EMP polarized in the direction of the wire. The wire was divided into 40 zones and the 20th and 21st zones were loaded with 50Ω resistances. The resulting induced current is given in Figure 26. The damped oscillating current is an expected result.

The practical limitation to the size of a structure that can be analyzed with TWTD is determined by the highest frequency component of the EMP for which meaningful data is desired. To use the code, the user must supply a time sampling increment, Δt , which is determined by this highest frequency component. The sampling criterion imposed by the code is that there be approximately 12 samples/cycle at the highest frequency. An initial estimate for Δt was based upon the assumption that EMP spectral components more than 90 dB down from the peak should contribute negligibly to the induced current. From Figure 8, it can be seen that all components above 667 MHz fall in this category. Thus, 667 MHz was selected as the highest frequency of interest. Applying the 12 sample/cycle requirement produces a Δt of 1.25×10^{-10} seconds. (The response of Figure 26 resulted from utilizing $\Delta t = 1.25 \times 10^{-10}$ sec.)

For more complex structures, however, small time increments incur unacceptably large computer memory and run time requirements. Therefore, an ability to use large time increments was considered highly desirable. Unfortunately, upon examination of preliminary results with large time increments, it was found that as Δt was increased to 5×10^{-10} seconds (representing a highest frequency component of 167 MHz) the EMP-induced current exhibited unbounded oscillations as time increased (a condition obviously not possible with a time-limited input). Consequently, all of the test cases were evaluated with $\Delta t = 1.25 \times 10^{-10}$ seconds.

Such a small value of Δt places a severe limitation on the size of a structure that is practical to run with TWTD. In fact, it is necessary that $D \leq c\Delta t$, where D is the longest zone in any zoning scheme of the structure, and c is the speed of light in a vacuum. For $\Delta t = 1.25 \times 10^{-10}$ seconds, $D \leq .0375$ m. Thus, a single wire 1 m long requires approximately 27 zones. (It is evident that a typical structure





Figure 26. Calculated current response of a 1.5 m internal collector.

of realistic dimensions and complexity will require an extensive amount of computer time and memory.)

For these reasons, only the analysis of structures of small dimension was attempted. The dimensions of the wire cage of the test cases were chosen to be 0.2 m x 0.1 m x 0.05 m in length, width and height, respectively, with an internal wire of length 0.05 m centered vertically inside the cage. The wire radius was 0.0003 m. The incident EMP was assumed vertically polarized parallel to the internal collector. Each 0.1 m section of wire in the cage was divided into three zones. The 0.05 m and 0.025 m sections were divided into two zones and one zone, respectively.

The computed responses of the 0.05 m "internal collector" are shown in Figure 27 for the one unshielded and two shielded cases. Notice that the early time responses of the induced currents are well behaved. In all three cases, however, oscillations begin around the 30th time step, or around 3.75 nanoseconds.

Since the preliminary results of Figure 26 had indicated that the resulting currents seemed to be more stable with longer wire lengths, it was decided to test a larger structure. For this test, a 0.5 m x 0.5 m x 0.5 m cage with a vertically centered 0.5 m wire was run. Again, the EMP was vertically polarized. Each 0.5 m segment was divided into 14 zones. The results, compared to an unshielded wire of the same length, are given in Figure 28. Computer memory space limited the number of time steps to 58, but the results do show decaying oscillatory behavior. The initial peak currents occur at about 2.5 nanoseconds, and the shielded wire shows an attenuation in the peak current level of 1.68 dB with respect to the unshielded wire.

These results indicate that more work is necessary in order to make TWTD a useful tool for EMP analysis of internal collectors. Indeed, the severe limitation placed on the size of structures that can be analyzed with TWTD may limit its usefulness. Also, these results indicate that convergence criteria for the modified (four-term exponential) TWTD code have not been fully characterized. These criteria may well be different than those described for the unmodified code. The usefulness of TWTD for analyzing EMP coupling to internal collectors will depend on the upper limit of the structural size capability of the program and the severity of the conditions necessary for convergence.




Figure 27. Calculated current response of 0.05 m internal collector for three different shielding conditions.




Figure 28. Calculated (center zone) current response of a shielded versus an unshielded 0.5 m conductor.

3.3 EXPERIMENTAL INVESTIGATION OF STRUCTURAL SHIELDING AT EMP FREQUENCIES

The degree of coupling to an internal collector will be influenced by the shielding effectiveness of the surrounding structure. To obtain an estimate of this influence, measurements of the attenuation of EM fields into two buildings were performed in order to see if any insight could be gained into the shielding properties of "typical" structures over a frequency range representative of the EMP power spectrum. The field strengths of locally available commercial broadcast sources from 0.59 MHz to 660 MHz were measured externally to the structures and at selected locations within. These measurements were made in two buildings located on the Georgia Tech campus. Each building is of steel and masonry (brick veneer over concrete blocks) construction. Building No. 1 consists of three floors, while Building No. 2 contains four floors. (See Figure 29 for generalized layouts and for relative locations of the radiating sources.)

For each building, reference field levels were measured on the roof for each selected emitter. (The reference levels were taken as the average at two roof locations.) Then, at various interior locations on each floor, the field strength levels of each emitter were again measured. Identical antennas were used in each case and signal substitution methods using calibrated signal sources were employed to indicate the relative signal levels at each frequency. At each location, the pickup antenna was rotated until a maximum signal level was obtained. The difference between the field level measured on the roof and at an interior location was defined as the relative shielding effectiveness of the structure at that point.

Interior test sites were distributed around the periphery of the buildings approximately 5 to 6 meters from the outside wall. Also, a location near the center of each building was chosen for measurement. In this way, knowing the direction of the transmitter, the effects on attenuation of the field of longer path lengths through the building could be observed.

The data from the measurements are presented in Tables 1 and 2. In all cases the data are given as the attenuation (in dB) observed at the location nearest the source (N), at a central location (C), and at a point farthest from the source (F). The data indicate that the greatest attenuation is, in general, on the ground floor and decreases on the higher floors. This characteristic appears to hold throughout the range of frequencies measured. This result is in agreement with Rice [14], whose measurements at 35 and 150 MHz found the greatest attenuation on the lowest level. Rice also found overall average local losses for 11 buildings in New York

Table 1. Signal Attenuation in dB as Measured at Selected Locations in Building No. 1.

| Source | | Location [*] | | | | | | | | | |
|--------------|------------|-----------------------|------|------|------|------|------|------|------|------|------|
| Freq. MHz | Identifier | R ^{**} | GN | GC | GF | 1N | 1C | 1F | 2N | 2C | 2F |
| .59 | WPLO | 70 | 34 | 49 | - | 12.5 | 42 | 31 | 14 | 25 | 24 |
| .86 | WAEC | 63.5 | 45.5 | 45.4 | 36.5 | 25.5 | 37.5 | 19.5 | 9.5 | 23.5 | 19.5 |
| 1.33 | WIGO | 66 | 38 | 43 | 27 | 15 | 40 | 33 | 14 | 26 | 20 |
| 32.6 | --- | 50.5 | - | 37.5 | - | - | 38.5 | - | - | 29.5 | - |
| 55 | CH 2 | 34.5 | 32.5 | 41.5 | 23.5 | 9.5 | 19.5 | 32.5 | 2.5 | 17.5 | 2.5 |
| 77 | CH 5 | 25.5 | 33.5 | 48.5 | 22.5 | 20.5 | 45.5 | 30.5 | 17.5 | 28.5 | 19.5 |
| 91 | WREK | 11 | 36 | 30 | 25 | 20 | 19 | 37 | 22 | 13 | 18 |
| 98 | WSB | 29.5 | 22.5 | 32.5 | - | 13.5 | 18.5 | 12.5 | 19.5 | 13.5 | 9.5 |
| 162 | WEATHER | 39 | - | 31 | - | - | 22 | - | - | 16 | - |
| 198 | CH 11 | 32 | 28 | 26 | 26 | 12 | 23 | 18 | 3 | 12 | 14 |
| 485 | CH 17 | 16.5 | 30.5 | 28.5 | - | 26.5 | 28.5 | 33.5 | 18.5 | 18.5 | 26.5 |
| 660 | CH 46 | 38.5 | 34.5 | 39.5 | - | 9.5 | 24.5 | 34.5 | 14.5 | 28.5 | 18.5 |

*G, 1 and 2 refer to ground, first and second floor. N, C, and F refer to the location nearest, central and farthest from the source. Locations N and F are always on the periphery.

**The value R is the field strength taken on the roof as a reference level.

Table 2. Signal Attenuation in dB as Measured at Selected Locations in Building No. 2.

| Source | | Location* | | | | | | | | | | | | |
|----------------|------------|-----------|----|----|----|----|----|----|----|----|----|----|----|----|
| Freq. (MHz) | Identifier | R** | GN | GC | GF | 1N | 1C | 1F | 2N | 2C | 2F | 3N | 3C | 3F |
| .59 | WPLO | 68 | 37 | 62 | - | 24 | 53 | 25 | 19 | 47 | 22 | 19 | 32 | 19 |
| .86 | WABC | 62 | 25 | 44 | - | 17 | 48 | 21 | 18 | 47 | 19 | 11 | 30 | 22 |
| 1.34 | WIGO | 66 | - | 54 | 21 | 22 | 54 | 23 | 28 | 44 | 21 | 33 | 30 | 14 |
| 32.6 | - | 39 | - | 38 | - | - | 31 | - | - | 34 | - | - | 29 | - |
| 55 | CH 2 | 20 | 45 | 42 | 50 | 28 | 30 | 30 | 34 | 23 | 19 | 19 | 20 | 25 |
| 77 | CH 5 | 27 | 31 | 32 | 49 | 10 | 30 | 9 | 0 | 25 | 12 | -3 | 24 | 8 |
| 91 | WREK | 10 | 27 | 28 | 51 | 10 | 21 | 26 | -2 | 17 | 34 | 5 | 16 | 20 |
| 98 | WSB | 22 | 34 | 32 | 36 | 13 | 26 | 19 | 12 | 23 | 27 | 5 | 15 | 17 |
| 162 | WEATHER | 33 | - | 26 | - | - | 36 | - | - | 26 | - | - | 17 | - |
| 198 | CH 11 | 30 | 24 | 28 | 35 | 10 | 20 | 18 | -2 | 12 | 18 | 4 | 11 | 11 |
| 485 | CH 17 | 14 | 40 | 43 | 50 | 24 | 40 | 32 | 13 | 26 | 35 | 21 | 21 | 37 |
| 660 | CH 46 | 36 | 40 | 40 | 39 | 25 | 29 | 23 | 11 | 27 | 21 | 20 | 23 | 14 |

*G, 1 and 2 refer to ground, first and second floor. N, C and F refer to the location nearest, central and from the source. Locations N and F are always on the periphery.

**The value R is the field strength taken on the roof as a reference level.





Figure 29. Relative source locations for structural shielding effectiveness measurements.

City to be about 20 dB at 150 MHz and 25 dB at 35 MHz. Local loss means that the signal strength (in dB) measured on the main street level floor of the building as compared to the signal strength in the street adjacent to the building.) The first floor (street level) overall averages for the two buildings measured were about 35 dB at 32.6 MHz and 20 dB at 162 MHz. It must be remembered that the data of Tables 1 and 2 are relative to the signal strength recorded on the roofs of the buildings.

From Figure 29, the relative path lengths that the signal must travel to reach the measuring point inside the building can be noted. Specifically, Figure 30 shows the attenuation at all frequencies as the measuring point is moved around the periphery of the first floor of the building (see Building No. 1 floor plan, Figure 31, for exact locations of measurement points). For some of these locations, the attenuation dependence on path length is clear. For instance, at 55 MHz (whose source lies to the southeast), the attenuation should be least at Position 3, intermediate at Position 5 and greatest at Position 1. Attenuation at these locations is 9.5, 19.5, and 32.5 dB, respectively. At frequencies of 485 MHz and 660 MHz, more attenuation with longer path length is noted. With the exception of 91 MHz^{*}, every measurement shows greater attenuation of the signal at the center of the building than at the periphery. However, at 6 frequencies (0.59, 0.86, 1.33, 77, 98, and 198 MHz), the longest path length shows a lower attenuation than the center. Of course, in an urban environment, multiple reflections of the signal by nearby objects could account for low attenuation at any peripheral location.

In Figure 32, the comparison between the attenuation on the first floor at the central location of Building No. 1 and Building No. 2 is presented. In general, the attenuation is greater for Building No. 2. (The solid lines of Figure 32 represent the best fit curve from linear regression.) Note that differences are evident in the shielding effectiveness of the two buildings. The only significant physical differences between the two structures are their sizes (Building No. 1, 76 m x 33 m; Building No. 2, 58 m x 30 m') and their orientations (see Figure 29). The two buildings are approximately 122 m apart.

In Figure 33, the attenuation in the central location in Building No. 1 is given for various floors. The solid lines (linear regression fit) indicates that the attenuation, in general, is greatest on the ground floor, intermediate on the first floor, and lest on the second floor. (This trend is in agreement with that published by Rice.) In particular, note that, over the frequencies containing most

*The 91 MHz source is the campus radio station located close by.







Figure 30. Measured shielding effectiveness at selected locations in Building No. 1. (Cont'd.)




Figure 30 (Cont'd.) Measured shielding effectiveness at selected locations in Building No. 1.




Figure 31. Floor plan of Building No. 1 showing relative locations for measurements shown on Figure 30.




Figure 32. Comparison of shielding effectiveness properties of the two measured buildings.




Figure 33. Shielding effectiveness versus floor level for Building No. 1.

of the energy of an EMP (<100 MHz), a general attenuation of from 20 to 40 dB is offered by this "typical" structure.

It is postulated that, with adequate data of the above described type, structures can be considered as generalized filtering functions which can be used to operate on an incident EMP to evaluate the relative pickup by internal conductors. Because of the heterogeneous nature of typical structures, a statistical description of shielding effectiveness is perhaps the only meaningful approach. The data gathered to date is not sufficient for statistical analyses, however. Additional measurements of these kinds are therefore suggested.

IV. EARTH ELECTRODES FOR EMP GROUNDING

4.1 INTRODUCTION

As an adjunct to the collector assessment study, an investigation was conducted into the properties of earth electrode systems over a frequency range covering a major portion of the EMP power spectrum (see Figure 8). Since this power spectrum extends well into the UHF region, conventional low frequency (less than 100 Hz) measurement techniques are not adequate to describe the electrode system's response to an EMP. Therefore, initial emphasis was placed on the development of a measurement technique that could be used to both (1) assess the performance of a given electrode and (2) conduct a site survey to determine the best location for electrodes. Then the technique was used to evaluate the performance of various common electrode configurations.

The response of an earth electrode to an EMP is determined by the properties of the soil and the electrical characteristics of the particular geometrical configuration [15]. Thus, the first step in establishing an adequate ground is to determine the dielectric properties (conductivity, permittivity, and permeability) of the soil. (This step is important because it dictates the geometrical configuration (i.e., number of ground rods, method of interconnection, etc.) required to establish a good ground in a given area.)

Historically, soil parameter identification started with a laboratory analysis of soil samples and then moved to sophisticated on-site analyses of the soils and underlying strata at the planned location. Recent advances in on-site techniques have been made (see Appendix F for a detailed discussion of various techniques, both recent and traditional). One of these, the Resonant Linear Antenna Method [16] appears to be the most suitable for EMP grounding studies. (The method is accurate over a broad frequency range, is easily transportable, and is generally in use by geophysicists for geological surveying.) From the input admittance and the geometry of a probe antenna, the soil parameters can be calculated. This method requires only a resonant monopole antenna, a signal source covering the desired frequency range, and a display device complete with necessary coaxial voltage and current probes. An adaption of this technique was employed to examine the behavior of selected earth electrodes up to frequencies reflective of fast risetime responses applicable to EMP waveforms. Traditionally, the grounding of power circuits (25-60 Hz) [17] and grounding for lightning protection (impulse)

[18], [19], [20] was the primary concern for structures and power lines. Thus, many studies were performed to determine the volt-ampere characteristics of a driven ground rod using direct current or low frequency (< 100 Hz) alternating current instruments to determine power frequency properties [21], [22]. Impulse generators were used to determine the response to lightning strokes [23]. The typical impulse generator was capable of producing 50 kilovolts and 800 amperes. From these tests, a resistive, inductive and capacitive (RLC) model of a ground rod was developed [24] (Figure 34) that reflected the geometry of the rod, the soil parameters [25], and the climatic conditions at the time of the test [26], [27].

The rise time of the typical EMP is much faster than the rise time of a lightning pulse, however. Thus, a new technique for measuring ground electrode impedances was necessary. After careful consideration of existing instrumentation capabilities and upon evaluation of the EMP power spectrum, it was determined that a technique capable of displaying the response of an electrode system up to 500 MHz would be appropriate. To cover the entire frequency range from DC up to 500 MHz, three different measurement techniques must be used. The three frequency ranges covered by each are: (1) low (DC to 100 Hertz), (2) medium (100 Hertz to 500 kilohertz), and (3) high (500 kilohertz to 500 megahertz). The design and construction of a standardized test probe along with a description of the test techniques for these three frequency regions are discussed in the next sections.

4.2 STANDARD TEST PROBE

For the standardized test probe, a rod of 1.25 cm (0.5 inches) in diameter and 81 cm (32 inches) in length was chosen. (Brass was used although steel, copper, or any other metal of sufficient strength is adequate.) This length is long enough to provide effective soil contact but not so long as to require extensive work to place the rod in the ground.

An adapter was then constructed to interface the ground rod to the test instruments (see Figures 35 and 36). The adapter consists of a tapered coaxial line transition with a male type N connector on the top. The taper maintains 50 ohms impedance down to the point of attachment to the rod. (The impedance characteristics of the connector from 0.5 to 500 megahertz are shown in Figure 37.) The adapter is fastened to the ground rod via a threaded connection.




Figure 34. Ground rod model.




Figure 35. Standard test probe details.




Figure 36. Photograph of standard test probe.




Figure 37. Connector input impedance.

4.2.1 High Frequency Measurements

The high frequency impedance characteristics of the test probe were measured with the aid of a General Radio 1710 RF Network Analyzer. The analyzer was connected to the type N connector as shown in Figure 35, calibrated (Figure 38), and an impedance plot of the probe in earth was photographed (see Figure 39). It is noted that there is a great deal of ringing associated with both the magnitude and phase of the rod impedance. The ringing is due to the non-uniform imaging of the rod with the soil, the inductance and capacitance of the test leads to earth, and the standing waves at the surface [28]. By increasing the reference plane area of the probe, the standing waves and reflections were reduced, yielding a more acceptable plot of the ground rod impedance. The reference plane area was increased by attaching auxiliary grounds and an aluminum plate to the test connector shield (see Figure 40). A series of plots, Figures 41 to 46, were taken with different auxiliary grounds. The figures reveal that the rod impedance ringing decreased and displayed an overall capacitive nature at high frequencies as expected. These results indicated that this approach can be used to determine the impedance of the reference probe up to frequencies of 500 MHz. From this impedance characteristic, determination of the equivalent circuit of the probe can be made [29].

A computer run was made to calculate the input impedance of the equivalent circuit (Figure 34) with the test rod geometry and soil conditions of the particular test area. The input impedance of the ground rod equivalent circuit is given by:

$$Z = \frac{Z_L Z_C}{Z_L + Z_C} \quad (37)$$

where

$$Z_L = R + j\omega L$$

$$Z_C = \frac{1}{j\omega C}$$

$$R = \frac{\rho}{2\pi\ell} \ln \left(\frac{2\ell}{a} \right) \text{ ohms}$$

$$L = 2\ell \ln \left(\frac{2\ell}{a} \right) 10^{-7} \text{ H}$$

$$C = \frac{\epsilon_r \ell}{2\ell \ln \left(\frac{2\ell}{a} \right)} \frac{10^{-9}}{9} \text{ F}$$

ℓ = length of rod

a = radius of rod

$\rho = 97.67 \text{ } \Omega \text{ m}$

$10 \leq \epsilon_r \leq 13$




Figure 38. Connector output impedance for calibrated 100 ohm load.




Figure 39. Simple ground rod impedance.




Figure 40. Test setup for high frequency measurements.




Figure 41. Impedance of ground rod and one auxiliary ground.




Figure 42. Impedance of ground rod and two auxiliary grounds.




Figure 43. Impedance of ground rod and three auxiliary grounds.




Figure 44. Impedance of ground rod and four auxiliary grounds.




Figure 45. Impedance of ground rod, four auxiliary grounds, and an aluminum ground plate.




Figure 46. Impedance of ground rod, four auxiliary grounds, and a buried aluminum ground plate.

A graph of the results is shown on Figure 47. For this second order system, the resonant frequency is approximately 15 megahertz. The response of the final test configuration (Figure 46) reveals a resonance around 8 to 9 megahertz with ringing from 100 to 500 megahertz.

4.2.2 Low Frequency Measurements

The impedance of an earth electrode at low frequencies is dominated by the properties of the soil. Analytically the resistance of a ground rod can be determined if the soil resistivity, ρ , and the rod geometry are known, i.e.,

$$R = \frac{\rho}{2\ell} \ln \frac{2\ell}{a} \text{ ohm} \quad (38)$$

where ℓ = length of the rod and a = its radius.

Experimentally the ground rod resistance was accurately measured by the Fall-of-Potential Method (see Figure 48) [30]. This is a simple voltage drop measurement relating the current injected to the resistance of the probe (ground rod). (The injected current usually has a frequency of 70 to 100 hertz so as not to be confused with stray 60 hertz ground currents.) The ground probe resistance was found by recording the resistance on a Biddle Meggar-Earth Tester^{*} as distance, d (distance between the ground rod and probe C_2), was varied. The potential probe, P_2 , must be placed 62% of d , between the ground rod and probe C_2 . By using this method a plot was made of ground rod resistance versus separation distance, d (see Figure 49). From this graph the test ground rod resistance was determined to be 107 ohms.

The four probe technique can also be used to find soil resistivity, ρ . The resistivity of the soil at the test site was measured using the test setup shown in Figure 50.

It was determined to be 97.67 ohm-meter. With this resistivity, the resistance of the ground rod should be 98.6 ohms, which is within 10% of the Fall-of-Potential Method. (This result is considered to represent reasonable accuracy, given the high degree of dependence of the tests on environmental conditions.)

* James G. Biddle Co., Plymouth Meeting, PA 19462




Figure 47. Computer simulation of impedance of ground electrode model.




Figure 48. Test setup for low frequency measurements.




Figure 49. Test probe resistance characteristic.




Figure 50. Soil resistivity measurement setup.

4.2.3 Mid-Frequency Measurements

The mid-frequency range, 100 hertz to 500 kilohertz, impedance measurement proved to be the most difficult to obtain because of instrumentation limitations. Most off-the-shelf impedance measuring devices require that the object of the test not be grounded. (Specifically the HP 4800A Vector Impedance Meter has "DO NOT GROUND" printed under the input terminals.) Therefore, measuring the impedance of a grounded rod proved impossible with this type of instrument.

An approach was developed which relied strictly on network theory and the fact that the magnitude of the impedance is equal to the ratio of the magnitude of the voltage across and the current through the rod. Several attempts were made to obtain a suitable measurement. Since most oscilloscopes use "ground" as a reference and have a high impedance input, there was no problem with making voltage measurements on the source end of the ground rod. A problem arose in trying to measure the current into the ground rod, however. The first try was to measure the voltage drop across a one ohm resistor in series with the ground rod. Problems were encountered when the oscilloscope probe shield was connected to the terminal of the resistor thereby adding another "ground" to the circuit. Attempts were made to isolate the oscilloscope from ground, but this only served to increase the noise in the measurement. Obviously, a method of measuring the current was needed which would provide isolation from ground and provide noise reduction.

An HP current probe and amplifier provided just such a solution (see Figure 51). This test setup worked well in measuring the ground rod impedance over the mid-frequency range. The results match the low and high frequency impedance measurement of the rod and allowed measurements of impedance over the low end of the EMP spectrum. Figure 52 is a plot of the test probe impedance to ground using the mid-frequency setup. The highest frequencies are compared to the high frequency test and the results are within the measurement error.

The test procedure consisted of varying the frequency of the HP 651A Test Oscillator, while maintaining constant output voltage, and measuring the voltage at the terminal of the ground rod and the current through the lead to the ground rod. The test probe configuration was the same as for the high frequency measurements technique. The ground plate and auxiliary ground points were used to provide an effective reference contact with the soil.




Figure 51. Test setup for mid-frequency measurement.




Figure 52. Mid-frequency ground electrode impedance behavior.

4.3 EVALUATION OF GROUND ELECTRODES

There are times when a single ground rod does not offer an adequately low impedance path to earth, and another configuration will be required to provide a lower impedance path to earth. Electric utilities use this approach in substation grounding whereby they use a ground mat (a combination of rods and wires) to effectively ground an entire area. By connecting ground rods in parallel, the overall impedance can be lowered. This is a well understood practice for low frequency grounding. The purpose of the grid is primarily to lower the step-and-touch potential between any two step and touch points in the area when large fault currents are flowing. This principle is presumed to hold true for lightning strokes although utilities are constantly trying to upgrade their tower grounding techniques [31] to handle the high frequency as well as high currents of lightning. A good reference for substation grounding techniques is the IEEE "Guide for Safety in Alternating-Current Substation Grounding," [3]. This guide tells how to calculate and measure ground rod impedance. Section 23 of the guide is devoted to Model Testing [32]. Model testing has been employed to determine ground resistance and potential gradient patterns of different grounding configurations because modeling allows the various parameters to be controlled. This control allows a comparison of different grounding schemes to be made. The model usually consists of scaled (1:20) ground rods and wires, submerged in a tank of water. The resistance measurements are made by the standard Fall-of-Potential method described previously. The scaling factors are used to relate the test measurements to various conditions of fault current and earth resistivity. It was assumed that this technique could be coupled with scale modeling techniques for electromagnetic systems [33]. Scale modeling techniques have been effectively used for the measuring patterns of low frequency buried antennas [34]. Thus, scale modeling was used to assist in the measurement of high frequency impedance characteristics of different electrode configurations.

4.3.1 The Scale Models

The development of a scale model to accurately predict results of an electromagnetic system requires that strict attention be paid to the four scaling factors:

p = the scale factor for length

γ = the scale factor for time

α = the scale factor for electric intensity

β = the scale factor for magnetic intensity

If these parameters are accounted for when deriving the model, then an absolute model of the system can be developed.

The scale factor for length will determine the physical size of the model. Since the purpose was to measure ground rods and wires, a value of p was chosen which would allow multiple rods to be placed in a relatively small box of soil. The physical limitations were the size of the box and the quantity of earth required to fill it. The typical ground rod is approximately 3 to 4 meters in length and 1.0 to 2.5 cm in diameter. Noting that the model length, ℓ_m , will vary as

$$\ell_m = \frac{\ell}{p} \quad (39)$$

then a model length of 4 cm can be used if $p = 100$. It was felt that 4 cm would be a convenient length because the box of soil could be 15 cm in depth and not cause fringing problems. Therefore, a 100 to 1 length scale factor was chosen.

The soil parameters for the experiment will vary with the model scale factors by the following relationships:

$$\sigma_m = \frac{p}{\beta} \alpha \sigma \quad (40)$$

$$\epsilon_m = \frac{p}{\beta \gamma} \epsilon \quad (41)$$

$$\mu_m = \frac{p}{\alpha \gamma} \mu \quad (42)$$

The impedance of the model will vary with the scale factors of the E and H fields:

$$Z_m = \frac{\beta}{\alpha} Z \quad (43)$$

Note in Equation(43) that the model impedance is not an explicit function of physical or time scaling. Therefore, the network analyzer could be used to measure the impedance with the E and H scale factors equal to 1.0. This approach facilitated measurements because the impedance of the ground network could be read directly off the analyzer screen.

The model soil is a 325 Mesh Silica mixed with granulated graphite in a 7 to 5 mixture. The relative dielectric constant and the conductivity was determined to be 11.3 and 0.12 mho per meter, respectively. This mixture was placed in a copper lined styrofoam box to a depth of about 15 cm. A copper ground plate with a cut-out for the ground test samples was placed on top of the soil (see Figures 53 and 54).

The ground test sample configurations were chosen to conform with commonly used geometries. These configurations were numbered from one to five as follows:

| <u>No.</u> | <u>Configuration</u> | <u>Figure</u> |
|------------|----------------------------------|---------------|
| 1. | Single Ground Rod | 55 |
| 2. | Two Parallel Rods | 56 |
| 3. | Three Parallel Rods (triangular) | 57 |
| 4. | Eight Parallel Rods (star) | 58 |
| 5. | Eight Parallel Rods (loop) | 59 |

The construction of the ground rod assemblies began with a square plastic plate for support. A copper plate was glued to the top of the plastic plate and a hole was drilled through the two plates. A BNC connector was then placed over the hole, and the shield was soldered to the copper plate. A 4 cm long, #32, 0.127 cm wire was then soldered to the BNC connector (see Figure 55). The size of the plates was chosen to correspond to the cutout in the copper ground plate of the test box as shown in Figure 54.

The test samples with two or more ground rods have a spacing between rods approximately equal to the length of the rods. (This distance was difficult to control during the actual experiment because of the flexibility of the small diameter wire.)

4.3.2 Configuration Tests and Results

The general test setup is shown in Figure 60. The network analyzer probe was connected to the BNC connector of the sample after the sample had been carefully placed in the soil. Care was taken when the sample was placed in the soil to avoid bending the thin ground rods. Such bending was found to lead to erroneous measurements because the capacitance of the circuit would change with relative position of the rods. In addition, uncorrelated measurements were noted to arise

from variations in soil density. To overcome this problem, the soil was first stirred to loosen it up for the insertion of the ground rods, and then small weights were placed on top of the samples to provide uniform packing of the soil. With this procedure, the experiments were repeatable.

The object of the tests was to determine the impedance characteristics of different ground rod configurations at high frequencies and compare the results with those at low frequency (DC). The DC resistance for different configurations, all other conditions held constant, should vary with the Geometric Mean Distance, A, of the sample [35], i.e.,

$$R = \frac{\rho}{2\pi\ell} \ln \frac{2\ell}{A} \text{ ohms} \quad (44)$$

where

$$A = (a S_2 S_3 \dots S_n)^{1/n} \quad (45)$$

a = radius of rod

S_i = distance from rod 1 to rod i

Several DC tests were run to determine if the test samples followed this accepted theory. Figure 61 displays a very good correlation between the tests and theory. By adding ground rods of the proper spacing, the effective resistance to ground was lowered.

The high frequency impedance of an earth electrode system should vary as the square root of L/C , where L is the inductance and C is the capacitance of the particular configuration. These parameters vary with Geometric Mean Distance, A, as follows:

$$L = 2\ell \ln \frac{2\ell}{A} 10^{-7} \text{ H} \quad (46)$$

and

$$C = \frac{\epsilon_r \ell}{2\ell \ln(\frac{2\ell}{A})} \times \frac{10^{-9}}{9} \text{ F} \quad (47)$$

where ℓ = length of rod

ϵ_r = relative dielectric constant of soil




Figure 53. Test box for ground electrode model - cutaway view.




Figure 54. Test box for ground electrode model - top view.




Figure 55. Single ground rod model.




Figure 56. Two parallel rod model.





Figure 57. Three parallel rod model.





Figure 58. Eight parallel rod (star) model.





Figure 59. Eight parallel rod (loop) model.




Figure 60. Test setup for model impedance measurement.




Figure 61. Behavior of electrode resistance with relative area.




Figure 62. Single ground rod impedance behavior.




Figure 63. Two parallel rod impedance behavior.




Figure 64. Three parallel rod impedance behavior.




Figure 65. Eight parallel rod (star) impedance behavior.




Figure 66. Eight parallel rod (loop) impedance behavior.




Figure 67. Behavior of model impedances at various frequencies.




Figure 68. Marginal impedance per geometric mean distance of model.

Therefore, the impedance, Z, will vary with the Geometric Mean Distance, A:

$$Z \approx \frac{60}{\sqrt{\epsilon_r}} \ln \left(\frac{2\ell}{A} \right) \text{ ohms} \quad (48)$$

Testing was performed from 0.5 to 500 megahertz to determine if this hypothesis was true. The results are shown by the photographs in Figures 62 to 66 and are plotted on Figure 67. Examination of the figures reveals that the impedance does decrease with increasing Geometric Mean Distance for frequencies up to at least 300 megahertz. At 500 megahertz the impedance is relatively constant regardless of the ground rod area. It should be noted that the benefits of significant increases in area are limited, particularly at frequencies above 100 megahertz. The range of frequencies between 500 kilohertz and 100 megahertz enjoys the most benefit from increasing the area (see Figure 68). At frequencies above 100 megahertz, the conductor-soil interface evidently predominates, giving little change in impedance for increases in area. At DC the impedance (resistance) is strictly determined by rod contact area which is inversely proportional to the length of the ground system.

To examine this argument more closely, it was decided to remove the rods and leave the ground wires on Models 4 and 5, forming new Models 6 and 7 (see Figures 69 and 70), respectively. The same impedance tests were performed on Models 6 and 7, (Figures 71 and 72) and the results compared to Models 4 and 5 (see Figures 73 and 74). The figures reveal that as frequency is increased the impedance of the "rodless" sample approaches that of the sample with rods. Thus, for any frequency greater than approximately 300 megahertz, surface contact with earth will yield as good a ground as is obtainable. (The impedance to ground will be determined by the soil parameters at the point of contact.)

The above models represent only the external, below ground grid and rod structures. Most facilities, however, use a ground plate or ground bus that runs throughout the facility to which all equipment grounds are tied. There is a need to measure the impedance looking into this ground configuration [36] because this is the "ground" that internal equipment will see. To simulate the facility ground bus, Models 6 and 7 were further rewired so as to connect all the ground points together (multi-point ground) above the ground plate as shown in Figures 75 and 76.





Figure 69. Model 6 - Star with no ground rods.





Figure 70. Model 7 - Loop with no ground rods.




Figure 71. Model 6 impedance behavior.




Figure 72. Model 7 impedance behavior.




Figure 73. Comparison of Model 4 and Model 6 impedances at various frequencies.




Figure 74. Comparison of Model 5 and Model 7 impedances at various frequencies.





Figure 75. Model 8 - Model 6 with shorted ground connections.





Figure 76. Model 9 - Model 7 with shorted ground connections.

The models thus created were numbered 8 and 9, respectively. These models were connected to the network analyzer and the impedance plots (Figures 77 and 78) were taken. The photos exhibit the resonance characteristics of a series RLC circuit. The added inductance of the above ground wires has added appreciable series inductance to the circuit. Thus, as viewed from the equipment point of termination of a ground lead, the benefits offered by an earth ground may be negated by the inductance of the connecting lead.

4.4 OBSERVATIONS

An earth electrode system behaves like a second order, parallel, RLC network. It's low frequency (DC and power frequencies) impedance is predominantly determined by the resistivity of the soil and the length of the conductors. The high frequency (up to 500 MHz) impedance of the electrode is governed primarily by the soil's dielectric properties.

The impedance of an earth electrode system is inversely proportional to its geometric mean distance. This proportionality tends to disappear above 300 MHz. Above this frequency, there appears to be no benefit to be derived from increasing the ground system area.

Ground rods appear to be unimportant in so far as the behavior of an electrode system at RF (fast rise and fall times) is concerned. The contact of the electrode appears to be the primary factor in determining effectiveness.

For determining the best location for an earth electrode, the Resonant Antenna method is the most promising candidate for performing rapid ground conductivity and dielectric surveys. This method is portable, does not disturb the site, and accurately indicates performance over the frequency range occupied by the EMP power spectrum. This method should be supplemented with the standard Fall-of-Potential method to determine the low frequency (or DC) resistance of an electrode. High frequency measurements can be made with an RF Network Analyzer.

A typical approach to the establishment of auxiliary grounds would be to survey candidate sites with the Resonant Linear Antenna method. The local soil parameters will dictate the most appropriate ground configuration. After the electrodes are installed, they should be verified at DC by the classical Fall-of-Potential method, and their high frequency performance should be confirmed with a portable RF Network Analyzer.




Figure 77. Model 8 impedance behavior.




Figure 78. Model 9 impedance behavior.

V. CONCLUSIONS AND RECOMMENDATIONS

The External Collector Assessment Model (ECAM) can be effectively applied to the evaluation of EMP pickup of an overhead power line under various conditions of line length, line spacing, and number of grounding points. The results indicate that supplemental grounds exert a primary influence on the level of induced current only when they are placed within some 30-50 m of the line termination, i.e., the facility penetration point. At greater distances, supplemental grounds do exhibit a detectable effect but it is not considered sufficient to justify the associated effort and expense. The close-in effects, however, suggest that the "point of penetration" should be remotely located from the protected facility with surge suppression applied at the remote location and the intervening conductors routed underground in metal conduit.

The results from the preliminary investigation of internal collector coupling were inconclusive. Those obtained with an available method of moments code strongly suggest that considerably more developmental work is going to be required if an analytical approach is to be used. The limited results that were achieved suggest that internal collector pickup should be evaluated relative to potential effects from external collector pickup. A more promising approach for quantifying the level of internal collector pickup is that of experimental determination of the nominal shielding effectiveness of a typical, "unshielded" facility. Preliminary results suggest that indeed the inherent protective properties of typical construction may be usable and may be quantifiable. If such proves to be the case in actual operational facilities, a networks approach is suggested to the determination of the voltage and current levels on internal collectors from an EMP event (or any other electromagnetic threat).

Although extensive supplemental grounds on external collectors are not suggested, earth electrode systems do play a viable role in the protection of a facility from an EMP (or other impulsive phenomenon, such as lightning). Therefore, the earth electrode measurement approach described herein should prove useful in determining those constitutive parameters necessary for electrode design, for surveying a candidate site for the preferred electrode location, and for evaluating the performance of an installed electrode, whether full size or scaled. It utilizes current state-of-the-art instrumentation, which would have to be appropriately ruggedized for in-field use.

In view of the promising results of the external collector assessments, it is recommended that these assessments be extended to accommodate the effects of

nonlinear devices, i.e., surge suppressors. Further, validation of the analytical results through scale model tests (using TEM mode wave launchers) should be undertaken to confirm the penetration treatments suggested.

Additional experimental work on the shielding effectiveness of typical structures is recommended to support tradeoff decisions as to the level of supplemental shielding required for a given installation. Analytical verification of certain simplified geometries may be in order to confirm experimental findings.

VI. REFERENCES

1. Lightning Protection Code 1968, NFPA 78, National Fire Protection Association, Boston, MA.
2. Volcik, L., Martin, T. A., Mindel, I. N., "Shielded Enclosure Test Bed Requirement", DNA 5341F, Contract No. DNA 001-79-C-205, IIT Research Institute, Chicago, IL, April 30, 1980.
3. IEEE Guide for Safety in Alternating-Current Substation Grounding, IEEE Std. 80-1961, IEEE New York, NY.
4. Messier, M. A., "The Effect of Ground Reflections on Observed EMP Waveforms," DNA 3370T, Contract No. DNA-001-73-C-0118, Mission Research Corporation, Santa Barbera, CA, September 11, 1974.
5. Dudley, D. G., "Numerical Inversion of the Fourier Transforms A Combination Trapezoidal and Filon Technique," UCRL0S1878, California University, Livermore, CA, 1975.
6. Carson, J. R., "Wave Propagation in Overhead Wires with Ground Return," Bell System Technical Journal, Vol. 5, Oct. 1926, pp. 538-554.
7. Paul, C. R., "Applications of Multiconductor Transmission Line Theory to the Prediction of Cable Coupling, Volume I, Multiconductor Transmission Line Theory," RADC-TR-76-101, Contract No. F30602-72-C-0418, Rome Air Development Center, Griffiss AFB, NY, April 1976.
8. Paul, C. R., "Modal Decomposition for Power Transmission Lines with Imperfect Earth Return," Proceedings of the IEE (London), Vol. 124, July 1971, pp. 647-648.
9. Marable, J. H., et. al., "Power System EMP Protection," AFWL EMP-Interaction Note 246, Kirtland AFB, Albuquerque, NM, May 1975.
10. DNA EMP (Electromagnetic Pulse) Handbook, Volume 1 - Design Principles DNA 2114H-1, General Electric Company - TEMPO DAS1AC, 816 State Street, Santa Barbara, CA 93102.
11. Vance, E. F., "Electromagnetic-Interference Control," IEEE Transactions on Electromagnetic Compatibility, Vol. EMC-22, No. 4, November 1980, pp. 319-328.
12. Landt, J. A., Miller, E. K. Van Blaricum, M., "WT-MBA/LLL1B: A Computer Program for the Time Domain Electromagnetic Response of Thin-Wire Structures," AFWL EMP - Interaction Note 210, Kirtland AFB, Albuquerque, NM, May 6, 1974.
13. Holland, R., "THREDE: A Free-Field EMP Coupling and Scattering Code," IEEE Transactions on Nuclear Science, Vol. NS-24, Dec. 1977, pp. 2416-2421.
14. Rice, L. P., "Radio Transmission into Buildings at 35 and 150 Mc.," Bell System Technical Journal, Jan. 1959, pp. 197-210.

15. Electromagnetic-Pulse Handbook for Electric Power Systems, Stanford Research Institute, Palo Alto, CA, February 4, 1975.
16. Smith, G. S., and King, R. W. P., "The Resonant Linear Antenna as a Probe for Measuring the In Situ Electrical Properties of Geological Media", Journal of Geophysical Research, Vol. 79, No. 17, June 10, 1974, pp. 2623-2628.
17. Towne, H. M., "Impulse Characteristics of Driven Grounds", General Electric Review, Vol. 31, No. 11, November 1928, pp. 605-609.
18. Bellaschi, P. L., "Impulse and 60 Cycle Characteristics of Driven Grounds", AIEE Transactions, Vol. 60, March 1941, pp. 123-128.
19. Bellaschi, P. L., Armington, R. E., and Snowden, A. E., "Impulse and 60-Cycle Characteristics of Driven Grounds II", AIEE Transactions, Vol. 61, 1942, pp. 349-363.
20. Eaton, J. R., "Impulse Characteristics of Electrical Connections to the Earth," General Electric Review, Vol. 47, October 1944, pp. 41-50.
21. Curdts, E. B., "Some of the Fundamental Aspects of Ground Resistance Measurements", AIEE Transactions, Communications and Electronics, Vol. 77, No. 39, November 1958, pp. 767-770.
22. Duke, C. A., and Smith, L. E., "The Technique and Instrumentation of Low-Impedance Ground Measurement", AIEE Transactions, Communications and Electronics, Vol. 77, No. 39, November 1958, pp. 767-770.
23. Gaddy, O. L., "A Simple Method of Measuring Fractional Millimicrosecond Pulse Characteristics," IRE Transactions on Instrumentation, Vol. 1-9, No. 3, December 1960, pp. 326-333.
24. Mukhedkar, D., Gervais, Y., and De Jean, J. P., "Modeling of a Grounding Electrode", IEEE Transactions on Power Apparatus and Systems, Vol. PAS 92, No. 1, January-February 1973, pp. 295-297.
25. Mukhedkar, D., and Dawalibi, F., "Ground Electrode Resistance Measurements in Non-Uniform Soils", IEEE Transactions on Power Apparatus and Systems, Vol. PAS-93, 1973, pp. 109-115.
26. Scott, L. D., and Smith, G. A., "Measurement Techniques for Antennas in Dissipative Media", IEEE Transactions on Antennas and Propagation, Vol. AP-21, No. 4, July 1973, pp. 499-507.
27. Mukhedkar, D., Gervais, Y., and Dawalibi, F., "Modeling of Potential Distribution Around a Grounding Electrode", IEEE Transactions on Power Apparatus and Systems, Vol. PAS-92, No. 4, July-August 1973, pp. 1455-1459.
28. Lee, K. M., and Smith, G. S., "Measured Properties and Insulated Antennas in Sand", IEEE Transactions on Antennas and Propagation, Vol. AP-23, No. 5, September 1975, pp. 664-70.
29. Lytle, R. J., "Properties of the Ground Inferred from Electromagnetic Measurements", IEEE Transactions on Antennas and Propagation, Vol. AP-27, No. 6, November 1979, pp. 899-902.

30. Denny, H. W., Holland, L. D., Robinette, S. L., and Woody, J. A., "Grounding, Bonding, and Shielding Practices and Procedures for Electronic Equipments and Facilities," Volume 1, Final Report, Contract DOT-FA72WA-2850, Engineering Experiment Station, Georgia Institute of Technology, December 1975, AD A022 332.
31. Rogers, E. J., "Impedance Characteristics of Large Tower Footings to a 100 s Square Wave of Current", IEEE Transactions on Power Apparatus and Systems, Vol. PAS-100, No. 1, January 1981, pp. 66-71.
32. Armstrong, H. R., "Grounding Electrode Characteristics from Model Tests," AIEE Transactions, Vol. 72, Part II, pp. 1301-6, 1953.
33. Sinclair, G., "Theory of Models of Electromagnetic Systems," Proceedings of the IRE., November, 1948, pp. 1364-1370.
34. Jenkins, H. H., "Study and Evaluation of Buried Dipole Antennas", Final Report, Contract No. DAAB07-74-C-0103, Engineering Experiment Station, Georgia Institute of Technology, May 1975.
35. Rudenberg, R., Electrical Shock Waves in Power Systems, Harvard University Press, Cambridge, Massachusetts, 1968.
36. "EMP Protection for Emergency Operating Centers," TR-61A, Defense Civil Preparedness Agency, Washington, D.C., July 1972.

APPENDIX A

FILON'S METHOD FOR TIME-FREQUENCY DOMAIN CONVERSIONS

In order to use the frequency domain model of the transmission line to determine the EMP coupling to the line, an accurate and efficient method of transforming from the time domain to the frequency domain and vice versa was necessary. Because of the exceedingly large bandwidth of the EMP power spectrum, conventional methods were too inefficient. A method called "Filon's Method" proved effective. The method is based on a piecewise linear approximation of the argument function. The purpose of this appendix is to summarize the essential features of this method.

The Fourier Integral may be written as

$$F(\omega) = \int_{-\infty}^{\infty} f(t) e^{-j\omega t} dt \quad (A-1)$$

while the Inversion Integral may be written as

$$f(t) = \frac{1}{2\pi} \int_{-\infty}^{\infty} F(\omega) e^{j\omega t} d\omega \quad (A-2)$$

If $f(t)$ in Equation (A-1) is sufficiently smooth, then straight line segments may be used to approximate (piecewise-linearly) $f(t)$ by

$$f(t) \approx \sum_{i=1}^N a_i t + b_i \quad (A-3)$$

where, as given in Figure (A.1),

$$a_i = \frac{f(t_{i+1}) - f(t_i)}{t_{i+1} - t_i}$$
$$b_i = f(t_i) - a_i t_i$$




Figure A-1. Piecewise-linear approximation of a time function, $F(t)$.

Differentiating $f(t)$ twice, one obtains

$$f''(t) \approx \sum_{i=1}^N a_i \delta(t - t_i) \quad (A-4)$$

where $\delta(t)$ is the dirac delta function. However, it is known that differentiating Fourier transforms twice yields:

$$f''(t) = (j\omega)^2 F(\omega) \quad (A-5)$$

Substituting Equations (A-4) and (A-5) into Equation (A-1), produces

$$-\omega^2 F(\omega) \approx \int_{-\infty}^{\infty} \sum_{i=1}^N a_i \delta(t - t_i) e^{-j\omega t} dt \quad (A-6)$$

which can be reduced to

$$F(\omega) \approx -\frac{1}{\omega^2} \sum_{i=1}^N a_i e^{-j\omega t_i} \quad (A-7)$$

Using this equation, the Fourier Transform of a smooth time function $f(t)$ may be easily calculated.

This method was used to transform the incident EMP field from the time domain to the frequency domain. To illustrate, the EMP incident field is commonly represented as a four term exponential as follows:

$$E(t) = E_o [e^{-\alpha t} - e^{-\beta t} - A(e^{-\alpha t} - e^{-\delta t})] \quad (A-8)$$

where

$$E_o = 5 \times 10^4 / .9646 \text{ V/m}$$

$$\alpha = 1.5 \times 10^6$$

$$\begin{aligned}
\beta &= 2.6 \times 10^8 \\
\alpha &= 2.0 \times 10^5 \\
\delta &= 5.0 \times 10^5 \\
A &= (\alpha^{-1} - B^{-1})/(\alpha^{-1} - \delta^{-1})
\end{aligned}$$

and t is defined in seconds.

(The time domain representation of this incident field and its transformed frequency spectrum are shown in Figure 8.)

The transmission line program was run for 211 discrete frequencies, where an incident plane wave is impinged upon the line at the given frequency of the calculated amplitude and phase. The frequency domain output of the program then was transformed back to the time domain by the way of the inversion integral.

The piecewise linear approximation method used in the forward integral was also used in the inverse transformation to obtain $f(t)$ from the real and imaginary parts of $F(\omega)$. Since $f(t)$ is known to be a real time causal function, then $f(t)$ can be determined in terms of the real or imaginary part of its Fourier transform* $F(\omega) = R(\omega) + i X(\omega)$

$$f(t) = \frac{2}{\pi} \int_0^{\infty} R(\omega) \cos \omega t d\omega = -\frac{2}{\pi} \int_0^{\infty} X(\omega) \sin \omega t d\omega \quad (A-9)$$

Therefore, since either the real or the imaginary parts of the transform may be used, the imaginary part $X(\omega)$ was selected. Thus $f(t)$ can be determined by evaluating the following:

$$f(t) = -\frac{2}{\pi} \int_0^{\infty} X(\omega) \sin \omega t d\omega \quad (A-10)$$

where $X(\omega)$, the imaginary part of the Fourier transform, is piecewise linearly approximated by

$$X(\omega) = \sum_{k=1}^N c_k \omega + d_k \quad (A-11)$$

*A. Papoulis, The Fourier Integral and Its Applications, McGraw-Hill, New York, NY, (1962), pp. 53-59.

where

$$c_k = \frac{F(\omega_{k+1}) - F(\omega_k)}{\omega_{k+1} - \omega_k}$$

$$d_k = F(\omega_k) - c_k \omega_k$$

Thus, analogously with the forward (i.e., time-to-frequency) transformation, the frequency function is piecewise-linearly approximated. Then Equation (A-11) is substituted into Equation (A-10) and integration is performed to obtain:

$$f(t) = -\frac{2}{\pi} \sum_{k=1}^N c_k C(t) - d_k D(t) \quad (A-12)$$

where

$$C(t) = -\frac{\omega_{k+1}}{t} \cos \omega_{k+1} t + \frac{1}{t^2} \sin \omega_{k+1} t$$

$$+ \frac{\omega_k}{t} \cos \omega_k t - \frac{1}{t^2} \sin \omega_k t$$

and

$$D(t) = -\frac{1}{t} \cos \omega_{k+1} t + \frac{1}{t} \cos \omega_k t$$

Using Equation (A-7) for the forward (time-to-frequency) Fourier transform and Equation (A-12) for the inversion (frequency-to-time) transform, Fourier transformations for time functions with exceedingly large bandwidths may be performed.

APPENDIX B

DESCRIPTION OF MULTICONDUCTOR TRANSMISSION LINE BEHAVIOR WHEN ILLUMINATED BY AN INCIDENT FIELD IN THE PRESENCE OF A LOSSY GROUND

The purpose of this appendix is to derive the transmission line equations for a uniform line consisting of N perfect conductors at a given height above a lossy ground when the line is excited by an incident electromagnetic field*. The equations can be developed from Faraday's law in integral form, which can be expressed as

$$\int_{C_i} \underline{E} \cdot d\underline{\ell} = -j\omega\mu \int_{S_i} \underline{H} \cdot \hat{n} da \quad (B-1)$$

where S_i is a flat, rectangular surface in the x - y plane between the i^{th} wire and the ground plane and between x and $x + \Delta x$ as shown in Figure B-1. The unit normal \hat{n} is z directed, the surface differential is defined as $da = dxdy$ and C_i is a closed contour encircling S_i in a counter-clockwise direction. Equation (B-1) can then be rewritten as**

$$\begin{aligned} & \int_0^{d_{io}} \left[E_{ti}(y, x + \Delta x) - E_{ti}(y, x) \right] dy - \int_x^{x+\Delta x} \left[E_{li}(d_{io}, x) - E_{li}(0, x) \right] dx \\ &= -j\omega\mu \int_x^{x+\Delta x} \int_0^{d_{io}} H_{ni}(y, x) dy dx \end{aligned} \quad (B-2)$$

where E_{ti} is the component of the total electric field (incident plus scattered) transverse to the line axis and lying along a straight line between the conductor and the ground plane; E_{li} is the component of total electric field along the longitudinal axis of the line; H_{ni} is the component of total magnetic field perpendicular to the plane formed by the wire and ground.

*C. R. Paul, "Applications of Multiconductor Transmission Line Theory to the Prediction of Cable Coupling, Volume VI, A Digital Computer Program for Determining Terminal Currents Induced in a Multiconductor Transmission Line by an Incident Electromagnetic Field." Technical Report, RADCR-76-101, Rome Air Development Center, Griffiss AFB, NY, February 1978.

**In integrating from $y = 0$ to $y = d_{io}$, it is assumed that $r_{wi} \ll d_{io}$, i.e., the wire may be replaced by a filament.




Figure B-1. Incremental transmission line model.

The voltage between the i^{th} wire and the ground may be defined as

$$V_i(x) = - \int_0^{d_{io}} E_{ti}(y, x) dy \quad (\text{B-3})$$

Thus,

$$\frac{-dV_i(x)}{dx} = \lim_{\Delta x \rightarrow 0} \frac{1}{\Delta x} \int_0^{d_{io}} [E_{ti}(y, x + \Delta x) - E_{ti}(y, x)] dy \quad (\text{B-4})$$

Since the wires are assumed to be perfect conductors ($E_{\ell i}(d_{io}, x) = 0$), then Equation (B-2) becomes

$$\frac{dV_i(x)}{dx} - \lim_{\Delta x \rightarrow 0} \frac{1}{\Delta x} \int_x^{x+\Delta x} E_{\ell i}(0, x) = j\omega\mu \int_0^{d_{io}} H_{ni}(y) dy \quad (\text{B-5})$$

The second term of Equation (B-5) needs to be evaluated using L'Hospital's Rule, i.e.

$$\lim_{\Delta x \rightarrow 0} \frac{1}{\Delta x} \int_x^{x+\Delta x} E_{\ell i}(0, x) dx = \lim_{\Delta x \rightarrow 0} \frac{\frac{d}{d\Delta x} \int_x^{x+\Delta x} E_{\ell i}(0, x) dx}{\frac{d}{d\Delta x} (\Delta x)} \quad (\text{B-6})$$

The numerator of Equation (B-6) may then be evaluated using Leibnitz's Rule:

$$\begin{aligned} \frac{d}{d\Delta x} \int_x^{x+\Delta x} E_{\ell i}(0, x) dx &= \int_x^{x+\Delta x} \frac{\partial E_{\ell i}(0, x)}{\partial \Delta x} dx \\ &+ (1) E_{\ell i}(x + \Delta x) - (0) E_{\ell i}(x) = E_{\ell i}(x + \Delta x) \end{aligned} \quad (\text{B-7})$$

Substituting Equation (B-7) into Equation (B-6) and Equation (B-6) back into Equation (B-5) produces

$$\frac{dV_i(x)}{dx} - E_{li}(x) = j\omega\mu \int_0^{d_{io}} H_{ni}(y) dy \quad (B-8)$$

The total \underline{H}_n field can now be separated into two parts:

$$\underline{H}_n = \underline{H}_n^{scat} + \underline{H}_n^{inc} \quad (B-9)$$

where \underline{H}_n^{scat} is the scattered magnetic field and \underline{H}_n^{inc} is the incident field.

The longitudinal electric field, $\underline{E}_l(x)$, represents the losses in the earth and can be expressed as

$$\underline{E}_l(x) = \underline{Z}_g \underline{I}_1(x) \quad (B-10)$$

where

$$\underline{Z}_g = \underline{R}_e + j\omega\underline{L}_e \quad (B-11)$$

and

$$\underline{I}_1(x) = -\underline{I}(x) \quad (B-12)$$

The ground impedance term \underline{Z}_g is made up of the ground resistance term \underline{R}_e and the ground inductance term, \underline{L}_e , which can be calculated using Carson's Formula's*.

*Carson, op. cit., Reference 6.

Substituting Equation (B-12) into Equation (B-10) and using Equation (B-9), Equation (B-8) becomes

$$\begin{aligned} \frac{\partial \underline{V}(x)}{\partial x} + \underline{Z}_g \underline{I}(x) = & + j\omega\mu \int_0^{d_{io}} \underline{H}_{ni}^{scat}(y, x) dy \\ & + j\omega\mu \int_0^{d_{io}} \underline{H}_{ni}^{inc}(y) dy \end{aligned} \quad (B-13)$$

The scattered flux passing between the conductor and the ground plane is directly related to the scattered magnetic field and the per-unit-length inductance matrix \underline{L}_1 by

$$\phi_i^{scat}(x) = - \int_0^{d_{io}} \mu \underline{H}_{ni}^{scat}(y) dx = [\underline{L}_1 \underline{I}(x)]_i \quad (B-14)$$

Upon substituting Equation (B-14) into Equation (B-13), the transmission line voltage equation is obtained for the line excited by an incident field in the presence of a lossy earth as

$$\frac{d}{dx} \underline{V}(x) + \underline{Z}_T \underline{I}(x) = \underline{V}_s(x) \quad (B-15)$$

where

$$\underline{Z}_T = j\omega \underline{L}_1 + \underline{Z}_g \quad (B-16)$$

and

$$\underline{V}_{s1}(x) = j\omega\mu \int_0^{d_{io}} \underline{H}_{ni}^{inc}(y) dy \quad (B-17)$$

The transmission line current equation may be derived using Amperes' Law in differential form

$$\nabla \times \underline{H} = j\omega\epsilon\underline{E} + \underline{J} \quad (B-18)$$

Assuming a source free region and allowing only the TEM mode of propagation, Equation (B-18) becomes

$$\underline{E}_y = \frac{1}{j\omega\epsilon} \left[\frac{\partial H_x}{\partial z} - \frac{\partial H_z}{\partial x} \right] \quad (B-19)$$

where \underline{E}_y consists of a scattered electric field component and an incident field component and is written as

$$\underline{E}_t(y, x) = \underline{E}_y(y, x) = \underline{E}_y^{scat}(y, x) + \underline{E}_y^{inc}(y, x) \quad (B-20)$$

Substituting Equation (B-19) into the voltage definition (Equation B-3) produces

$$V_i(x) = \frac{-1}{j\omega\epsilon} \int_0^{d_{io}} \left[\frac{\partial H_{zi}^{scat}(y, x)}{\partial x} + \frac{\partial H_{zi}^{inc}(y, x)}{\partial x} - \frac{\partial H_{xi}^{scat}(y, x)}{\partial z} - \frac{\partial H_{xi}^{inc}(y, x)}{\partial z} \right] dy \quad (B-21)$$

Using the definition in Equation (B-14), Equation (B-21) becomes

$$\begin{aligned} \underline{V}_1(x) = & \frac{-\underline{L}}{j\omega\mu\epsilon} \frac{d}{dx} [\underline{I}(x)] - \frac{1}{j\omega\epsilon} \int_0^{d_{io}} \frac{\partial}{\partial z} H_{xi}^{scat}(y, x) \\ & - \int_0^{d_{io}} E_{ti}^{inc}(y, x) dy \end{aligned} \quad (B-22)$$

If it is assumed that there are no transverse components of current on the wire or the ground plane, then $\underline{H}_x^{scat}(y, x) = 0$ and Equation (B-22) becomes

$$\frac{\partial \underline{I}_1(x)}{\partial x} + j\omega\mu\epsilon \underline{L}^{-1} \underline{V}(x) = -j\omega\mu\epsilon \underline{L}^{-1} \int_0^{d_{io}} E_{ti}(y, x) dy \quad (B-23)$$

Since

$$\underline{C} = \mu\epsilon \underline{L}^{-1} \quad (B-24)$$

then Equation (B-23) becomes

$$\frac{\partial}{\partial x} \underline{I}(x) + \underline{Y} \underline{V}(x) = \underline{I}_s(x) \quad (B-25)$$

where

$$\underline{Y} = j\omega \underline{C} \quad (B-26)$$

and

$$\underline{I}_s(x) = -\underline{Y} \int_0^{d_{io}} \underline{E}_t(y, x) dy \quad (B-27)$$

Thus, Equations (B-15) and (B-25) are the first order voltage and current transmission line differential equations for a transmission line in the presence of a lossy ground when impinged upon by an incident electromagnetic field.

APPENDIX C

DETERMINATION OF THE EARTH RETURN PARAMETERS

The problem of wave propagation along a transmission system composed of an overhead wire parallel to the surface of the earth was first solved by Carson in 1926*. The contribution of the resistance \tilde{R}_e and reactance \tilde{X}_e due to the earth-return path was calculated using the infinite series developed by Carson to solve the following integral equations:

$$[\tilde{R}_e]_{ii} + j\omega[\tilde{L}_e]_{ii} = \frac{j\omega\mu_0}{\pi} \int_0^\infty \frac{\mu \exp(-2\zeta H_i)}{\mu\zeta + (\zeta^2 + \beta^2)^{1/2}} d\zeta \quad (C-1)$$

$$[\tilde{R}_e]_{ij} + j\omega[\tilde{L}_e]_{ij} = \frac{j\omega\mu_0}{\pi} \int_0^\infty \frac{\mu \cos[\zeta\{D_{ij}^2 - (H_i - H_j)^2\}^{1/2}] \exp\{-\zeta(H_i + H_j)\}}{\mu\zeta + (\zeta^2 + \beta^2)^{1/2}} d\zeta \quad (C-2)$$

where μ is the relative permeability of the soil, μ_0 is the free space permeability, H_i is the height of the i^{th} conductor above ground, D_{ij} is the center-to-center separation of conductors i and j and $\beta^2 = j\omega\mu\mu_0^2$ where σ is the conductivity of the soil.

Carson's method for solving Equations (C-1) and (C-2) was used. The real and imaginary correction component matrices \tilde{P} and \tilde{Q} , respectively, are calculated in terms of the geometry-related terms r and θ , where

$$r_{ij} = \sqrt{\omega\mu\sigma} D_{ij} \quad (C-3)$$

and θ_{ij} is the angle subtended at the i^{th} conductor by the i^{th} image and the j^{th} image, see Figure (C-1). The relationship between $\tilde{R}_e(\omega)$ and $\tilde{L}_e(\omega)$ and the correction component matrices \tilde{P} and \tilde{Q} are

$$\tilde{R}_e(\omega) = \frac{\omega\mu}{\pi} \tilde{P} \quad (C-4)$$

$$\tilde{L}_e(\omega) = \frac{\omega}{\pi} \tilde{Q} \quad (C-5)$$

*Carson, op. cit., Reference 6




Figure C-1. Conductor-earth geometry.

Therefore, the only thing left is a method to calculate \tilde{P} and \tilde{Q} . The determination of the correction component matrices is dependent on the parameter r . Therefore, the formulas given for \tilde{P} and \tilde{Q} will only be used for the ranges of r specified.

For the range where $r \leq 1/4$,

$$[\tilde{P}]_{ij} = \frac{\pi}{8} - \frac{r \cos \theta}{3\sqrt{2}} + \frac{r^2}{16} \cos 2\theta (0.6728 + \ln \left(\frac{2}{r}\right)) + \frac{r^2}{16} \theta \sin 2\theta \quad (C-6)$$

and

$$[\tilde{Q}]_{ij} = -.0382 + \frac{1}{2} \ln \left(\frac{2}{r}\right) + \frac{1}{3\sqrt{2}} r \cos \theta \quad (C-7)$$

For the range, $1/4 < r \leq 5$

$$[\tilde{P}]_{ij} = \frac{\pi}{8} (1 - S_4) + \frac{1}{2} \ln \left(\frac{2}{\gamma r}\right) S_2 + \frac{\theta}{2} S_2' - \frac{\sigma_1}{\sqrt{2}} + \frac{\sigma_2}{2} + \frac{\sigma_3}{\sqrt{2}} \quad (C-8)$$

$$[\tilde{Q}]_{ij} = \frac{1}{4} + \frac{\ln \left(\frac{2}{\gamma r}\right) (1 - S_4)}{2} - \frac{\theta S_4'}{2} + \frac{\sigma_1}{\sqrt{2}} - \frac{\pi S_2}{8} + \frac{\sigma_3}{\sqrt{2}} - \frac{\sigma_4}{2} \quad (C-9)$$

where γ is Euler's constant (1.7811) and S_2 , S_2' , S_4 , S_4' , σ_1 , σ_2 , σ_3 , σ_4 are defined by the following infinite series:

$$S_2 = \sum_{n=0}^{\infty} a_n \cos (4n + 2) \theta \quad (C-10)$$

$$S_2' = \sum_{n=0}^{\infty} a_n \sin (4n + 2) \theta \quad (C-11)$$

$$S_4 = \sum_{n=0}^{\infty} c_n \cos (4n + 4) \theta \quad (C-12)$$

$$S_4' = \sum_{n=0}^{\infty} c_n \sin (4n + 4) \theta \quad (C-13)$$

$$\sigma_1 = \sum_{n=0}^{\infty} e_n \cos (4n + 1) \theta \quad (C-14)$$

$$\sigma_2 = \sum_{n=0}^{\infty} g_n \cos (S_2)_n \quad (C-15)$$

$$\sigma_3 = \sum_{n=0}^{\infty} f_n \cos (4n + 3) \theta \quad (C-16)$$

$$\sigma_4 = \sum_{n=0}^{\infty} h_n (S_4)_n \quad (C-17)$$

$$a_n = \frac{-a_{n-1}}{2n(2n+1)^2(2n+2)} \left(\frac{r}{2}\right)^4, \quad a_o = \frac{r^2}{8} \quad (C-18)$$

$$c_n = \frac{-c_{n-1}}{(2n+1)(2n+2)^2(2n+3)} \left(\frac{r}{2}\right)^4, \quad c_o = \frac{r^4}{192} \quad (C-19)$$

$$e_n = \frac{-e_{n-1}}{(4n-1)(4n+1)^2(4n+3)} r^4, \quad e_o = \frac{r}{3} \quad (C-20)$$

$$f_n = \frac{-f_{n-1}}{(4n+1)(4n+3)^2(4n+5)} r^4, \quad f_o = \frac{r^3}{45} \quad (C-21)$$

$$h_n = h_{n-1} + \frac{1}{4n+2} + \frac{1}{2n+2} + \frac{1}{2n+3} - \frac{1}{4n+6}, \quad h_o = \frac{5}{3} \quad (C-22)$$

$$g_n = g_{n-1} + \frac{1}{4n} + \frac{1}{2n+1} + \frac{1}{2n+2} - \frac{1}{4n+4}, \quad g_o = \frac{5}{4} \quad (C-23)$$

The above series converge quite rapidly; therefore, for the range $1/4 < r \leq 1$, only the first terms are important. For the range $1 < r < 2$, only the first two leading terms of each series need be retained and for the case of the range between $2 < r < 5$ the first five terms were retained in the calculation of \tilde{P} and \tilde{Q} . However, for the range $5 < r \leq 10$, the following asymptotic expansion for \tilde{P} and \tilde{Q} were required:

$$[\tilde{P}]_{ij} = \frac{1}{\sqrt{2}} \frac{\cos \theta}{r} - \frac{\cos 2\theta}{r^2} + \frac{1}{\sqrt{2}} \frac{\cos 3\theta}{r^3} + \frac{3}{\sqrt{2}} \frac{\cos 5\theta}{r^5} \dots \quad (C-24)$$

$$[\tilde{Q}]_{ij} = \frac{1}{\sqrt{2}} \frac{\cos \theta}{r} - \frac{1}{\sqrt{2}} \frac{\cos 3\theta}{r^3} + \frac{3}{\sqrt{2}} \frac{\cos 5\theta}{r^5} \dots \quad (C-25)$$

Finally, for large values of r , i.e., $r > 10$, \tilde{P} and \tilde{Q} can be determined from

$$\tilde{J} = \tilde{P} + i\tilde{Q} \quad (C-26)$$

where

$$\tilde{J} = \frac{1+i}{\sqrt{2}} \frac{\cos\theta}{r} - \frac{\cos 2\theta}{r^2} \quad (C-27)$$

These formulas will allow the determination of the line resistance and reactance, due to the earth return path, if the geometry is specified, i.e., line configuration, and the soil's constitutive parameters ($\sigma_s, \epsilon_s, \mu_s$) are known.

The relative permeability of the soil will be assumed to be unity ($\mu_r = 1$). The relative permittivity and conductivity, on the other hand, must be determined. Because the EMP power spectrum extends over a wide range of frequencies, it was necessary to determine the relative permittivity of the soil, ϵ_r , and the conductivity, σ , as functions of frequency. A set of curves^{*} have been developed which relate the conductivity and dielectric constant to frequency up to 1 MHz. (Messier^{**} has graphically extrapolated the curves out to 100 MHz). These curves are functions of both frequency and percent by volume of water content. A curve fitting procedure was employed to obtain a second order polynomial which fits Scott's median curve (a 3% per volume water content in the soil). The resulting polynomials are:

$$K = .2139188 - .105563 * F + .0220925 * F^2 \quad (C-28)$$

$$D = 5.607518 - 1.0794379 * F + .062138524 * F^2 \quad (C-29)$$

where

$K = \log_{10}$ of conductivity (mho/m)

$D = \log_{10}$ of dielectric constant (ϵ/ϵ_0)

$F = \log_{10}$ of frequency (Hz)

*J. H. Scott, "Electrical and Magnetic Properties of Rock and Soil", United States Geological Survey, Technical Letter, Special Project 16 May 1966.

**Messier, op. cit., Reference 4

With this information, the effect of a lossy ground on the response of an overhead transmission line can be taken into account.

APPENDIX D

DETERMINATION OF THE SIMILARITY TRANSFORM T AND ITS INVERSE T^{-1}

In order to be able to perform the model decomposition suggested in Section II, it is necessary to obtain a similarity transform T that diagonalizes the matrix product of \underline{Y} \underline{Z} in

$$\underline{\gamma}^2 = \underline{T} \underline{Y} \underline{Z} \underline{T}^{-1} \quad (D-1)$$

where $\underline{\gamma}^2$ is a diagonal matrix.

Equations (3) and (4) define \underline{Y} and \underline{Z} as

$$\underline{Y}(\omega) = j\omega \underline{C} \quad (D-2)$$

$$\underline{Z}(\omega) = \underline{R}_e(\omega) + j\omega \underline{L}_e(\omega) + j\omega \underline{L} \quad (D-3)$$

where L and C are per-unit-length transmission line inductance and capacitance matrices and $\underline{R}_e(\omega)$ and $\underline{L}_e(\omega)$ are the per-unit-length resistance and capacitance matrices of the earth return, respectively.

The matrix product $\underline{Y} \underline{Z}$ is thus:

$$\underline{Y} \underline{Z} = -\omega^2 \underline{C} \underline{L} + j\omega \underline{C} (\underline{R}_e(\omega) + j\omega \underline{L}_e(\omega)) \quad (D-4)$$

Using the fact that

$$\underline{C} \underline{L} = \frac{1}{c^2} \underline{I}_n \quad (D-5)$$

where \underline{I}_n is an $n \times n$ identity matrix and c is the velocity of light in free space, then Equation (D-4) reduces to

$$\underline{Y} \underline{Z} = \frac{-\omega^2}{c^2} \underline{I}_n + j\omega \underline{C} (\underline{R}_e(\omega) + j\omega \underline{L}_e(\omega)) \quad (D-6)$$

Thus, in order to diagonalize $\underline{Y} \underline{Z}$ a \underline{T} must be found to diagonalize the matrix product of $\underline{C} \underline{R}_e(\omega)$ and $\underline{C} \underline{L}_e(\omega)$. It is possible to diagonalize each independently but there is no guarantee the \underline{T} that diagonalizes one will diagonalize the other. Therefore, the following approximation suggested by Paul* was used

$$\underline{R}_e(\omega) + j\omega \underline{L}_e(\omega) \approx z_e(\omega) \underline{U}_n \quad (D-7)$$

where the scalar $z_e(\omega)$ is the complex equivalent impedance of the earth. The equivalent impedance was calculated by taking the average of all elements in the matrix as Paul suggests. The \underline{U}_n matrix is an $n \times n$ matrix of all ones, i.e.,

$$\underline{U}_n = \begin{bmatrix} 1 & 1 & . & . & . & 1 \\ 1 & 1 & . & . & . & 1 \\ . & . & . & . & . & . \\ . & . & . & . & . & . \\ 1 & 1 & . & . & . & 1 \end{bmatrix} \quad (D-8)$$

(This procedure is equivalent to representing the return path as another lossy conductor similar to one of the phase conductors, as shown in Figure 10.) Therefore, Equation (D-1) then becomes

$$\underline{Y}^2 = \underline{T} \underline{Y} \underline{Z} \underline{T}^{-1} = \frac{-\omega^2}{c} \underline{1}_n + \underline{\Lambda}^2 \quad (D-9)$$

where $\underline{\Lambda}^2$ is a diagonal matrix defined as follows:

$$\underline{\Lambda}^2 = z_e(\omega) \underline{T}^{-1} \underline{C} \underline{U}_n \underline{T} \quad (D-10)$$

*Paul, op.cit., Reference 8.

The only thing left now is to find a \tilde{T} which will diagonalize the matrix product $\tilde{C} \tilde{U}_n$. Paul in Reference 8 defines such a \tilde{T} .

The model decomposition matrix \tilde{T} which diagonalizes $\tilde{C} \tilde{U}_n$ is given by

$$[\tilde{T}]_{ii} = 1 \quad i = 1, \dots, (n-1) \quad (D-11)$$

$$[\tilde{T}]_{in} = c_{ii} \sum_{m=1}^n c_{mm} \quad i = 1, \dots, n \quad (D-12)$$

$$[\tilde{T}]_{ni} = -1 \quad i = 1, \dots, (n-1) \quad (D-13)$$

with zeros elsewhere.

The inverse of the \tilde{T} matrix denoted by \tilde{T}^{-1} , which is also needed, is given by

$$[\tilde{T}^{-1}]_{ii} = 1 - \frac{c_{ii}}{\left(\sum_{m=1}^n c_{mm} \right)} \quad (D-14)$$

$$[\tilde{T}^{-1}]_{ij} = \frac{-c_{ii}}{\left(\sum_{m=1}^n c_{mm} \right)} \quad (D-15)$$

$$[\tilde{T}^{-1}]_{nj} = \frac{1}{\left(\sum_{m=1}^n c_{mm} \right)^2} \quad \begin{array}{l} i = 1, \dots, (n-1), \\ j = 1, \dots, n \text{ and } i \neq j \end{array} \quad (D-16)$$

The c 's used in the calculations in Equations (D-11) through (D-16) came from the per-unit-length capacitance matrix \tilde{C} for perfect conductors. The entries in \tilde{C} are given by

$$[\tilde{C}]_{ii} = c_{ii} + \sum_{j=1}^n c_{ij} \quad F/m \quad (D-17)$$

$$\begin{aligned} [\tilde{C}]_{ij} &= -c_{ij} & F/m & & (D-18) \\ i &\neq j \end{aligned}$$

It should be noted that upon careful examination of the calculation of the \tilde{T} and \tilde{T}^{-1} matrices, Equations (D-11) - (D-13) and (D-14) - (D-16), respectively, a numerical problem is apparent*. \tilde{T} has ones in every position except the last column. For typical line parameters, c_{ii} will be on the order of picofarads/meter. Therefore, the elements in the last column will be on the order of 10^{24} ; similarly each element on \tilde{T}^{-1} will be on the order of unity, but the last row will again be on the order of 10^{24} . Therefore, in order to avoid this problem, the last column of \tilde{T}_v can be normalized by α , where α is defined as follows

$$\alpha = \max \left[c_{ii} \sum_{m=1}^n c_{mm} \right] \quad (D-19)$$

(Each column of \tilde{T} is an eigenvector and hence can be arbitrarily normalized).

However, this normalization in turn requires that \tilde{T}^{-1} also be fixed; this can be accomplished by multiplying all entries in the last row of \tilde{T}^{-1} by α . Now all entries in \tilde{T} and \tilde{T}^{-1} are on the order of unity.

Thus, the diagonalization of the matrix product $\tilde{Y} \tilde{Z}$ can be performed using the similarity transform \tilde{T} given above, modal decomposition may be performed; and, finally, a solution that the multiconductor transmission line equations can be obtained.

*C. R. Paul, private communication.

APPENDIX E

DETERMINATION OF THE INDUCED VOLTAGES SOURCE $\underline{V}_s(x)$ and AND THE INDUCED CURRENT SOURCE $\underline{I}_s(x)$ FOR THE OVERHEAD TRANSMISSION LINE MODEL

In Section II, it is shown that the incident field interaction with the transmission line can be described as:

$$\hat{V}_s(x_i) = \int_{x_{i-1}}^{x_i} [\phi_{11}(x_i, \hat{x}) \underline{V}_s(\hat{x}) + \phi_{12}(x_i, \hat{x}) \underline{I}_s(\hat{x})]_i d\hat{x} \quad (E-1)$$

$$\hat{I}_s(x_i) = \int_{x_{i-1}}^{x_i} [\phi_{21}(x_i, \hat{x}) \underline{I}_s(\hat{x}) + \phi_{22}(x_i, \hat{x}) \underline{V}_s(\hat{x})]_i d\hat{x} \quad (E-2)$$

where

$$V_{sj}(\hat{x}) = j\omega\mu \int_0^d H_{zj}^{inc}(y, x) dy \quad (E-3)$$

$$I_{sj}(\hat{x}) = Y \int_0^d E_{yj}^{inc}(y, x) dy \quad (E-4)$$

and

$$\phi_{11} = \frac{1}{2} \underline{Y}^{-1} \underline{T} (e^{\underline{Y}(x_i - \hat{x})} + e^{-\underline{Y}(x_i - \hat{x})}) \underline{T}^{-1} \underline{Y} \quad (E-5)$$

$$\phi_{12} = -\frac{1}{2} \underline{Y}^{-1} \underline{T} (e^{\underline{Y}(x_i - \hat{x})} - e^{-\underline{Y}(x_i - \hat{x})}) \underline{T}^{-1} \quad (E-6)$$

$$\phi_{21} = -\frac{1}{2} \underline{T} (e^{\underline{Y}(x_i - \hat{x})} - e^{-\underline{Y}(x_i - \hat{x})}) \underline{Y}^{-1} \underline{T}^{-1} \underline{Y} \quad (E-7)$$

$$\phi_{22} = \frac{1}{2} \underline{T} (e^{\underline{Y}(x_i - \hat{x})} + e^{-\underline{Y}(x_i - \hat{x})}) \underline{T}^{-1} \quad (E-8)$$

Upon substituting Equations (E-3) through Equation (E-8) into Equations (E-1) and (E-2) and expanding, they become

$$\hat{\underline{V}}_{\underline{s}}(x_i) = \underline{C}_1 \underline{I}_1 + \underline{C}_2 \underline{I}_2 \quad (\text{E-9})$$

$$\hat{\underline{I}}_{\underline{s}}(x_i) = \underline{C}_3 \underline{I}_1 + \underline{C}_4 \underline{I}_2 \quad (\text{E-10})$$

where

$$\underline{C}_1 = j\omega\mu \underline{Y}^{-1} \underline{T} \quad (\text{E-11})$$

$$\underline{C}_2 = \underline{Y}^{-1} \underline{T} \underline{\gamma} \quad (\text{E-12})$$

$$\underline{C}_3 = -j\omega\mu \underline{T} \quad (\text{E-13})$$

$$\underline{C}_4 = -\underline{T} \quad (\text{E-14})$$

and

$$\underline{I}_{1i} = \int_{x_{i-1}}^{x_i} \int_0^d \cosh(\underline{\gamma}(x_i - \hat{x})) \underline{M}_1 \underline{H}_z^{\text{inc}}(y, \hat{x}) dy d\hat{x} \quad (\text{E-15})$$

$$\underline{I}_{2i} = \int_{x_{i-1}}^{x_i} \int_0^d \sinh(\underline{\gamma}(x_i - \hat{x})) \underline{M}_1 \underline{E}_y^{\text{inc}}(y, \hat{x}) dy d\hat{x} \quad (\text{E-16})$$

$$\underline{I}_{3i} = \int_{x_{i-1}}^{x_i} \int_0^d \sinh(\underline{\gamma}(x_i - \hat{x})) \underline{M}_2 \underline{H}_z^{\text{inc}}(y, \hat{x}) dy d\hat{x} \quad (\text{E-17})$$

$$\underline{I}_{4i} = \int_{x_{i-1}}^{x_i} \int_0^d \cosh(\underline{\gamma}(x_i - \hat{x})) \underline{M}_1 \underline{E}_y^{\text{inc}}(y, \hat{x}) dy d\hat{x} \quad (\text{E-18})$$

where

$$\underline{\tilde{M}}_1 = \underline{\tilde{T}}^{-1} \underline{\tilde{Y}} \quad (\text{E-19})$$

$$\underline{\tilde{M}}_2 = \underline{\tilde{Y}}^{-1} \underline{\tilde{T}}^{-1} \underline{\tilde{Y}} \quad (\text{E-20})$$

The terms $\sinh \underline{\tilde{\gamma}}$ and $\cosh \underline{\tilde{\gamma}}$ represent diagonal matrices where

$$[\sinh \underline{\tilde{\gamma}}]_i = \sinh (\gamma_i) \quad (\text{E-21})$$

and

$$[\cosh \underline{\tilde{\gamma}}]_i = \cosh (\gamma_i) \quad (\text{E-22})$$

Making use of Faradays' Law in differential form, then

$$\underline{H}_z^{inc} = \frac{1}{j\omega\mu} \left[\frac{\partial \underline{E}_x^{inc}}{\partial y} - \frac{\partial \underline{E}_y^{inc}}{\partial \hat{x}} \right] \quad (\text{E-23})$$

Upon substituting Equation (E-23) into \underline{I}_1 and \underline{I}_3 and integrating by parts with respect to y and expanding Equations (E-9) and (E-10), using the definition in Equations (E-11) through Equation (E-18), the following expressions for $\underline{V}_s(\hat{x})$ and $\underline{I}_s(\hat{x})$, are obtained:

$$\underline{\hat{V}}_s(\hat{x}) = \underline{\tilde{Y}}^{-1} \underline{\tilde{T}} [\underline{\tilde{M}}] - [\underline{E}_y^{inc}(x_i)] \quad (\text{E-24})$$

$$+ \underline{\tilde{Y}}^{-1} \underline{\tilde{T}} \cosh \underline{\tilde{\gamma}} (x_i - x_{i-1}) \underline{\tilde{T}}^{-1} \underline{\tilde{Y}} [\underline{E}_y^{inc}(x_{i-1})]$$

$$\underline{\hat{I}}_s(\hat{x}) = -\underline{\tilde{T}} [\underline{\tilde{N}}] - \underline{\tilde{T}} \sinh \underline{\tilde{\gamma}} (x_i - x_{i-1}) \underline{\tilde{Y}}^{-1} \underline{\tilde{T}}^{-1} \underline{\tilde{Y}} [\underline{E}_y^{inc}(x_{i-1})] \quad (\text{E-25})$$

where

$$[\underline{E}_{\underline{x}}^{\text{inc}}(\hat{x})]_j = E_{xj}^{\text{inc}}(d_{jo}, \hat{x}) = E_{xj}^{\text{inc}}(0, \hat{x}) \quad (\text{E-26})$$

$$[\underline{E}_{\underline{y}}^{\text{inc}}(x_i)]_j = \int_0^{d_{jo}} E_{yj}^{\text{inc}}(y, x_i) dy \quad (\text{E-27})$$

$$[\underline{E}_{\underline{y}}^{\text{inc}}(x_{i-1})]_j = \int_0^{d_{jo}} E_{yj}^{\text{inc}}(y, x_{i-1}) dy \quad (\text{E-28})$$

$$[\underline{M}]_j = \int_{x_{i-1}}^{x_i} \cosh \gamma_j (x_i - \hat{x}) [\underline{T}^{-1} \underline{Y} \underline{E}_{\underline{x}}^{\text{inc}}(\hat{x})]_j d\hat{x} \quad (\text{E-29})$$


$$[\underline{N}]_j = \int_{x_{i-1}}^x \sinh \gamma_j (x_i - \hat{x}) [\underline{Y}^{-1} \underline{T}^{-1} \underline{Y} \underline{E}_{\underline{x}}^{\text{inc}}(\hat{x})]_j d\hat{x} \quad (\text{E-30})$$

Therefore, the only terms needed to complete the calculation of Equations (E-1) and (E-2) are the terms in Equations (E-26) - (E-30). However, to evaluate Equations (E-26) - (E-30), it is necessary to determine $\underline{E}_{\underline{x}}^{\text{inc}}$ and $\underline{E}_{\underline{y}}^{\text{inc}}$ taking into consideration the effects of reflections off an imperfect (lossy) earth. Thus, $\underline{E}_{\underline{x}}^{\text{inc}}$ and $\underline{E}_{\underline{y}}^{\text{inc}}$ become

$$\underline{E}_{\underline{x}}^{\text{inc}} = \underline{E}_{\underline{xm}}^{\text{inc}} e^{-(\gamma_{\underline{x}} x + \gamma_{\underline{z}} z)} [-2\sinh(\gamma_{\underline{y}} y) + (1 + \Gamma) e^{\gamma_{\underline{y}} y}] \quad (\text{E-31})$$

$$\underline{E}_{\underline{y}}^{\text{inc}} = \underline{E}_{\underline{xm}}^{\text{inc}} e^{-(\gamma_{\underline{x}} x + \gamma_{\underline{z}} z)} [-2\sinh(\gamma_{\underline{y}} y) + (1 + \Gamma) e^{\gamma_{\underline{y}} y}] \quad (\text{E-32})$$

where the incident angles are defined as shown in Figure E-1 and



NOTE: ZERO PHASE REFERENCE TAKEN AT $x = 0, y = 0, z = 0$.

Figure E-1. Definition of the uniform plane wave parameters.

$$\underline{E}_{xm}^{inc} = -\underline{E}_m^{inc} e^{j\phi} (\cos\theta_E \cos\theta_p \sin\phi_p + \sin\theta_E \cos\phi_p) \quad (E-33)$$

$$\underline{E}_{ym}^{inc} = \underline{E}_m^{inc} e^{j\phi} (\cos\theta_E \sin\theta_p) \quad (E-34)$$

$$[\underline{\gamma}_x] = [\underline{\gamma}] \sin\theta_p \sin\phi_p \quad (E-35)$$

$$[\underline{\gamma}_y] = [\underline{\gamma}] \cos\theta_p \quad (E-36)$$

$$[\underline{\gamma}_z] = [\underline{\gamma}] \sin\theta_p \cos\phi_p \quad (E-37)$$

and Γ , the horizontal polarization reflection coefficient, is defined as

$$\Gamma = \frac{\eta_2 \cos\theta_1 - \eta_1 \cos\theta_2}{\eta_2 \cos\theta_1 + \eta_1 \cos\theta_2} \quad (E-38)$$

where η_i , the intrinsic impedance, is defined as

$$\eta_i = \sqrt{\frac{j\omega\mu_i}{\sigma_i + j\omega\epsilon_i}} \quad (E-39)$$

and θ_1 is the angle of incidence and θ_2 is defined to be

$$\theta_2 = \sin^{-1} \left[\frac{j\omega\sqrt{\mu_1\epsilon_1} \sin\theta_1}{\sqrt{-\omega\mu_2\epsilon_2 + j\omega\mu_2\sigma_2}} \right] \quad (E-40)$$

Upon substitution of Equations (E-31) and (E-32) into Equations (E-26)-(E-30), they become

$$[\underline{E}_y^{\text{inc}}(x_i)]_j = [\underline{E}_{ym}^c]_j e^{-(\gamma_{x_i} x_i + \gamma_{z_j} z_j)} \quad (\text{E-41})$$

$$[\underline{E}_y^{\text{inc}}(x_{i-1})]_j = [\underline{E}_{ym}^c]_j e^{-(\gamma_{x_i} x_{i-1} + \gamma_{z_j} z_j)} \quad (\text{E-42})$$

$$[\underline{M}]_j = \sum_{k=1}^N \underline{A}_{jk}^c \quad (\text{E-43})$$

$$[\underline{N}]_j = \sum_{k=1}^N \underline{B}_{jk}^c \quad (\text{E-44})$$

where

$$[\underline{E}_{ym}^c]_j = [\underline{E}_{ym}^{\text{inc}}]_j e^{j\phi} [E_2(0, y_j, -[\underline{\gamma}_y]_j)] \quad (\text{E-45})$$

$$- \Gamma E_2(0, y_j, -[\underline{\gamma}_y]_j)]$$

$$\underline{A}_{jk}^c = \int_{x_{i-1}}^{x_i} \underline{A}_{jk}(\hat{x}) = [\underline{T}^{-1} \underline{\gamma}]_{jk} \underline{E}_{xm}^c [\underline{I}_1 + \underline{I}_2] \quad (\text{E-46})$$

$$\underline{B}_{jk}^c = \int_{x_{i-1}}^{x_i} \underline{B}_{jk}(\hat{x}) = [\underline{\gamma}^{-1} \underline{T}^{-1} \underline{\gamma}]_{jk} \underline{E}_{xm}^c [\underline{I}_1 - \underline{I}_2] \quad (\text{E-47})$$

and

$$\begin{aligned} \underline{E}_{xm}^c &= \underline{E}_{xm}^{\text{inc}} e^{j\phi} [e^{-\gamma_{zk} z_k (-2 \sinh \gamma_{yk} y_k)} + (1 + \Gamma) e^{\gamma_{yk} y_k} \\ &\quad - (1 + \Gamma)] \end{aligned} \quad (\text{E-48})$$

$$\underline{I}_1 = \frac{1}{2} e^{[\underline{\gamma}]_{jj} x_i} E_2(x_{i-1}, x_i, -([\underline{\gamma}]_{jj} + \gamma_{xk})) \quad (\text{E-49})$$

$$\underline{I}_2 = \frac{1}{2} e^{-[\underline{\gamma}]_{jj} x_i} E2(x_{i-1}, x_i, ([\underline{\gamma}]_{jj} - \gamma_{xk})) \quad (E-50)$$

and finally

$$E2(a,b,k) = \int_a^b e^{ks} ds \quad (E-51)$$

Therefore, substituting Equations (E-41) - (E-44) into Equations (E-24) and (E-25), the distributed source along the transmission line due to the incident field interaction (i.e., evaluate Equations (E-1) and (E-2), taking into account the reflection direct to a lossy ground, can be determined.

APPENDIX F

SOIL PARAMETER IDENTIFICATION TECHNIQUES

The electrical parameters which characterize any medium are:

(1) Conductivity, σ

$$\sigma = \frac{\rho_c q}{m(j\omega + \nu_c)} \quad \frac{m \text{ hos}}{m} \quad (\text{F-1})$$

where

ρ_c = resistivity

q = charge

m = mass of the charge

ω = sinusoidal excitation frequency

ν_c = electron collision frequency

(2) Permittivity, ϵ

$$\epsilon = \epsilon_o (1 + \chi_e) \quad \frac{\text{farad}}{m} \quad (\text{F-2})$$

where

ϵ_o = permittivity of free space

χ_e = electric susceptibility

the complex permittivity

$$\epsilon_c = \frac{\sigma}{j\omega} + \epsilon$$

and the relative dielectric constant

$$\epsilon_r = \epsilon / \epsilon_o$$

(3) Permeability,

$$\mu = \mu_o (1 + \chi_m) \frac{\text{henry}}{\text{m}} \quad (\text{F-3})$$

where

μ_o = permeability of free space

χ_m = proportionality constant, magnetism per applied external field

Typically, soil is non-magnetic (i.e., low iron ore content) and its permeability is that of free space, $\mu = \mu_o$. Thus, the soil parameters of interest to this study are the conductivity, σ , and the permittivity, ϵ . The determination of these two parameters for any given soil will be a function of (1) frequency (2) hydration, and (3) ionization.

The frequency range of interest to this study is 100 Hz to 500 MHz. Thus we must find a method of determining σ and ϵ over this frequency range.

The hydration is a function of the climate and current weather conditions. Thus the parameters σ and ϵ must be determined for the entire range of hydration expected in the region of interest.

Finally, the ionization is a function of the mineral content of the soil. There will be a natural value of σ and ϵ for a region due to the mineral content. If desired though, the σ and ϵ may be changed by altering the chemical (mineral) content of the soil.

The changes in σ and ϵ of soil for variations in frequency, water content, and ion content are shown in Figures F-1, F-2, and F-3. Increasing the frequency of excitation will increase the soil's σ and decrease ϵ , all other parameters held constant. Increasing the water content of the soil will increase σ and ϵ . Increasing the ion content, by adding earth salts, will increase the σ of the soil [F-3]. (This technique is used by utilities to lower tower footing resistance to earth.)




Figure F-1. Conductivity of soil versus frequency for various volume percent of water.




Figure F-2. Soil dielectric constant versus frequency for various volume percent of water.




Figure F-3. Soil resistivity versus salt content.

Properties of soil have been researched for many years [F-4]. Typical soil parameters for given conditions are listed in Table F-1, F-2, and F-3. From these tables a general range of values are:

$$3 \leq \epsilon_r \leq 24$$

$$0.5 \leq \sigma \leq 30 \text{ mmho/m}$$

Survey of Techniques

Ground parameter measurement techniques fall into two major categories, depending on the location of the tests [F-5]. These are:

- (1) Laboratory
- (2) In-Situ

As expected, the laboratory tests will yield the more accurate measurement of the constituents of a given soil sample, but may not reflect the environment from which the sample came.

The laboratory methods are:

- (1) Parallel Plate Capacitor
- (2) Coaxial Transmission Line
- (3) Resonant Cavity

The In-Situ tests, which are carried out in the field, will measure the characteristics of a greater volume of soil. These tests will yield parameters which will be more representative of the site conditions especially if the soil in the area is non-homogeneous. The In-Situ measurements will not be as accurate, per sample, as the laboratory tests.

The In-Situ methods are:

- (1) Four Probe
- (2) Two-Loop
- (3) Wave Tilt
- (4) Field Decay
- (5) Coaxial In-Situ
- (6) Resonant Antenna

Table F-1. Low frequency electrical characteristics of various types of soils [F-4].

| Type of Terrain | Relative Dielectric Constant | Conductivity (mmho/m) |
|---|------------------------------|-----------------------|
| Fresh Water | 80 | 1 |
| Sea water, minimum attenuation | 81 | 4640 |
| Pastoral, low hills, rich soil typical of Dallas, Texas, Lincoln, Nebraska, areas | 20 | 30 |
| Pastoral, low hills, rich soil typical of Ohio and Illinois | 14 | 10 |
| Flat country, marshy, densely wooded, typical of Louisiana near Mississippi River | 12 | 7.5 |
| Pastoral, medium hills and forestation, typical of Maryland, Pennsylvania, New York, exclusive of mountainous territory and seacoasts | 13 | 6 |
| Pastoral, medium hills and forestation, heavy clay soil, typical of central Virginia | 13 | 4 |
| Rocky soil, steep hills, typical of New England | 14 | 2 |
| Sandy, dry, flat, typical of coastal country | 10 | 2 |
| City, industrial areas, average attenuation | 5 | 1 |
| City, industrial areas, maximum attenuation | 3 | 0.5 |

Table F-2. Dielectric and conductivity properties of various terrain at Selected wavelengths [F-4].

| | | $> 3_m$ | 10 cm | | 3 cm | | 1 cm | |
|---|---|-----------------------|--------------|--------------|--------------|---------------|--------------|----------|
| | ϵ_r with respect to vacuum | σ^a (mho/m) | ϵ_r | σ | ϵ_r | σ | ϵ_r | σ |
| Sea water | 80 | 1-5 | 69 | 6.5 | 65 | 16 | 22 | 50 |
| Fresh water | 80 | 0.00-0.1 | | | | | | |
| Humid soil, clay | 30 | 0.01-0.02 | 24 | 0.6 | | | | |
| Fertile cultivated soil | 15 | 0.005 | | | | | | |
| Grass, meadow, race courses, sports grounds | | | 3-6 | 0.05 0.11 | | | | |
| Rocky ground | 7 | 0.001 | | | | | | |
| Urban areas, large towns | 5 | 0.001 | | | | | | |
| Dry soil | 4 | 0.01 | | | | | | |
| Very dry soil, deserts | 4 | 0.001-0.0001 | 2 | 0.03 | about 3 | 0.007 -0.1 | | |

Table F-3. Dielectric properties of earth media at selected frequencies [F-4].

| Material | Composition | Temp. ($^{\circ}$ C) | 10^3 | 10^6 | 10^8 | 10^9 |
|----------|---------------------------------|--------------------------|--------|--------|--------|--------|
| Soil | Sandy dry | 25 | 2.91 | 2.59 | 2.55 | 2.55 |
| Soil | Loamy dry | 25 | 2.83 | 2.53 | 2.48 | 2.44 |
| Ice | From pure distilled water | -12 | | 4.15 | 3.45 | 3.20 |
| Snow | Freshly fallen | -20 | 3.33 | 1.20 | 1.20 | 1.20 |
| Snow | Hard-packed followed by rain | -6 | | 1.55 | | 1.5 |

Capacitor Method

As the name implies, this method is based on measuring the dielectric in the volume of a standard parallel plate capacitor. The capacitor with an air dielectric is connected to a capacitance bridge and the capacitance, C_0 , and conductance, G_0 , are noted. A right circular disc made from the soil sample is then placed between the plates and the capacitance, C , and conductance, G , are again measured. The complex permittivity of the sample can then be computed as follows:

$$\epsilon^* = \epsilon' - j\epsilon'' \quad (F-4)$$

with

$$\epsilon' = 1 + \Delta C/C_0$$

where

$C_0 = \epsilon_0 A/d$ is the capacitance of the sample volume with no sample in place.

ΔC = the change in capacitance due to sample insertion

ΔG = the change in conductance due to sample insertion

The Capacitor Method may be used over a wide range of frequencies from .01 Hz to 1 GHz. However, different measurement apparatus must be employed for different frequency ranges [F-6].

Transmission Line Method

A coaxial transmission line terminated with the soil sample and short-circuited can be used to determine the dielectric constant of the sample. A traveling probe inserted in the line is used to find the first null from the sample (see Figure F-4). From this position, d_2 , and the VSWR of the probe, the impedance of the sample is determined via a Smith Chart. The propagation constant, γ , is then calculated from




Figure F-4. Transmission line method for determining soil properties.

$$Z = (j \omega \mu_0 / \gamma) \tanh(\gamma d_2) \quad (F-5)$$

Once γ has been determined, the dielectric constant ϵ^* may be calculated from

$$\gamma^2 = k_c^2 - \epsilon^* \omega^2 / c^2 \quad (F-6)$$

where

k_c = cutoff wave number
 c = speed of light.

This method is similar to the capacitor methods and has similar problems of air gap (between sample and conductors) flux fringing. The gaps can be filled with conducting epoxy for more accurate measurements.

Resonant Cavity Method

A cavity resonator in the TE_{01} mode can conveniently measure the relative dielectric constant, ϵ_r , of a sample in the range of 1 to 100. Either a disk or a rod type sample may be used (see Figure F-5)[F-7]. The same equations that are used for the transmission line method are applied, where d is now the length from the cavity wall to the sample.

Four Probe Method

The most common of the In-Situ methods is the four-probe method. With this method, four electrodes are placed in the earth in a specific pattern (see Figure F-6 for typical geometries) [F-7]. Two of the probes are transmitters (current injectors) and two of the probes are receivers (voltage probes). This method works well for low frequencies where induction effects and attenuation can be neglected. The resistance of the soil can be determined from V , I , and the geometry and spacing of the probes. This is the typical method used to determine the DC (low frequency) impedance of a ground circuit (see Figure F-7).







Figure F-5. Resonant cavity method for determining soil parameters.



(a) WENNER ARRAY



(b) ELTRAN ARRAY



(c) RIGHT-ANGLE ARRAY

Figure F-6. Commonly used four-probe arrays.




Figure F-7. Electrode resistance versus probe spacing.

Two-Loop Method

The measurement of the mutual impedance between two above ground loops allows σ and ϵ of the transversed earth to be estimated. This method is used extensively in ground conductivity surveys and in geophysical prospecting. The technique works in the 0.1 to 21 MHz range and is capable of measuring conductivities from 10^{-4} to 2×10^{-1} mho/m and relative dielectric constants of 5 to 25. The test setup for swept frequency measurements is shown in Figure F-8; typical loop orientations are shown in Figure F-9. Reference F-8 presents the theory of this method and gives typical curves relating loop impedance to ground conductivity.

Wave Tilt Method

The tilt of an EM wave near the ground between transmitting and receiving antennas, a moderate distance apart (see Figure F-10), is determined by soil properties and the frequency of the signal. By finding the tilt angle, θ , of a vertically polarized wave, the conductivity and dielectric constant of the ground can be calculated from the following equation [F-4]:

$$\tan^2 \theta \approx \frac{\epsilon_r + \sqrt{\left[\epsilon_r^2 + \frac{(18 + \sigma)^2}{f} \right]}}{2 \left[\epsilon_r^2 + \frac{(18 \sigma)^2}{f} \right]} \quad (\text{F-7})$$

For high frequencies, $(18\sigma)^2 / f$ will be small and Equation (F-7) becomes

$$\tan^2 \theta \approx \frac{1}{\epsilon_r} \quad (\text{F-8})$$

This method has proven effective at frequencies from 100 kHz to 10 MHz for ground conditions of $\sigma = 10^{-4}$ to 10^{-2} mho/m and $\epsilon_r = 10$ to 40. The equipment required to perform the test is a transmitter and a receiver. The receiving antenna must have an angular scale and be capable of rotating about the horizontal axis. The receiving antenna can measure the tilt angle





Figure F-8. Two-loop method for determining soil parameters.



(a) HORIZONTAL MAGNETIC DIPOLE TRANSMITTER CASES



(b) VERTICAL MAGNETIC DIPOLE TRANSMITTER CASES

Figure F-9. Loop orientations for two-loop method for determining soil parameters.




Figure F-10. Illustration of wave tilt method of determining soil parameters.

directly by rotating to find the minimum received signal, at which point the antennas will be perpendicular to the E field.

Field Intensity Method



This is a widely used method for determining ground conductivity. Field strength is measured as a function of distance from a transmitter and compared with computed field intensities for different values of ground constants. The data are then correlated, and the ground conductivity determined. This method works well in flat, homogeneous regions with a smooth field decay.

Coaxial In-Situ

This method employs a specially built [F-9] coaxial line with a hollow end which is inserted directly into the soil. The line is removed from the ground with soil sample intact. The EM properties of the soil can then be determined from the open circuited lossy coaxial transmission line [F-10]. This method is similar to the classical laboratory method of the short circuited coaxial transmission line, and the same equations are used. The reliable frequency range is 300 to 4000 MHz. However, the method could be adapted to lower frequencies by using a larger diameter coaxially line and an impedance bridge rather than a VSWR meter.

Resonant Linear Antenna Method

The resonant linear antenna is used as a probe to measure the EM properties of soil [F-11]. The properties are determined from the length of the antenna and the input impedance at resonance. The equipment for making the measurement of input impedance is a vector voltmeter with voltage and current probes delicately inserted into the coaxial line feeding the linear antenna (see Figure F-11). An experimental test setup is depicted in Figure F-12. This method of soil parameter identification has proved useful in geological surveying and can be used over the frequency range of interest.



(b) ADMITTANCE MEASURING EQUIPMENT

Figure F-11. Coaxial in-situ method for measuring soil parameters.




Figure F-12. Illustration of electrode layout of the linear antenna method for determining soil parameters.

APPENDIX F

REFERENCES

- F-1. Longmire, L., and Smith, K. S., "A Universal Impedance for Soils," Missions Research Corporation, Santa Barbara, CA, DNA 3788T AD-A025759, Oct. 1975.
- F-2. "Getting down to earth . . .", James G. Biddle Co., Plymouth Meeting, Pennsylvania 19462, October 1970.
- F-3. Scott, H., Carroll, D., and Cunningham, R., "Dielectric Constant and Electrical Conductivity Measurements of Moist Rock: A New Laboratory Method," Journal of Geophysical Research, Vol. 72, No. 20 Oct. 15, 1967 pp, 5101-5115.
- F-4. Kovattana, T., "Electrical Constant of Central, Eastern, and Northeastern Thailand," STR No. 29, Contract DA 36-039AMC-00040(E), Stanford Research Institute, Palo Alto, CA, February 1967.
- F-5. Bussey, H. E., "Measurement of RF Properties of Materials-A Survey", Proceedings of the IEEE, Vol. 55, No. 6, June 1967, pp. 1046-1053.
- F-6. Collett, L. S., and Katsube, T. J., "Electrical Parameters of Rocks in Developing Geophysical Techniques," Geophysics, Vol. 38, No. 1, Feb. 1973, pp. 76-91.
- F-7. Lytle, R. J., "Measurements of Earth Medium Electrical Characteristics: Techniques, Results, and Applications," Lawrence Livermore Laboratory, EMP Sensor and Simulation Note No. 188, Kirtland AFB, Albuquerque, NM, Nov. 12, 1973.
- F-8. Lytle, R. J., Laine, E. and Lager, D., "Determination of the IN SITU Ground Conductivity and Relative Dielectric Constant Via the Two-Loop Method Using Swept Frequency Excitation," AFWL EMP Sensor and Simulation Note No. 187, Kirtland AFB, Albuquerque, NM, Aug. 8, 1972.
- F-9. Hipp, J. E., "'IN SITU' EM Soil Properties Measurement: Instrumentation, Theory, and Method," Southwest Research Institute, San Antonio, TX AD-784282, June 7, 1974.
- F-10. Hipp, J. E., "Soil Electromagnetic Parameters as Functions of Frequency Soil Density, and Soil Moisture," Proceedings of the IEEE, Vol. 62, No. 1, Jan. 1974, 98-103.
- F-11. Smith, G. A., and King, R. W. P., "The Resonant Linear Antenna as a Probe for Measuring the In Situ Electrical Properties of Geological Media", Journal of Geophysical Research, Vol. 79, No. 17, June 10, 1974, pp. 2623-2628.

DISTRIBUTION LIST

DEPARTMENT OF DEFENSE

Commander-in-Chief, Pacific
5 cy ATTN: C3SRD

Defense Communications Agency
ATTN: WWMCCS Sys Engr

Defense Communications Agency
ATTN: Commander

Defense Communications Engineer Ctr
ATTN: Code R720, C. Stansberry

Defense Intell Agency
ATTN: DT, Sci-Tech Intell

Defense Nuclear Agency
ATTN: RAEF
ATTN: RAAE
ATTN: NATA
4 cy ATTN: TITL

Defense Tech Info Ctr
12 cy ATTN: DD

Deputy under Secretary of Defense
Comm, Cmd, Cont & Intell
ATTN: Telecomm Systems
ATTN: Programs & Resources
ATTN: Assistant Director (Sys)
ATTN: Surveillance & Warning Sys

Field Command
Defense Nuclear Agency
Lawrence Livermore Lab
ATTN: FC-1

Field Command
Defense Nuclear Agency
ATTN: FCTT, G. Ganong
ATTN: FCTT, W. Summa
ATTN: FCTXE
ATTN: FCPR

Joint Chiefs of Staff
ATTN: GD10, J-5, Nuc & Chem Div
ATTN: SAGA
ATTN: C3S, Evaluation Ofc, (HD00)
ATTN: J-3, WWMCCS & Telecommunications

Joint Strategic Connectivity Staff
ATTN: JCC, A. Buckles

Joint Tactical Comm Ofc
ATTN: TT-E-SS

National Central Security Svc, Pacific Area
ATTN: Central Sec Serv, Pac Area

National Communications system
ATTN: NCS-TS

National Security Agency
ATTN: S-15
ATTN: R-52

DEPARTMENT OF DEFENSE (Continued)

Office of the Secretary of Defense
Net Assessments
ATTN: Military Assistants

US National Military Representative, SHAPE
ATTN: Surv Sect

Under Secretary of Defense for Rsch & Engrg
ATTN: DEPUNSEC, C31-Strategic & C2 Sys
ATTN: Strategic & Space Sys (OS)
ATTN: DEPUNSEC Com Sys
ATTN: Strat & Theater Nuc Forces, B. Stephan

DEPARTMENT OF THE ARMY

Defense Communications Sys
ATTN: DRCPM-COM-W-D

Deputy Chief of Staff for Rsch Dev & Acq
ATTN: DAMA-CSS-N

Headquarters
Department of the Army
ATTN: DAMO-TCV-A

Harry Diamond Labs
ATTN: 00100 Commander/Tech Dir/Div Dir
ATTN: DELHD-TA-L, 81100
ATTN: Chief Div 30000
ATTN: Chief Div 20000
ATTN: Chief Div 10000
ATTN: DELHD-NW, J. Bombardt, 20000
ATTN: Chief Div 40000
ATTN: Chief Div 50000
ATTN: Chief 21500
ATTN: DRDEL-CT
2 cy ATTN: Chief 21000
2 cy ATTN: Chief 22000
3 cy ATTN: Chief 20240

Multi Service Comm Sys
ATTN: DRCPM-MSCS-APB, M. Francis

US Army Communications Cmd
ATTN: CC-OPS-WR

US Army Communications Sys Agency
ATTN: CCM-AD-LB
ATTN: CCM-RD-T
ATTN: CCM-AD-SV

US Army Materiel Dev & Readiness Cmd
ATTN: DRXAM-TL

US Army Nuclear & Chemical Agency
ATTN: Library

US Army Western Cmd
ATTN: Communications Electronics Div

DEPARTMENT OF THE NAVY

Naval Electronic Sys Cmd
ATTN: PME, 117-20
ATTN: Tech Library

Headquarters
Naval Material Cmd
ATTN: 08DEL, N. Jackson

Naval Ocean Sys Ctr
ATTN: Code 4471

Naval Postgraduate School
ATTN: Code 1424, Library

Naval Rsch Lab
ATTN: Code 2627

Naval Sea Sys Cmd
ATTN: SEA-6431

Naval Security Group Cmd
ATTN: G83

Naval Shore Electronics Engrg
ATTN: D. Koide

Naval Surface Weapons Ctr
ATTN: Code F30
ATTN: Code F32

Naval Telecommunications Cmd
ATTN: Deputy Director Systems

NAVCAMS, Eastpac
ATTN: Commander

NAVCAMS, Westpac
ATTN: Commander

Office of the Deputy Chief of Naval Ops
ATTN: NOP 98
ATTN: OP 94

Strategic Sys Project Ofc
ATTN: NSP-43

DEPARTMENT OF THE AIR FORCE

Air Force Communications Cmd
ATTN: XOT

Air Force Electronic Warfare
ATTN: XRX

Air Force Ofc of Scientific Rsch
ATTN: J. Allen

Air Force Weapons Lab
ATTN: SUL

Air University Library
ATTN: AUL-LSE

DEPARTMENT OF THE AIR FORCE (Continued)

Assistant Chief of Staff
Studies & Analyses
ATTN: AF/SA

Deputy Chief of Staff
Rsch, Dev, & Acq
ATTN: AFRDS, Space Sys & C3 Dir

Deputy Chief of Staff
Operations and Plans
ATTN: AFXOK, C2 & Telecom

Foreign Technology Div
ATTN: NIIS, Library

Pacific Air Forces
ATTN: Communications Electronics

Pacific Communications Area
ATTN: Comm Electronics Eng

Rome Air Dev Ctr
ATTN: TSLD

Strategic Air Cmd
ATTN: NRI-STINFO, Library
ATTN: XPFS

Headquarters
United States Air Force
ATTN: SAS

OTHER GOVERNMENT AGENCIES

Central Intelligence Agency
ATTN: OSR/SE/C

Federal Emergency Management Agency
ATTN: Office of Rsch, NPP, J. Hain

DEPARTMENT OF DEFENSE CONTRACTORS

American Telephone & Telegraph Co
ATTN: W. Edwards

BDM Corp
ATTN: L. Jacobs
ATTN: W. Sweeney

Boeing Co
ATTN: R. Scheppe, MS 9F-01

Booz-Allen & Hamilton, Inc
ATTN: D. Durgin

EG&G Wash Analytical Svcs Ctr, Inc
ATTN: A. Bonham

Horizons Technology, Inc
ATTN: R. Lewis

DEPARTMENT OF DEFENSE Contractors (Continued)

Georgia Institute of Technology
Attention Res & Sec Coord for:
2 cy ATTN: D. Acree
2 cy ATTN: G. Melson
2 cy ATTN: D. Millard
6 cy ATTN: H. Denny

Institute for Defense Analyses
ATTN: Classified Library

IRT Corp
ATTN: R. Stewart
ATTN: B. Williams

JAYCOR
ATTN: R. Schaeffer
ATTN: R. Poll

Kaman Tempo
ATTN: DASIAC

ORI, Inc
ATTN: R. Hendrickson, Crystal Square 2

Pacific-Sierra Rsch Corp
ATTN: H. Brode, Chairman SAGE

R & D Associates
ATTN: Library

DEPARTMENT OF DEFENSE CONTRACTORS (Continued)

R & D Associates
ATTN: P. Haas
ATTN: W. Karzas
ATTN: W. Graham

Rockwell International Corp
ATTN: G. Morgan

Science & Engrg Associates, Inc
ATTN: B. Gage
ATTN: V. Jones

SRI International
ATTN: A. Grant
ATTN: E. Clark
ATTN: E. Vance
ATTN: A. Whitson

Sylvania Systems Group
ATTN: R. Steinhoff

Systems Rsch & Applications Corp
ATTN: S. Greenstein

TRW Electronics & Defense Sector
ATTN: J. Brossier

TRW Electronics & Defense Sector
ATTN: Librarian

