

PROJECT ADMINISTRATION DATA SHEET

ORIGINAL



REVISION NO. _____

Project No. A-3198DATE 6/25/82Project Director: ~~Jerry Jackson~~ R. LannSchool/Lab EDL/BDDSponsor: Synergic Resources CorporationType Agreement: Subcontract Agreement No. 7105 -1 (under DOE Prime #DE-AC79-82BP30593)Award Period: From 2/1/82 To 12/31/82 (Performance) _____ (Reports)Sponsor Amount: \$36,7633/1/83

Contracted through:

Cost Sharing: _____

GTRI/~~GTR~~Title: Development of Fuel Choice and Floor Space Models for BPA's Commercial ModelADMINISTRATIVE DATAOCA Contact Faith G. Costello x4820

1) Sponsor Technical Contact:

Craig McDonaldSynergic Resources Corp.One Bala Cywyd Plaza (Suite 630)Bala - Cynwyd, PA 19004

2) Sponsor Admin/Contractual Matters:

Sharon H. LimayeDirector, Finance and AdministrationSynergic Resources Corp.One Bala Cynwyd Plaza (Suite 630)Bala - Cynwyd, PA 19004(215) 667-2160Defense Priority Rating: n/aSecurity Classification: n/aRESTRICTIONSSee Attached (DOE) Gov't Supplemental Information Sheet for Additional Requirements.

Travel: Foreign travel must have prior approval - Contact OCA in each case. Domestic travel requires sponsor approval where total will exceed greater of \$500 or 125% of approved proposal budget category.

Equipment: Title vests with Government, except that items costing less than \$1,000 vest with GIT upon acquisition if prior approval obtained from Sponsor.COMMENTS:

Prime Contract Number from DOE: DE-AC79-82BP30593

COPIES TO:Administrative Coordinator
Research Property Management
Accounting
Procurement/EES Supply Services
ORM OCA 4:781Research Security Services
Reports Coordinator (OCA)
Legal Services (OCA)
LibraryEES Public Relations (2)
Computer Input
Project File
Other GTRI

SPONSORED PROJECT TERMINATION SHEET

Date 4/13/83

Project Title: Development of Fuel Choice and Floor Space Models for BPA's Commercial Model

Project No: A-3198

Project Director: Robert B. Lann

Sponsor: Synergic Resources Corporation

Effective Termination Date: 3/1/83

Clearance of Accounting Charges: 3/1/83

Grant/Contract Closeout Actions Remaining:

- ☒ Final Invoice and Closing Documents
- ☐ Final Fiscal Report
- ☒ Final Report of Inventions
- ☒ Govt. Property Inventory & Related Certificate
- ☐ Classified Material Certificate
- ☐ Other _____

Assigned to: EDL/BDD (~~School~~/Laboratory)

COPIES TO:

Administrative Coordinator
Research Property Management
Accounting
Procurement/EES Supply Services

Research Security Services
Reports Coordinator (OCA)
Legal Services (OCA)
Library

EES Public Relations (2)
Computer Input
Project File
Other Lann



ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
 A Unit of the University System of Georgia
 Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
 for BRA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
 to
 June 30, 1982

(Covers period from start date to formal award date)

- I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours *</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Jerry Jackson	182	\$30.95	\$5,633.55
Robert Lann	342	19.65	6,730.01
Research Assistant	24	6.00	142.80
Secretarial	4	6.68	28.95
Subtotal			12,535.31
b. Retirement			1,432.93
c. Travel			0.00
d. Computer			1,280.90
e. Other Expenses			32.92
f. Overhead			8,405.14
Total			\$23,687.20

III. Summary of Progress:

Task 2

A copy of the most recent version of the commercial sector energy demand forecasting model has been made available to BPA.

Task 3

The preliminary version of the new fuel choice algorithm has been encoded and is contained in the model made available to BPA along with

* Hours are rounded

parameter estimates for 8 regions and 2 weather zones in the PNW region. Continuing examination of the behavior of the simulation model and its sensitivity to distribution parameters is being conducted.

Task 4

The floor space forecasting model has been completed for the PNW region and is encoded in the model. The parameter estimates of the model have been included in the data sets mentioned in Task 3. The examination of the three approaches to floorspace forecasting is completed. Due mostly to the severe data problems encountered for developing approaches a. and b., approach c. was decided on and incorporated in the model. It should be noted that the coding necessary to implement approaches a. or b. has been incorporated in the model so that in future when and if the data issues are resolved either of the other two approaches can easily be incorporated in the simulation model.

A-3198



ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
A Unit of the University System of Georgia
Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period

July 1982

I This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours*</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Research Assistant	12	6.00	72.00
b. Retirement			0.00
c. Travel			0.00
d. Computer			409.06
e. Other Expenses			1.56
f. Overhead			227.80
Total			710.42

No labor was expended by key personnel in July. The hours for the research assistant involved tabulation of results from simulation runs.

*Hours are rounded



Georgia Institute of Technology

ENGINEERING EXPERIMENT STATION

ATLANTA, GEORGIA 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
August 1982

I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours*</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Robert Lann	33	19.65	642.00
Secetarial		6.68	2.68
b. Fringe Benefits			133.03
c. Travel			977.59
d. Computer			307.50
e. Other Expenses			87.78
f. Overhead			<u>1,015.07</u>
Total			3,165.65

III. Summary of Progress:

Task 3

Additional simulation analysis was performed to examine the behavior of the fuel share/efficiency choice algorithms.

*Hours are rounded



A-3198

ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
A Unit of the University System of Georgia
Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
September 1982

I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Research Assistant	4.5	6.00	27.00
Secetarial	1.2	6.68	8.02
b. Fringe Benefits			.54
c. Travel			0.00
d. Computer			83.11
e. Other Expenses			218.94
f. Overhead			159.35
Total			<u>496.96</u>

ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
A Unit of the University System of Georgia
Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
October 1982

I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Robert Lann	40.8	19.65	802.50
Secetarial	0.9	6.68	6.01
b. Fringe Benefits			166.76
c. Travel			0.00
d. Computer			89.93
e. Other Expenses			57.24
f. Overhead			529.79
Total			<u>1,652.23</u>

III. Summary of Progress:

Task 4

In response to your letter of October 20, 1982 and phone conversation previous to the letter, I spent one week in October on additional work for Task 4 as outlined in your letter. The results of this effort were mailed to SRC on November 3, 1982.



ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
A Unit of the University System of Georgia
Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
December 1982

- I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours</u>	<u>Rate</u>	<u>Cost</u>
d. Computer			12.48
e. Other Expenses			.54
f. Overhead			6.15
Total			<u>19.17</u>

III. Summary of Progress:

Task 6: Documentation

A draft of the final report will be completed and sent to SRC for review by the end of January 1983.



ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
A Unit of the University System of Georgia
Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
January 1983

I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Robert Lann	123	19.65	2,407.50
Secretarial	10	6.68	66.81
b. Fringe Benefits			547.92
c. Travel			0.0
d. Computer			21.63
e. Other Expenses			2.46
f. Overhead			1,437.86
Total			4,484.18

III. Summary of Progress:

Task 6: Documentation

A draft of the final report has been completed and sent to SRC for review.



ENGINEERING EXPERIMENT STATION
Georgia Institute of Technology
A Unit of the University System of Georgia
Atlanta, Georgia 30332

PROGRESS REPORT

Development of Fuel Choice and Floor Space Models
for BPA's Commercial Model

Sub-Contract to Synergic Resources Corporation

Report Period
February 1983

I. This progress report covers work expended on subcontract agreement no. 7105-1 (under DOE prime #DE-AC79-82BP30593) with Synergic Resources Corporation.

II. Itemized Expenditures:

	<u>Hours</u>	<u>Rate</u>	<u>Cost</u>
a. Labor			
Robert Lann	58	19.65	1,140.76
Secretarial	5	6.68	32.73
b. Fringe Benefits			258.17
c. Travel			0.0
d. Computer			177.84
e. Other Expenses			43.84
f. Overhead			780.38
Total			<u>2,433.72</u>

III. Summary of Progress:

Task 6: Documentation

The final report has been completed and sent to SRC.

DEVELOPMENT OF FUEL CHOICE AND
FLOOR SPACE MODELS FOR BPA'S
COMMERCIAL MODEL

FINAL REPORT

Prepared for

Synergic Resources Corporation
4th & Pike Building, Suite 820
Seattle, WA 98101
February 1, 1983

Prepared by

Jerry R. Jackson
Robert B. Lann

Economic Development Laboratory
Georgia Institute of Technology
Atlanta, Georgia 30332

Table of Contents

	<u>Page</u>
CHAPTER 1 INTRODUCTION.....	1-1
CHAPTER 2 FLOOR SPACE MODEL.....	2-1
Introduction.....	2-1
Discussion of Methodologies.....	2-2
Methodology Selected.....	2-10
Development of Model Parameters.....	2-11
Subroutine Structure.....	2-18
CHAPTER 3 FUEL SHARE MODEL.....	3-1
Methodology.....	3-1
Data Development.....	3-6
Parameter Estimation.....	3-8
Subroutine Structure.....	3-15
REFERENCES.....	i
APPENDIX A Floor Space Subroutine Coding	
APPENDIX B Fuel Share Subroutine Coding	
APPENDIX C Heat Load Simulation Results	

Chapter 1

INTRODUCTION

In February 1982, the Synergic Resources Corporation contracted with Georgia Institute of Technology to improve on two components of a commercial sector end use energy forecasting model, to provide the most recent version of this model and outline model sensitivity and validation exercises for testing the end use model. Georgia Tech's effort was, in fact, a subcontract to a larger effort being performed by Synergic Resources Corporation for the Bonneville Power Administration. The two components of the model Georgia Tech developed were the floor space forecasting module and the space heat fuel share/efficiency choice module.

These new components, most importantly the fuel share module, were incorporated into the latest version of a commercial end use model developed at Oak Ridge National Laboratory in 1976. The model has gone through phases of development at different locations so that no one version incorporated all of the enhancements. The version delivered to Synergic Resources Corporation does incorporate the improvements from past efforts as well as new coding that enhances the analysts ability to operate the model in a variety of settings with a minimum of effort.

The report is organized into four chapters with three appendices that exhibit the FORTRAN code of the two modules to be discussed, and heat load simulation results used to develop parameters for the fuel share/efficiency choice module. Chapter 2 will discuss the floor space methodologies we examined, the chosen approach and the data development performed to operate the module. Chapter 3 will discuss the fuel share component methodology, the data development and requirements, the heat load model simulations, parameter estimation, and the submodule structure of the code.

Chapter 2

FLOOR SPACE SUBMODULE

Introduction

The stock of floor space is a major determinate of future commercial sector energy use. Despite its importance, our knowledge of commercial floor space characteristics and our improvement in forecasting these characteristics has increased at a much slower rate than many other less important variables. The reason for this situation relates to data collected and made available by the F. W. Dodge Company. In 1977, the Energy Information Administration obtained copies of the detailed Dodge data base. It was believed at that time that these data were acceptably complete and would provide a data source for econometric models far superior to any other available data.

Because of unusually long delays in providing these data for further analysis and the more recent budget problems at DOE, these data have not as yet been fully analyzed or used in their detailed form to support a floor space modeling effort (less intensive studies based on aggregate data have been conducted at ORNL and more recently at Battelle Northwest for the Bonneville Power Administration). In spite of the lack of detailed analysis of the Dodge Data, recent evidence indicates a severe underreporting problem in the Dodge data, at least for certain building types and geographic areas. This issue is discussed more fully later in this section.

Consequently, we find ourselves in a situation where the long anticipated use of the "ultimate" data source has inhibited additional research in this area. Fortunately, the recently available data sources that led us to question Dodge data integrity can be used to develop more accurate floor space stock estimates and models than existed previously.

The objectives of our floor space modeling effort are: to develop the most accurate estimates possible of floor space stock by building type and state for our base year (1979), and to develop the most accurate floor space forecasting model possible with existing time and budget constraints. The purpose of this chapter is to document these efforts.

The remainder of this chapter includes a discussion of the conceptual issues considered in our modeling approach and in past studies. Data issues and our empirical estimates are also discussed.

Discussion of Methodologies

The various approaches to modeling future floor space stock (or floor space additions) are related through a general framework that describes the production of commercial services. Floor space is one of the factors used to produce commercial services provided in all of the various commercial sector activities. The amount of floor space used in any building type category depends upon the level of activity in that category. This floor space demand also depends on the prices of the other factors used to produce commercial services (e.g., energy, land, labor). This discussion relates the floor space stock demand to explanatory variables; we may just as easily relate floor space additions to these same variables by focusing on the change in stock demanded from one year to the next.

As is obvious from our discussion above, several estimable floor space relationships can be specified consistent with the commercial services production process. The three most-used relationships include:

1. Stock demand. The stock of floor space (i.e., the services provided by that stock) is typically related to measures of appropriate commercial activity and possibly to other factors such as construction prices.
2. Investment demand. Floor space additions have been empirically related to the prices of inputs in the

commercial services production process and to levels of commercial sector activity.

3. Floor space-per-employee. The relationship between these two factors used in the production of commercial services are used to estimate future floor space stock by utilizing available forecasts of employment.

Each of these approaches has been used successfully in previous studies to forecast floor space stock. Early studies (Jackson (1978), Westinghouse (1975), Arthur D. Little (1974)) used the stock demand approach exclusively. Dodge floor space additions data published in the Statistical Abstract of the United States are sufficient to develop national historical series of aggregate floor space stock. This data development requires assumptions on floor space removals and on an initial floor space stock estimate for some early year as well as an adjustment for limited geographic coverage of several western states prior to the early 1950s. Despite these adjustments and assumptions this approach is generally judged to provide a reasonably accurate time series for limited time spans if the Dodge data coverage is relatively accurate (coverage relates to floor space not number of buildings; thus Dodge's recognition of undercoverage of small buildings is not, by itself, cause for concern). A detailed discussion of this approach is provided in Jackson and Johnson (1978).

More recently Corum developed a much improved floor space stock model at Oak Ridge National Laboratory (Cohn, et al. (1979)). The Corum model, which is currently the most widely used floor space model, makes use of variations in floor space stock across geographic areas at one point in time to relate floor space stock by building type to aggregate variables such as income and population.

Stock demand models reflect stable long-term trends and consequently are less likely to be affected by several years of atypical cyclical influences than the other approaches. Unfortunately, the aggregate nature of data generally available for such studies precludes the successful determination of the influence

of factors such as construction costs, land prices and energy prices. The primary drawback of the stock demand approach is its susceptibility to biases resulting from Dodge coverage problems and the inability to distinguish the impacts of collinear influences (e.g., land prices, capital cost) over time. Since Dodge is the only comprehensive source of time series data, the fortunes of stock demand models are tied to the integrity of the Dodge data.

Investment demand models relate floor space additions to explanatory variables such as construction costs and commercial activity. Despite several attempts, Lann's (1979) study is the only successful investment demand analysis relating to commercial floor space. The advantage of this approach is the potential for determining the impacts of a wider variety of explanatory variables. The disadvantages relate to estimation difficulties arising from the cyclical nature of both floor space additions and explanatory variables. Investment demand models must also rely on Dodge data making them susceptible to the many problems caused by potential systematic biases in the dependent variable, floor space additions. In most cases the time and other resources required to develop a reliable investment demand model represents the greatest drawback in using this approach.

The floor space-per-employee approach is the third major modeling approach. One of the earliest applications of this approach (Jackson (1980)) was prompted because of dissatisfaction with the original ORNL stock demand model. The advantages of this approach include representation of a presumably stable relationship, reliance on non-Dodge data, and the availability of employment forecasts which drive floor space estimates. Disadvantages include the sparsity of non-Dodge floor space stock data and the cyclical nature of the employment series which is one of the two data series required for the ratio estimates. A potentially serious problem is the estimation difficulties faced in estimating temporal changes in the ratio resulting from changing relative prices of the inputs used in producing the

commercial services, changes in marketing and business environments and other factors.

As this brief review makes clear all approaches suffer from several potential deficiencies. In choosing our modeling approach we first ruled out the investment demand model. The immediate reason was our lack of access to the detailed Dodge data required for such analysis; however, even if access were obtained, the time frame for our project was clearly too short to feel positive about the possibility of deriving usable results.

Beyond these immediate considerations, however, we feel that the investment demand approach is unlikely to yield a forecasting model that is as robust as a model derived from one of the other two methods. The out-of-phase cyclical nature of all of the data series involved in such analysis, the role of expectations in the commercial structure investment market, the role of other constraints in determining construction (e.g., failure of local bond initiatives for public buildings), the difficulty encountered in modeling the dynamic character of the market, and the high correlation (both positive and negative) reflected in the explanatory data series often yield models which generate unstable and/or inaccurate forecasts. This problem is inherent in all investment demand models. Poor forecasts of investment in durable goods is a well-recognized culprit in problems exhibited by macro-econometric models of the economy.

One difficulty which must be overcome before a large-scale investment demand modeling approach is undertaken relates to the underreporting problem of the Dodge data. A systematic bias in this data series will result in model parameters that are also biased. As indicated below, this problem is also a major consideration in evaluation of the stock demand approach.

Developing a stock demand model requires data series reflecting the stock of commercial structures by building type. The only feasible data source for developing such a series is the Dodge data. To develop such a series, one must estimate the stock at some point in

time and use Dodge floor space additions data and an assumption on stock removals to work backward (or forward) from the stock estimate. An obvious requirement in developing a data series that differs from the actual only by a random component (as permitted in our estimation technique) is that the Dodge data coverage is complete, or that the undercoverage can be estimated. If one of these two conditions cannot be reasonably satisfied then the potential for biased forecasts is uncertain.

Thus, the choice between the stock demand and floor space-per-employee approach hinges in part on the Dodge coverage problems. One way of assessing this problem is to use publicly available Dodge data to develop national floor space stock estimates and to compare these stock estimates to other sources.

We used our earlier work in Jackson and Johnson (1978) and Jackson (1980) for the Dodge-based floor space stock estimates. The approach used in these studies to develop floor space stock estimates consists of three primary steps including:

1. estimation of the stock of floor space in 1924;
2. summation of annual data on floor space additions (available in published sources for years following 1925);
3. subtraction of a fraction of floor space to account for building removals.

Adjustments were made to the publicly available Dodge data series to compensate for incomplete geographical coverage. Since the pre-1950 construction represents only about one-third of current Dodge-based stock estimates, the impact of uncertainty in the building removal rate and the 1924 stock is diminished. The resulting national Dodge-based floor space stock estimates are given in the third column of Table 2-1 for selected building types for 1979.

We also developed estimates of national floor space stock estimates from two other sources. The first is derived from the DOE Interim survey developed by the Energy Information Administration (1981). Unfortunately, the detailed data tapes are not currently

Table 2-1
Estimates of National Floor Space by Building Types,
1979, 10⁶ ft²

Basic Data Source

<u>Building Type</u>	<u>California Energy Commission</u>	<u>DOE Interim Survey</u>	<u>F.W. Dodge</u>
Office	8,376	7,263	5,809
Retail	7,885	8,891	5,329
Warehouse	5,006	6,327	2,432
Education	6,715	6,142	6,970
Health	1,973	1,387	2,027
Hotel/Motel	1,566	1,856	1,647*
Miscellaneous	6432	10,171	5852
Total	37,953	42,038	30,066
Warehouse Adjustment		-1,321	
Adjusted Total	37,953	40,717	30,066
Total Relative to DOE	.93	1.0	.73**

*Not estimable from national Data; estimate taken from Jackson (1978) as developed at ORNL.

**Calculated without Hotel/Motel category in DOE and Dodge total.

available so some processing of the publicly available data were required to make the data conform to our use. Data are provided by DOE on total nonresidential floor space stock, and size distribution by building type. We assumed that the number of buildings in each of the seven size categories multiplied by the midpoint of the size category would provide estimates reasonably close to those derivable from the detailed tape. The midpoint of the largest open-ended size category was determined in such a way that total nonresidential floor space equalled the DOE estimated total of 54.6 billion square feet. We then converted this nonresidential floor space to conform with our commercial sector definition by subtracting the estimates of residential buildings (included in the survey because of some commercial activity in the building), industrial buildings, and vacant buildings.

A second estimate of national floor space stock was derived from results of a utility survey conducted by California utilities for the California Energy Commission (CEC) in 1978. A total of more than 14,000 usable responses were received representing a response rate of 26%. Floor space stock for our 1979 comparison year was developed by using the CEC estimated 1977 stock and estimated additions and removals for 1978 and 1979.

The 1979 California stock estimates by building type were related to County Business Patterns (CBP) employment SIC categories as indicated in Table 2-2. In some cases it was felt that activity measures other than employment were more appropriately related to floor space stock (see Table 2-3). The resulting floor space-per-employee activity estimates were used with national CBP employment data and other measures of subsector activity to develop national estimates of floor space stock. The DOE and CEC-based national estimates are also presented in Table 2-1. Definitions differ among the three basic sources so that building-specific estimates are not strictly comparable. The DOE Interim results undoubtedly reflect the most accurate estimate of total national floor space because of the sampling and survey approach used. One can argue that the California results may reflect some nonresponse bias because of the incomplete

response. The nature of relationships between floor space and employment is not likely to differ significantly from a California application to a National application.

The following conclusions can be drawn from the data in Table 2-1:

- o When dormitories are accounted for in the CEC data, the CEC and DOE Interim education results are very similar. Dodge estimates are greater, probably representing an underestimate of removals in the 1970s.
- o When nursing home floor space estimates are added to the DOE Interim Health estimates (which exclude nursing homes), the CEC, DOE and Dodge estimates are not significantly different.
- o The CEC and ORNL hotel/motel estimate are very close. The DOE hotel/motel category contains dormitories and nursing homes; when appropriate adjustments are made, the DOE figure appears to be about 60% of the other two.
- o The DOE estimate of warehouse floor space is considerably higher than the CEC or Dodge. This is likely the result of the DOE inclusion of industrial warehouses which was not part of the CEC effort. We have subtracted the difference and adjusted our estimate of the DOE commercial warehouses downward by this amount. The Dodge warehouse estimate is only about one-half of the CEC estimate.
- o A close correspondence exists between food sales floor space in the DOE and CEC surveys. (Not shown in Table 2-1).
- o While the definitions of office buildings are similar for Dodge and CEC figures, the DOE definition classifies many office related activities of federal and state governments to the miscellaneous category.
- o The definitional discrepancies in the retail sector are difficult to determine.
- o Except for the miscellaneous category, the CEC and DOE interim estimates are extremely consistent. This difference

is probably explained by the fact that the Interim sample picks up some utility customers not classified as commercial.

As the last row of Table 2-1 indicates, the Dodge data represent 73% of the DOE interim estimate. The CEC estimates, on the other hand, reflect 93% of the DOE estimate. Consideration of these items led us to the conclusion that the best national estimate of floor space stock by building types is derived by using the CEC based estimates for all building types except miscellaneous which should be adjusted upward by 43% to reflect the more appropriate commercial sector coverage in the DOE survey. The CEC estimates are chosen over the Interim estimates because they are more detailed on a building type basis and because the two sources appear to be very close. Thus the CEC column with a new miscellaneous total of 9,196 and a total floor space stock of 40,717 million square feet reflects our best estimate of the national stock of floor space.

Turning back to our consideration of the floor space stock approach, it appears that the Dodge undercoverage problem is severe enough to significantly impact estimated stock demand model coefficients. Thus, we consider the floor space-per-employee the only feasible approach that can be pursued in this study.

Methodology Selected

Having settled on the floor space-per-employee modeling approach, we can now specify our empirical model. A general form of this relationship can be represented as:

$$S_t = F \cdot e^{r(t - t_0)} \cdot E_t \quad (2-1)$$

where

S = floor space stock

t = forecast period

F = floor space-per-employee in base year period t_0

r = annual rate of growth of F

E = Employment

With sufficient time series data this relationship can be estimated. Our reason for rejecting the stock demand approach was, however, because of the lack of such data. Data requirements are less severe here since we can estimate F for a base year, and E for the forecast period. Thus an estimate of r from some other source can be used, or values of r can be chosen judgmentally and perhaps examined in sensitivity analysis.

It is interesting to note that if we multiply F by the term E_{t_0} and divide E_t by that same term we transform the equation above into

$$S_t = S_{t_0} \cdot e^{r(t-t_0)} \cdot E_t/E_{t_0} \quad (2-2)$$

Thus we may focus our efforts on estimation of floor space stock by building type for the base year and the relative increase in employment in the future. Operationally this form is preferred because it allows development of the floor space stock estimates with measures of activity that are currently available and most accurate but may not be available in a forecasting situation, it simplifies updating the model equation with new data and it is less sensitive to definitional variations between the CBP employment data used to develop S_t from the CEC data and employment forecasts that may be generated based on different data.

As indicated above, development of the empirical model requires estimation of the stock of floor space in the base year (S_{t_0}) and the rate of increase in the relationship between floor space stock and employment (r). The employment variables E_t and E_{t_0} are used in the forecasting mode but are not required in development of the empirical model.

Development of Model Parameters

We develop four models, one for each of the four states in the Pacific Northwest region. We assume that each of the state models

applies equally well to public and private rate pools within the state. We focus on the two primary parameters separately.

Base Year (1979) Floor Space Stock. As indicated in our discussion of the stock demand approach we have adopted the CEC survey data with an adjusted miscellaneous category floor space estimate. A floor space-per-activity relationship developed for the state of California using the estimated stock figures and measures of subsector activity such as county business patterns employment and school enrollment data were used along with the appropriate state level values for the activity measures in the four states to develop state level floor space stock estimates by building type. The activity measures used for the various building types are given in Tables 2-2 and 2-3.

Before presenting the state level estimates we briefly discuss our considerations of one alternative data sources used in developing these parameters. As indicated in the preceding section we reviewed alternative data sources available for parameter development. We reviewed a number of sources such as those developed by General Electric (1978) and Data Resources, Incorporated (1979) which are not discussed here because they either reflected seriously flawed approaches in our estimation or they reflect results very similar to the Dodge-based data presented in the last section.

One alternative data source relating specifically to the Pacific Northwest was provided by Bonneville Power Administration (BPA) from the results of three survey feasibility studies conducted in the Pacific Northwest. Three areas were surveyed including roughly the central city portion of Seattle, the Portland metropolitan area and the tri-cities of Richland, Kennewick and Pasco in southeastern Washington. Data from these surveys on floor space and employment were related to BPA employment series and used to develop estimates of floor space stock by three general building categories. These survey data were also provided by BPA on more detailed building type basis. Approximately 1,300 responses were obtained. After comparing this data source to the others described in the preceding section we decided that the feasibility results presented one potential problem

Table 2-2
Building Type - TWO DIGIT SIC CODE CORRESPONDENCE

<u>Building Type</u>	<u>Corresponding SIC Codes</u>	<u>SIC Code Description</u>
Office	40 - 49	Transportation, Communications, Electric, Gas and Sanitary Services
	60 - 67	Finance, Insurance and Real Estate
	73	Business Services
	81	Legal Services
	83	Social Services
	89	Miscellaneous Services
	90 - 96	Public Administration (except National Security and International Affairs)
Retail	52 - 53	
	55 - 57	Division G (Retail trade) - Except for 54 (Food stores) and 58 (eating and drinking places)
	59	Miscellaneous Retail
	72	Personal Services
	76	Miscellaneous Repair Services
Elementary/Secondary	82	Educational Services
Colleges	82	Educational Services
Hospital	80	Health Services
Grocery	54	Food stores
Restaurant	58	Eating and drinking places
Hotel/Motel	70	Hotels, Rooming Houses, Camps and other Lodging places
Warehouse	50 - 51	Wholesale Trade
Miscellaneous	75	Automotive Repair, Services and Garages
	78	Motion Pictures
	79	Amusement and Recreation Services (except 78)
	84	Museums, Art Galleries, Botanical and Zoological Gardens
	86	Membership Organizations
	97	National Security and International Affairs
	99	Nonclassifiable Establishments

Table 2-3

Activity Measures Used To Develop
State Level Pacific Northwest
Floor Space Stock Estimates

<u>Building Type</u>	<u>Activity Measure</u>
Office	CBP employment; federal and state government employment
Restaurant	CBP employment
Retail	CBP employment
Grocery	CBP employment
Warehouse	CBP employment
Elementary/Secondary	School enrollment
College	Full time college enrollment
Health	Hospital and nursing home bed space
Hotel/Motel	CBP employment
Miscellaneous	Population

that was more difficult to resolve than the problems of the CEC-adjusted data. Since these feasibility surveys were not intended to represent the population of commercial buildings in the Pacific Northwest, several issues must be resolved to develop such population estimates. For instance, to what extent is the Seattle City Light area (the area sampled in the Seattle study) representative of metropolitan Seattle? How representative is the tri-cities areas of nonmetropolitan areas? A detailed resolution of these issues was clearly not feasible in this project. Another important consideration in this evaluation process relates to the likely reduction in sampling error accompanying use of the DOE survey based on over 6,000 responses and the CEC survey of 14,000 commercial establishments.

The 1979 state level floor space stock estimates developed from CEC-adjusted floor space stock estimates and building-specific activity measures are given in Table 2-4. These estimates represent S_{t_0} in the forecasting equation 2-2.

Rate of Growth of Floor Space-per-Employee Ratio (r). The change in the relative use of floor space and employment factors over time is reflected in the variable r of equation 2-2. With sufficient data one could specify r as a function of relative factor prices and transform the extended form of 2-2 into an estimable relationship. As our discussion earlier makes clear, data required to support the econometric estimation of this relationship are not available.

A next best alternative is to develop an estimate of floor space stock (S_t) for an earlier year along with employment series (consistent with series to be used in the forecasting situation) and to estimate the rate of change of the floor space-per-employee estimate over time. Several problems must be considered in pursuing this approach. First one must choose comparison points in time that reflect a period of relative equilibrium. That is a period where employment and floor space stock are likely to reflect the kind of stable growth pattern implicit in forecasting situations. Our base year (1979) and 1965 were chosen as reasonably close to fulfilling

this requirement. Both years are periods of relatively low unemployment and are at the end of periods of stable GNP growth of three years. (Employment figures relate to mid-March of the year, floor space stock relates to end of year estimates.)

Table 2-4

1979 Floor Space Stock Estimates
By State and the Pacific Northwest, 10⁶ ft²

	<u>Washington</u>	<u>Oregon</u>	<u>Idaho</u>	<u>Montana</u>	<u>Pacific Northwest</u>
Office	149.49	95.59	29.40	10.46	284.94
Restaurant	15.64	10.98	3.17	1.22	31.01
Retail	99.64	68.91	20.33	7.17	196.05
Grocery	23.51	15.40	5.48	1.86	46.25
Warehouse	88.24	62.91	22.28	6.09	179.52
Elementary/Secondary	83.91	51.26	21.66	6.47	163.30
College	40.62	23.90	7.75	2.50	74.77
Health	30.18	16.71	5.86	2.80	55.55
Hotel/Motel	24.33	20.87	8.41	3.89	57.50
Miscellaneous	<u>165.21</u>	<u>106.34</u>	<u>37.64</u>	<u>12.08</u>	<u>321.27</u>
Total	720.77	472.87	161.98	54.54	1,410.16

Aggregate building type summaries of national F.W. Dodge reported additions were available from ORNL. The 1979 national floor space stock estimates, the national floor space additions and national employment in the related categories for 1979 and 1965 were used to determine the likely range of rates of change in r. A range was developed because of the uncertainty surrounding the undercoverage of the Dodge data. We assumed two situations: the first represents a best case where Dodge additions are accurately reported from 1966 to 1979, the worst case is where the additions undercoverage equals the estimated stock undercoverage indicated in Table 2-1. 1965 stock was then developed by subtracting the sum of 1966-1979 additions from the 1979 stock. This was performed using reported additions for the best

case, while an adjusted figure based on undercoverage estimates from Table 2-1 was used to inflate additions for the worst case. In both situations the rate of change in the ratio reflects the fact that gross additions (i.e., both new and replacement floor space additions) were used. To convert this gross ratio to the ratio appropriate in the model the impact of replacements must be subtracted. Replacement demand is about .8% on average for most building types in this period.

This distinction is more clearly illustrated with an example. If the ratio of floor space per employee in offices does not increase over this period, we can take the 1965 floor space, add the gross additions and subtract the portion of these additions required to offset removals from the building stock to derive 1979 floor space. Dividing by 1979 employment would yield the same ratio as existed in 1965. If the replacement additions were unknown and in fact reflected 1% of the stock, summing the gross additions, adding to the 1965 stock and dividing by employment would yield a ratio that is about 15% greater than the 1965 ratio with an average annual increase in the ratio of 1%. Thus, rates of increase in the ratio determined from gross additions must be decremented by the rate of replacement: about .8%. The results of such calculations are given in Table 2-5. In most cases the range, especially when adjusted for replacements appears to bracket zero. Assuming a replacement demand of .8% the total floor space range is -1.51 to 1.13 with an average rate of increase of -.19%. Only the warehouse building type exhibits a range entirely in positive numbers.

Some care must be applied when comparing the estimates of Table 2-5 with casual empiricism. First, building categories are somewhat broader than what may come to mind when one reviews the table. Office buildings, for instance, include all office related activities including public administration activities such as courthouses, jails, etc. Even in a narrowly defined sense office buildings appear to have increased their use of floor space per employee at a more moderate rate than anecdotal experience suggests. For instance information in

Armstrong (in Daniels, 1979) yields estimates of an average annual increase of only .8% per year over the 1964 to 1975 period.

Table 2-5

Average Annual Rates of Change in
Gross Floor Space-Per-Employee Ratios
Implied by F.W. Dodge Data

<u>Building Type</u>	Average Annual Rate of Change	
	<u>Minimum</u>	<u>Maximum</u>
Office	-1.11	0.60
Retail	-0.08	2.58
Warehouse	0.85	11.03
Education	-0.05	0.51
Health	-1.52	-1.33
Hotel/Motel - Miscellaneous	-0.75	1.35
Total	-0.71	1.93

It was our conclusion after considering the results of Table 2-5 that rates of change in the building specific ratios are likely to be close to zero and that in the absence of better information to the contrary, it is best to use zero as our best estimate at this point.

Subroutine Structure

In designing the subroutine that would incorporate the methodology for forecasting floor space stock and additions we wanted to allow maximum flexibility for the user. Rather than confining the coding to the chosen floor space-per-employee model discussed above, we wanted to encode enough flexibility to have the model handle any of the three approach's discussed in the methodology section; stock demand, investment demand, and the floor space-per-employee models.

We have encoded subroutine STOK in two sections; one section for dealing with models that forecast floor space stock directly and one section for models that use floor space additions as the dependent

variable. We have included a copy of the subroutine as Appendix A. Definitions for variables that appear in the subroutine are listed below in alphabetical order.

<u>Variable</u>	<u>Definition</u>
ADD	Contains the floor space additions
ALAG	Stores lagged stock or additions
ASTK	Stores first historical year's floor space
CADD	Comparison variable for ALAG selection
CF	Contains the model coefficients
CNO	Comparison variable for ALAG selection
CSTK	Comparison variable for ALAG selection
EP985	Stores survival fractions for ASTK
EXOG	Contains explanatory variable data
F	Stores survival fractions for ADD
FAC	Temporary variable for FSG
FSCH	Logical variable for section selection
FSG	Temporary variable for FSGRTH
FSGRTH	Contains FT2/emp growth rates
LAG	Stores information for ALAG selection
S	Stores forecasted floor space stock

Variable FSCH is used to direct execution to either of the two sections by a logical yes/no test. If the stock section is to be selected for a particular building subsector, L, then FSCH(L) should contain YES, and if the additions section is selected FSCH(L) should contain a NO. Since FSCH contains a value for each building subsector the user can use different sections and therefore different models for each subsector.

Once a section has been selected the LAG variable is used to select a lagged variable option. The choices are 1) a stock lag, 2) an additions lag, and 3) no lagged variable. This feature was included to accommodate the stock demand and investment demand models which often specify a lagged dependent variable in the estimating equation.

Since we have chosen the floor space-per-employee model for all building subsectors, the FSCH variable will contain all YES's. This directs execution of the stock section for each L. The LAG variable will contain all NO's since no lagged variable is used in this model.

Since the stock section is used for this type of model a variable is included in this code section to store the value of r from equation 2-2 above. The growth rate variable FSGRTH stores individual values for each building subsector, allowing the user to specify a declining, constant or growing value for floor space-per-employee for each building subsector individually.

Chapter 3

HVAC FUEL CHOICE/EFFICIENCY CHOICE SUBMODULE

Methodology

Heating, ventilation and air conditioning systems (HVAC) fuel choice and efficiency choice are jointly determined in a process that is structured to provide the average values for these end uses as required in the overall model based on the results of the simulated choices of many firms.

In describing this process, it is easiest to first focus on the choices modeled for an individual firm. Therefore, we first consider the decision process for a firm assuming that the energy use requirements, price expectations and discount rate have already been ascertained for that firm.

Decision Process For a Single Firm. When an HVAC equipment purchase is imminent (when old equipment is "worn out" or when a new building is designed), the decision maker must choose both a fuel type and HVAC characteristics. As demonstrated below, this is properly modeled as a joint decision.

The decision maker must select a system with the efficiency-cost combination that most closely fits the investment criterion used in that firm. The feasible combinations are described by an HVAC production relationship (i.e., the technology based relationship between equipment cost and efficiency) and represented as

$$S = A K^a E^b X^c \quad (3-1)$$

where K = stock of HVAC equipment
 E = energy use
 X = other factors

$A, a, b, c,$ = parameters of the production relationship.

K and E can be related to the other variables as

$$K = A^{-1/a} S^{1/a} E^{-b/a} X^{-c/a} \quad (3-2)$$

$$\text{and} \quad E = A^{-1/b} S^{1/b} K^{-a/b} X^{-c/b} \quad (3-3)$$

Relationships 3-2 and 3-3 indicate the level of capital and energy used for various levels of the other input factors and the level of output, assuming that the most efficient production process is used.

In an attempt to minimize life-cycle-cost of the end use system, decision makers will choose a system whose energy use-capital cost characteristics minimize the following relationship

$$LCC_T = P_{K,T} K + \sum_{t=T}^{T+n} \left[\frac{E P_{E,t} + M_t}{(1+r)^t} \right] \quad (3-4)$$

where LCC_T = life-cycle-cost of the system in current year, T
 P_K = price of capital
 K = quantity of capital
 E = energy use of the system
 P_E = price of energy
 M = maintenance cost of the system
 r = discount rate applied in this investment decision
 n = life of the system

Substituting 3-2 for K in equation 3-4 constrains the life-cycle-cost equation to reflect the production technology. Minimizing this new equation with respect to E gives the life-cycle-cost minimum choice of E . The corresponding K is provided by substituting the resulting value for E in equation 3-2.

This life-cycle-cost minimizing value of E is:

$$\ln E = - \frac{a}{b+a} \ln \sum_{t=T}^{T+n} \frac{P_{E,t}}{(1+r)^t} - \frac{a}{b+a} \ln \frac{a}{b} - \frac{c}{b+a} \ln X + \frac{1}{b+a} \ln S + \frac{a}{b+a} \ln P_K - \frac{1}{b+a} \ln A \quad (3-5)$$

The relationships between the energy use of the system chosen and other variables can be summarized as

$$\frac{\partial E}{\partial P_E} < 0, \frac{\partial E}{\partial r} > 0, \frac{\partial E}{\partial x} < 0, \frac{\partial E}{\partial S} > 0, \frac{\partial E}{\partial P_K} > 0,$$

That is, increases in the discount rate, level of end use services and the price of equipment tends to increase energy use (decrease efficiency). Increases in fuel price or the level of other factors (e.g., structural efficiency) tends to reduce energy use (increase efficiency). The inverse relationship between E and K (equation (3-2)) indicates that increases in each of these variables has just the opposite effect on the level of capital used in producing the end use service.

Thus, given the discount rate (r) used by the firm in making its energy-related investments and the prices expected over the next n years ($P_{E,t}$), we may use equation 3-5 to determine the preferred energy use characteristics (i.e., efficiency) of each system under consideration. Since price expectations vary across fuels and the parameters of equation 3-1 vary to reflect fuel specific system characteristics, the efficiency choice that a firm exhibits will vary by fuel type chosen. Equation 3-5 allows us to estimate that efficiency choice for each fuel specific system as if that system were actually chosen.

The resulting energy use requirement, (E), and corresponding, (K) of each system is used in equation 3-4 to determine which fuel-specific system reflects the least life cycle cost. This minimum life cycle cost option is then chosen by the firm under consideration.

The "other" factors represented by the variable X in equation 3-2 can include lighting levels, the thermal integrity of the structure, occupancy characteristics, equipment loads, etc.

Monte Carlo Approach. The process described above is actually repeated a large number of times in each forecast year, for each building type and building vintage in order to develop an average fuel choice and efficiency choice. Certain characteristics are allowed to vary from firm to firm to represent the actual variation in certain decision factors that influence the values of equation 3-4 and 3-5.

Within each building type, the particular values of fuel price expectations and a discount rate occur with a frequency in our sample of establishments that corresponds to the population frequency. The use of discount rates and price expectations give the simulation its "behavioral" component since the values of these variables are determined in large part by the cost of information, access to capital markets, judgmentally based forecasts of energy market factors and other items that result in actions by commercial establishments that differ from actions expected under a perfectly competitive market scenario.

This Monte Carlo process utilizes prespecified population distributions. Currently, the lower, median, and upper bound distribution parameters are supplied such that 80% of the population values are between the upper and lower bounds and the median value is identical to the median parameter. A Weibull distribution was chosen because, depending on the distribution parameter values, the Weibull distribution can represent a variety of density function shapes. The Weibull cumulative distribution inverse (equation 3-6) is used to calculate each firm's discount rate and price growth rate expectation. The parameters of equation 3-6 are solved using the upper and lower bounds and median.

$$X = a \left[-\ln (1-F(X)) \right]^{\frac{1}{c}} + b \quad (3-6)$$

Using $F(X)=.1$ for the lower bound, $F(X)=.5$ for the median and $F(X)=.9$ for the upper bound a , b and c are solved. The b parameter is not straight forwardly solved and must be estimated using numerical methods. The method of successive approximations is used to iterate to a value for b given lower, upper, and median values for X .

Equations 3-7 and 3-8 represent the solutions for c and a , respectively. Equation 3-9 is the relationship used to estimate b .

$$c = \frac{1.2005}{\ln \left(\frac{(X_u - b)}{(X_m - b)} \right)} \quad (3-7)$$

$$a = \exp \left[\frac{.3665}{c} + \ln(X_m - b) \right] \quad (3-8)$$

$$b_{n+1} = X_L - \frac{(X_m - b_n)^{2.5692}}{(X_u - b_n)^{1.5692}} \quad (3-9)$$

where X_m = median value
 X_L = lower bound value
 X_u = upper bound value
 $F(X)$ = value of the cumulative distribution given X
 n = iteration step number

This Monte Carlo approach is a very attractive way of representing fuel and efficiency choice because it incorporates the same decision variables actually used by firms in making these decisions and it permits a representation of the variation in the factors which do, in fact, vary from firm to firm. This approach offers considerable advantage over the econometric fuel-split approach used previously. The econometric representation was determined to be faulty when the model failed to forecast significant choice of electric space heating when that fuel offered significant cost advantages. Since 3-5 is a cost-based equation, that difficulty should not occur. The observed reluctance of commercial decision makers to invest in energy saving options is captured in the use of discount rate values that reflect such patterns. The interaction of end use systems such as lighting is reflected by the "other" factors in determining the energy use requirements of an HVAC system. While not pursued in our present research, this approach allows a straightforward incorporation of new technologies if one provides the energy-capital cost technology curve and the cost-equivalent disincentive generated by uncertainty of the new technology. The obvious new issues raised with this approach relates to the estimation of the population distributions of fuel price expectations and discount rates. This topic is the focus of the next section.

Data Development

To calculate the distribution of discount rates and price expectations as discussed in the previous section the Monte Carlo approach is employed. To generate the numbers using equation 3-6 a set of uniform probabilities, one set of five (three fuels and two discount rates (Public vs. Private sector), for each observation are chosen using a computerized random number generator in the interval 0,1. The population distribution parameters, X_L , X_m , X_u are derived as follows.

On the basis of a review of approximately two hundred case studies compiled from past issues of Energy Users News, we have concluded that commercial firms are reluctant to invest in energy saving investments. That is, unexpectedly strict investment criterion are used to evaluate energy-related investments. This finding is consistent with the conventional wisdom and "rules-of-thumb" often reported in this area. We believe that such behavior is, in fact, economically rational and can be explained by several factors including, uncertainty related to cost savings (in part from uncertainty over the technology, in part from other factors such as uncertainty of future weather trends which help determine cost savings), fuel price, and resource competition with other goals of the organization such as enhancement of market shares through advertising expenditures or product upgrading.

In any case, high discount rates (i.e., short payback periods) are without question applied in energy related investment decisions. We have specified the upper, median, and lower bound parameters of 25%, 50%, and 75% for the discount rate parameters. That is, we assume that 80% of all commercial establishments use discount rates between 25% and 75% with a corresponding required payback period of from 5 and 2.3 years.

To estimate the distribution of expected prices we used price expectations published by Energy Users News from their survey of

energy users. The number of panelists ranged from 64 to 70 in January, February, March, and April 1982 issues which were used to determine the appropriate parameters for this application. Energy Users News publishes the median estimate and the highest and lowest estimate. Oftentimes the two highest (or two lowest) estimates are published if the highest (or lowest) estimate appears to be an outlier. We used these data to develop an estimate of the variance of the price expectations around the median. The resulting upper and lower bound parameters showed an approximately 80% coverage for rates of electricity price increase that varied from -10.33 to 6.33% around the median; from -11.07% to 6.33% for gas; and from -8.33% to +8.33% around the reported oil prices median expectation. Thus, on the basis of these data, if the median electricity price expectations were 12%, we can assume that 80% of the population expects rates of increase that range from 1.67% to 18.33%. In our forecasts, we assume that commercial decision makers are accurate forecasters of price increases on average, but that individual forecasts vary according to the information developed from Energy Users News. This assumption allows us to use exogenously supplied price forecasts to represent the average price in any forecast year.

Incorporating these values into the model where the median expectation is equal to the exogenously supplied price forecast, the bounds are input as:

	<u>Lower</u>	<u>Median</u>	<u>Upper</u>
Electricity	.8967	1.00	1.0633
Natural Gas	.8833	1.00	1.0633
Fuel Oil	.9167	1.00	1.0833

Additional Data Requirements. The DOE 2.1 heat load model is used to develop the annual HVAC energy use requirements (E) used in estimation of equation 3-3. DOE 2.1 inputs require a vast array of information on building shell characteristics, equipment characteristics, internal loads and schedules, and weather. Based on

the HVAC system modeled and the shell characteristics, cost estimates in dollars per square foot can be calculated for each run. Lighting level is input to DOE 2.1 and, therefore, predetermined. These data are generated in a controlled experiment by running DOE 2.1 using all of the sixteen possible combinations of the four input factors (see equation 3-10 below) with two specifications; one for high energy use and one for low energy use.

Three prototype building specifications were modeled for DOE 2.1 consisting of a 40,500 sq. ft. office, a 40,000 sq. ft. school and a 180,000 sq. ft. hospital. Tables 3-1 through 3-3 contain the specifications for each, respectively.

Each building prototype was run with weather for two locations; Portland, Oregon and Yakima, Washington. Weather tapes from the National Oceanic and Atmospheric Administration (NOAA) were used for weather information corresponding to a typical meteorological year (TMY). These TMY tapes use actual months selected from various years in which the month selected is representative of 'typical' weather. That is, weather data for say January could be from 1960 and February weather could be from an entirely different year.

Parameter Estimation

As stated above, there are sixteen combinations to consider for running a regression to estimate the parameters in equation 3-3. Our empirical specification identifies two components of "other" factors; structure capital (thermal integrity) and lighting level. Equation 3-10 illustrates this estimating equation.

$$\ln E = a_0 + a_1 \ln KE + a_2 \ln KS + a_3 \ln S + a_4 \ln L \quad (3-10)$$

where E = HVAC Energy use per sq. ft.

KE = HVAC equipment cost per sq. ft.

KS = Cost per sq. ft. of the components of structure that change from high to low energy use settings; windows, walls, and roof

Table 3-1

OFFICE BUILDING DOE 2.1 SPECIFICATIONS

General:

Area = 40,500 square feet
 Number of stories = 3
 Yearly Schedule = 12 months

	<u>High Energy Use</u>	<u>Low Energy Use</u>
Lights:		
Recessed Fluorescent in ceiling	3.5 watts/sq. ft.	2.5 watts/sq. ft.
VAC Equipment:		
Air Delivery	Multizone with constant air- flow to 5 zones	Same with addition of rotary heat exchanges
Plant	Electric hot water boiler Hermetic reciprocating chiller and cooling tower	Electric hot water boiler Double bundle chiller
Structure:		
Walls	4" face brick 1" air space 8" concrete block 1/2" gypsum board	4" face brick 1" air space 8" concrete block 1/2" insulation, R-2 1/2" gypsum board
Roof	1/2" stone 3/8" felt 1" insulation, R-3 Metal deck Air space Suspended Acoustic Tile	1/2" stone 3/8" felt 2 1/2" insulation, R-7 Metal deck Air space Suspended Acoustic tile
Windows	30% of wall area Single pane	30% of wall area Triple glazing
Operating:		
Thermostat settings	7:00 am. - 6:00 pm. on workdays Cooling-70° Heating-75° Set back 6° at all other times	7:00 am. - 6:00 pm. on workday Cooling-76° Heating-68° Set back 6° at all other times
Outside air	20 CFM/person	10 CFM/person

Table 3-2

HOSPITAL BUILDING DOE 2.1 SPECIFICATIONS

General:

Area = 180,000 square feet
 Number of stories = 4
 Yearly Schedule = 12 months

	<u>High Energy Use</u>	<u>Low Energy Use</u>
Lights:		
Recessed Fluorescent in ceiling	3.5 watts/sq. ft. in core 2.25 watts/sq. ft. in perimeter	2.5 watts/sq. ft. in core 1.75 watts/sq. ft. in perimeter
A/C Equipment:		
Air Delivery	Four pipe fan coil in each patient room Constant air volume in treatment rooms	Same with addition of a noncontact heat exchanger
Plant	Electric hot water boiler Centrifugal chiller and cooling tower	Electric hot water boiler Double bundle chiller
Structure:		
Walls	4" face brick 1" air space 8" concrete block 1/2" gypsum board	4" face brick 1" air space 8" concrete block 1/2" insulation, R-2 1/2" gypsum board
Roof	1/2" stone 3/8" felt 1" insulation, R-3 Metal deck Air space Suspended Acoustic Tile	1/2" stone 3/8" felt 2 1/2" insulation, R-7 Metal deck Air space Suspended Acoustic tile
Windows	20% of wall area Single pane	20% of wall area Triple glazing
Operating:		
Thermostat settings	7:00 am. - 6:00 pm. on workdays Cooling-70° Heating-75° Set back 6° at all other times	7:00 am. - 6:00 pm. on workday Cooling-76° Heating-68° Set back 6° at all other times
Outside air	3.5 Airchanges/hour in core 2.0 Airchanges/hour in perimeter	3.0 Airchanges/hour in core 1.8 Airchanges/hour in perimeter

Table 3-3

SCHOOL BUILDING DOE 2.1 SPECIFICATIONS

eral:

Area = 40,000 square feet
 Number of stories = 1
 Yearly Schedule = 9 months

	<u>High Energy Use</u>	<u>Low Energy Use</u>
hts:		
ecessed Flourescent in ceiling	3.0 watts/sq. ft.	2.0 watts/sq. ft.
C Equipment:		
Air Delivery	Four pipe fan coil in classrooms, office, cafeteria	Same
Plant	Electric hot water boiler Hermetic reciprocating chiller and cooling tower	Electric hot water boiler Double bundle chiller
icture:		
Walls	4" face brick 1" air space 8" concrete block 1/2" gypsum board	4" face brick 1" air space 8" concrete block 1/2" insulation, R-2 1/2" gypsum board
Roof	1/2" stone 3/8" felt 1" insulation, R-3 Metal deck Air space Suspended Acoustic Tile	1/2" stone 3/8" felt 2 1/2" insulation, R-7 Metal deck Air space Suspended Acoustic tile
indows	15% of wall area Single pane	15% of wall area Triple glazing
ating:		
hermostat settings	7:00 am. - 6:00 pm. on workdays Cooling-70° Heating-75° Set back 6° at all other times	7:00 am. - 6:00 pm. on workdays Cooling-76° Heating-68° Set back 6° at all other times
utside air	15 CFM/person	12 CFM/person

Table 3-4

HEAT PUMP SPECIFICATIONS

Office:

Individual heat pumps serving each zone with the outside coil a water-to-refrigerant heat exchanger connected to a common water loop which is normally at a temperature between the conditioned space and outside, thus increasing efficiency. Electric hot water boiler and cooling tower backup.

Hospital:

Not modeled.

School:

Individual through-the-wall air-to-air heat pump in each room. Electric hot water boiler and cooling tower backup.

S = level of end use services, arbitrarily set at 2 for high energy use and 1 for low energy use
 L = lighting level in watts per sq. ft.

Table 3-5 illustrates the way in which the high/low settings are arranged for running the sixteen alternative specifications with DOE 2.1 and setting up the regression. Alternatively, to reduce the expenditures of running DOE 2.1, and without severely compromising the results, ten runs could be used for estimation. These include all cases where each of the four variables are changed one at a time while holding all others at first their high settings and then at their low settings. In Table 3-5, these would be cases 1, 2, 4, 5, 7, 8, 9, 12, 14, and 16. This reduces the number of runs from 32 (16 x 2 weather zones) to 20 (10 x 2 weather zones) for each building. For three prototypes this reduces the runs from 96 down to 60.

Table 3-5

EXPERIMENTAL DESIGN FOR DOE 2.1 RUNS

Energy Use Characterizations

<u>Case #</u>	<u>Structure</u>	<u>Lights</u>	<u>Service</u>	<u>Equipment</u>
1	H	H	H	H
2	H	L	H	H
3	L	H	L	H
4	L	H	L	L
5	L	H	H	H
6	L	H	H	L
7	L	L	L	H
8	L	L	L	L
9	L	L	H	L
10	L	L	H	H
11	H	L	H	L
12	H	H	H	L
13	H	H	L	L
14	H	L	L	L
15	H	L	L	H
16	H	H	L	H

Four HVAC systems are specified for analysis and use in the fuel share module. These are electric resistance, electric heat pump (see Table 3-4), a natural gas heating system, and an oil heating system. A set of coefficients is required for each of the four systems both with and without air conditioning. Ideally, DOE 2.1 should be run without an air conditioning system to derive the data for estimating this specification. Alternatively, the air conditioning annual load can be subtracted from HVAC annual use and the KE variable adjusted accordingly to set up the data to estimate systems without air conditioning. The efficacy of this alternative must be determined by weighing the costs of additional runs against the importance of non-air conditioned space in commercial buildings. Since it is widely accepted that almost all new floor space in the commercial sector has for years been built with air conditioning, this trade off is probably acceptable.

As Tables 3-1 to 3-3 indicate, an electric heating system was specified for each run. To derive data necessary for the natural gas systems, an efficiency factor is used to adjust the HVAC annual loads and KE is adjusted accordingly. The electric heating load is multiplied by 1.27 to derive the natural gas numbers. Coefficient estimates for the natural gas system are then used for the oil system. In the model, different base year capital cost figures are used for gas and oil but the responsiveness of HVAC efficiency choice to the explanatory variables is assumed to be the same for both.

For this project, we opted to reduce the runs to the minimum five per building per weather zone. The coefficients of equation 3-10 shown in Table 3-6 can be estimated by simply looking at two cases for each coefficient; one with the high setting and one with the low where all other variables stay at their high settings. The resulting change in E is a consequence then of the change in that one variable. Taking the ratio of the percentage change in E to the percentage change in the explanatory variable will produce an estimate of that coefficient.

For example, using data from Appendix C, Office-Portland, the coefficient for kE (-2.24 in Table 3.6) is calculated by taking the ratio of the percentage change in HVAC going from case HHHH to HHHL, to the percentage change in costs:

$$\% \text{ HVAL} = \frac{(4,713 - 10,698)}{10,698} = -.5595$$

$$\% \text{ Costs} = \frac{(\$6.50 - \$5.20)}{\$5.20} = .25$$

$$kE = \frac{-.5595}{.25} = -2.24$$

Our decision to estimate the coefficients in this manner was based primarily on budget constraints. The costs associated with running DOE 2.1, producing the data series for estimation and the estimation phase were judged to be beyond the limits of our budget for these tasks. The exploratory nature of this analysis and our recognition of other important issues which are involved but could not be addressed because of data limitations as well as budget constraints led us to this decision. Once better survey information is compiled on a large sample of buildings in each building type, e.g., office, retail, hospital, grocery, restaurants, etc., a better determination of what is a "typical" structure in both a physical and operational sense can be sought. This will greatly improve confidence in the results by virtue of improving the representativeness of the prototype buildings.

The heat load results and cost data are contained in Appendix C.

Subroutine Structure

This section will describe how the fuel/efficiency choice methodology is implemented into the overall commercial end use model code. Appendix B contains a copy of the FSHAR subroutine to help the reader follow the series of calculations contained in the subroutine.

Table 3-6

Coefficient Estimates for Equation 3-5

	Office			Hospital			School		
	ER	HP	FF	ER	HP	FF	ER	HP	FF
<u>Portland</u>									
<u>With AC</u>									
KE	-2.24	-2.24	-1.40	-2.58	-2.58	-1.65	-2.00	-2.00	-1.50
KS	-.170	-.170	-.150	-.210	-.210	-.150	-.040	-.040	-.040
L	.300	.300	.350	-.100	-.100	.100	-.040	-.040	.010
S	.88	.88	.33	.02	.02	.09	.11	.11	.12
<u>Without AC</u>									
KE	-2.77	-2.77	-2.09	-2.77	-2.77	-2.09	-2.00	-2.00	-1.50
KS	-.220	-.220	-.190	-.220	-.220	-.190	-.040	-.040	-.040
L	0.0	0.0	0.0	0.0	0.0	0.0	-.05	-.05	0.0
S	.40	.40	.37	.40	.40	.37	.11	.11	.12
<u>Yakima</u>									
<u>With AC</u>									
KE	-2.41	-2.41	-1.56	-3.32	-3.32	-2.35	-2.00	-2.00	-2.00
KS	-.180	-.180	-.180	-.110	-.110	-.090	-.050	-.050	-.040
L	0.0	0.0	.35	-.05	-.05	.09	-.04	-.04	0.0
S	.39	.39	.35	.05	.05	.10	.10	.10	.11
<u>Without AC</u>									
KE	-2.91	-2.91	-2.23	-2.91	-2.91	-2.23	-2.00	-2.00	-2.00
KS	-.190	-.190	-.180	-.190	-.190	-.190	-.050	-.050	-.050
L	0.0	0.0	0.0	0.0	0.0	0.0	-.04	-.04	0.0
S	.41	.41	.38	.41	.41	.38	.10	.10	.11

ER = Electric Resistance, HP = Heat Pump, FF = Fossil Fuel (Gas & Oil)

FSHAR has been divided into two sections using an ENTRY statement to call the second section. The subroutine is called by MAIN at the beginning of execution and a series of calculations are performed to set up values for arrays which are either constant over time or not dependent on other variables which are redefined as execution proceeds. The main function of this portion is to set up the price expectation and discount rate distributions for the sample of firms whose fuel and efficiency choices will be simulated over the forecast

period in the second section. Additionally, this first section will calibrate the encoded form of equation 3-5 by calculating a constant that ensures an initial value of E equal to the base year value input.

Before beginning the discussion of Section 1, we need to provide a list of the variables and their definitions from FSHAR. Because of the large number of variables in FSHAR, both those exclusive to FSHAR and those in common, we present the variable list in two sections.

Variables Exclusive to FSHAR

<u>Variable</u>	<u>Definition</u>
ACFLAG	Controls presence of AC in calculations
ACSUM	Sum of system AC EUI's for weighted average calculation
BD	Temp. var., used in coefficient transformation
B1	Temp. var., used in coefficient transformation
B2	Temp. var., used in coefficient transformation
B3	Temp. var., used in coefficient transformation
B4	Temp. var., used in coefficient transformation
CCOST	Stores captial cost of heating system
CD	Stores intermediate results in discount rate distribution calculation
CDEN	Temp. var., used in CCOST calculation
COVCOST	Stores conversion cost factor for water to air distribution system
CP	Stores intermediate results in fuel price distribution calculation
CSFF	Stores capital cost value
CYS	Stores number of choices by system
CYSAC	Stores number of choices, with air conditioning as part of HVAC
C1	Temp. var., used in CCOST calculation
C2	Temp. var., used in CCOST calculation
C3	Temp. var., used in CCOST calculation
DAL	Temp. var., used in discount rate distribution calculation
DD2	Temp. variable 4, air cond. utilization weight
DD3	Temp. variable 4, ventilation utilization weight
DIFE	Stores result for iterative check
D4	Utilization weights denominator
EAC	Air conditioning EUI by system & observation
EBS21L	Stores AC base year EUI
EBS31L	Stores ventilation base year EUI
ED	Temp. variable used in discount rate distribution calculation
EDR	Stores dicount rates by observation
ED1	Temp. variable used in discount rate distribution calculation

<u>Variable</u>	<u>Definition</u>
EHT	Space heating EUI by system & observation
ELT	Stores previous year new lighting EUI
EP	Temp. var., used in price distribution calculation
EPR	Stores price percent deviation from median by system and observation
EP1	Temp. var., used in price distribution calculation
EVT	Ventilation EUI by system and observation
HALF	Stores half of NOBS to control COVCOST application
HTMP	Temporary variable for heating EUI
HVAC	HVAC EUI
LCC	Life cycle cost
ONC	Stores LCC in minimization check
OPCOST	Operating cost for life cycle cost
PAL	Intermediate result in price distribution calculation
PP2	Utilization part of CCOST calculation
PP3	Lighting part of CCOST calculation
PP4	Thermal integrity part of CCOST calculation
PRI	Stores base year electricity price
PRICE	Stores base year prices
PVAC	Present value of air conditioning operating cost
PVHT	Present value of space heating operating cost
PVVT	Present value of ventilation operating cost
PO	Constant coefficient in HVAC equation
P1	Stores operating cost for HVAC equation
P2	Stores HVAC utilization for HVAC equation
P3	Stores lighting EUI for HVAC equation
P4	Stores thermal integrity value for HVAC equation
RHT	Stores HVAC lifetime
SPLIT1	Stores the ventilation coefficient to split HVAC changes into its components
SPLIT2	Stores the air conditioning coefficient to split HVAC changes into its components
SUM	Temp. var. for operating cost summation
SUMAC	Stores sum of EAC values for chosen systems
SUMHT	Stores sum of EHT values for chosen systems
SUMPV	Present value of indexed prices
SUMVT	Stores sum of EVT values for chosen systems
TD	Temp. var. in distribution calculation
TIN	Stores thermal integrity value
TOTSYS	Denominator for fuel share calculation
UWT	Stores weighted utilization value
U1I	Stores space heat utilization
U2I	Stores AC utilization
U3I	Stores ventilation utilization
VTFLAG	Controls presence of ventilation in calculation
VTMP	Temporary var. for ventilation EUI
VTSUM	Sum of system ventilation EUI's for weighted average calculation
WTU1	Stores space heating utilization weight
WTU2	Stores air cond. utilization weight

Variable List - COMMON BLOCKS

COMMON/SETVAR/

<u>Variable</u>	<u>Definition</u>
NNI	Number of fuel types
NNIHT	Number of fuels to use in FSHAR
NNK	Number of end uses
NNL	Number of building types
NOBS	# of cases in FSHAR simulation
NSP	Number of simulation periods
NVNT	Ventilation end use indicator

COMMON/SIMVAR/

<u>Variable</u>	<u>Definition</u>
A	Stores fuel shares by vintage
E	Stores EUI's by vintage
EBS	Stores base year EUI's
FPBS	Base year fuel prices
NREPl	Lifetimes for end uses
PR	Fuel price vectors, relative to base year
U	Stores utilization factors by vintage

COMMON/SHRVAR/

<u>Variable</u>	<u>Type</u>	<u>Definition</u>
AIRC		New construction air cond. electricity, fuel share
B		Weibal function parameter
CS		Coefficients for the technology curves
CSF		Cost/SQ.Ft. of HVAC systems
CZF		Fraction of population in climate zone 1
CZWT		Weights for partitions: CLZ1 with/without AC and CLZ2 with/without AC
D1		Space heating utilization weighting factor
D2		AC utilization weighting factor
D3		Ventilation utilization weighting factor
EBSHP		Ratio of Heat Pump EUI to Resistance EUI
EUI CZ		Weights for climate zone EUI weighting
FREQ		Array containing random sets of probabilities for fuels and discount rates
G		Weibal function parameter
HTEBS		Space heating base year EUI array
IRB		Index for discount rate choice
SPLIT		Coefficients for HVAC EUI split
TI		Thermal integrity index

XD	Array containing lower, median, upper bounds of discount rate distribution
XP	Array containing lower, median, upper bounds of price distribution

Section 1

Price and Discount Rate Distribution: The discount rate distributions (EDR) are calculated first followed by the price expectation distributions (EPR) for each fuel. The series of calculations used to calculate the values for each array are identical in logic. In the section on methodology, equations 3-6 thru 3-9 were presented. These equations are encoded into a series of calculations beginning with the iterative solution for, b (ED), using equation 3-9. Once, b, is determined, the code calculates a value for, c (CD), using equation 3-7. The value for, c, is then used to calculate, a (DAL), using equation 3-8.

Equation 3-6 is encoded in a loop which calculates a discount rate for each firm using the previously calculated values for a, b and c. The index, ID, in the code takes on values of 1 and 2 and is used to index EDR for storage of two discount rates per firm. The two discount rates can represent private and public sector values, respectively. Public institutions such as schools may use a different discount rate than private sector firms given their different pay back period criteria and availability to financing. The values of X_L , X_m , and X_u are used to differentiate between the two and the variable IRB is used to select one or the other for each building type.

The price expectation distribution array EPR follows the same series of calculations with variable names changed to distinguish them from the previous discount rate calculations. ED becomes EP, CD becomes CP, and DAL becomes PAL.

Present Value Calculation: Once EDP and EPR are calculated the code performs the present value calculation of fuel costs for each fuel type and firm in the sample for all simulation years. The variable SUMPV stores these values for later use in the second section. RHT

contains the number of years input from variable NREPL corresponding to the lifetime of HVAC systems.

Calibration of Equation 3-5: Using the base year value of SUMPV, the base year space heating EUI's (electric is split into electric resistance and heat pump and stored in HTEBS as well as the gas and oil EUI's) and fuel prices in the base year, the dollar value of the present discounted value of operating costs is calculated. PVHT, PVAC and PVVT store the present value calculations for heating, cooling, and ventilation, respectively.

Going back to equation 3-5, and noting that E is normalized to 1.0 in the base year for use in the model coding, it is clear that for E to average out to 1.0 in the base year the constant needs to be equal to the reciprocal of the base year present value calculation. The other terms in the equation; lighting EUI, thermal integrity and utilization are also all normalized to 1.0 in the base year for use in the model code. Therefore, the product of the constant and the present value term in the equation must average to 1.0 over all firms. The constant is then stored in CS (I, 1, L).

Section 2

The second section in FSHAR is called SHRCAL. This block of code is called from SUBROUTINE UPDAT twice each year of the simulation; once for replacement systems and once for new construction. The other floor space stock vintages replacing HVAC systems acquire the same results calculated by SHRCAL for the replacement system on the first pass through.

The comment statement that reads as PARTITION LOOP - CLIMATE ZONES, WITH/WITHOUT AIR COND begins the loop that calculates the efficiency choice, the capital cost corresponding to the efficiency choice and the resulting life cycle cost (LCC). These calculations are run for the sample of firms for each of the four systems with and without air conditioning and for each climate zone. In effect, there are four segments of the population which are run through the

calculations. First, split the population by climate zone giving two segments and then divide each segment into 2 more segments using the air conditioning penetration to differentiate between firms in buildings with air conditioning and firms in buildings without air conditioning.

The estimated parameters of equation 3-10, are transformed to calculate the parameters of equation 3-5, which is the life cycle cost minimizing relationship for efficiency choice, E. In the code these transformed parameters are B1, B2, B3, and B4. The capital cost equation (3-2) parameters are also calculated from the estimated parameters of equation 3-10. In the code these transformed parameters are C1, C2, C3, and CDEN.

Since the model requires separate heating, cooling, and ventilation EUI's the HVAC EUI is split into its components after efficiency is calculated. Estimates of how much of an efficiency gain could be attributed to each end use on average were calculated from the heat load runs. The variable SPLIT1 and SPLIT2 contain these estimates.

Once LCC is calculated for each system for a particular firm, the minimum is found and the system index and HVAC EUIS are stored away until all firms have been run through. Each choice is weighted by a climate zone/air conditioning factor corresponding to the segment being simulated. The fuel shares are then calculated from the accumulated number of weighted choices for each fuel type (electric resistance and heat pump are combined into electric) after all four segments have been run through. The average heating, cooling, and ventilation EUIs are calculated from the chosen systems of each fuel type.

References

AIA Research Corporation, Phase One/Base Data for the Development of Energy Performance Standards for New Buildings. Prepared for the Department of Housing and Urban Development and the Department of Energy, January 30, 1978.*

Bonneville Power Administration, Bonneville Power Administration Forecasts of Electricity Consumption in the Pacific Northwest, 1980-2000, Draft Report, DOE/BP-98, April 1982.

California Energy Commission, data provided on current energy use requirements of commercial building end uses, April 1982.*

S. Cohn, Fuel Choice and Aggregate Energy Demand in the Commercial Sector, ORNL/CON-27**, December 1978.

S. Cohn, K. Corum, J. Kurish and C. Emerson, A Commercial Energy Use Model for the Ten U.S. Federal Regions, ORNL/CON-40, April 1979 (Draft).

H.G. Huntington and Evan Soffer, The Demand for Energy in the Commercial Sector, Data Resources, Inc. (Preliminary Report to the Electric Power Research Institute), May 1979.

J.R. Jackson, An Econometric-Engineering Analysis of Federal Energy Conservation Programs in the Commercial Sector, ORNL/CON-30, January 1979.

J.R. Jackson, Energy Use in the Commercial Buildings Sector: Historical Patterns and Future Scenarios, Report Submitted to Solar Energy Research Institute and Consultant Agreement C-0-0179-1, October 1980.

J.R. Jackson, S. Cohn, J. Cape and W.S. Johnson, The Commercial Demand for Energy: A Disaggregated Approach, ORNL/CON-15, April 1978.

J.R. Jackson and P. DeGenring, (Charles River Associates), Development and Application of a Commercial Sector Energy Use Model for New York State, CRA Report #438, April 1980.

J.R. Jackson and W.S. Johnson, Commercial Energy Use: A Disaggregation by Fuel, Building Type and End Use, ORNL/CON-14, February 1978.

J.R. Jackson and R. Lann, Refinement and Extension of the NYSEO Commercial Sector Energy Demand Model, November 1981.

W.S. Johnson and F.E. Pierce, Energy and Cost Analysis of Commercial Building Shell Characteristics and Operating Schedules, ORNL/CON-39*, April 1980.

R. Lann, et al., Technical Documentation of the Commercial Sector Forecasting Model, California Energy Commission, October 1979.

A.D. Little, Project Independence Blueprint, Final Task Force Report, Residential and Commercial Energy Use Patterns, 1970-1990, report prepared for the Federal Energy Administration, November 1974.

R.E. Lyman, Jr., Energy and Cost Analysis of Commercial HVAC Equipment: Offices and Hospitals, Masters Thesis, University of Tennessee, December 1978.

Synergic Resources Corporation, data provided by Joan Gamble on schools and hospitals in the Pacific Northwest, April and May 1982.*

U.S. Department of Commerce, Bureau of the Census, County Business Patterns, 1977.

U.S. Department of Energy, Nonresidential Buildings Energy Consumption Survey: Buildings Characteristics, DOE/EIA-0246, March 1981.*

U.S. Department of Energy, Bonneville Power Administration, selected data from the Department of Energy Nonresidential Buildings Feasibility Survey, provided by Phillip Windell and John McConnoughey, May 1982.*

Westinghouse Research Laboratories, Assessing the Potential for Optimal Utilization of Off-Peak Power, prepared for the Federal energy Administration, December 1975.

*References used in data development are designated with an asterisk following the date of publication.

**ORNL/CON reports are published by the Energy Division, Oak Ridge National Laboratory, Oak Ridge, Tennessee.

APPENDIX A

Listing of the STOK Subroutine

```

1      C
      C
      C
      C      SUBROUTINE STOK
5      C
      C      THIS SUBROUTINE DETERMINES ADDITIONS AND FLOOR SPACE
      C      STOCK FOR THE SIMULATION PERIOD USING ONE OF TWO
      C      METHODS.
      C
10     C
      C      SUBROUTINE STOK(L)
      C
      C
15     C
      C      REAL LAG(13)
      C      LOGICAL LOPT1(7),LOPT2(13),LOPT3(4),FSCH(13)
      C
      C      COMMON /STKVAR/ ADD(13,79),S(13,31),EXOG(13,4,31),CF(6,13),
2      C      ASTK(13),F(79),EP985(79),FSGRTH(13)
20     C      COMMON /SETVAR/ TITLE(20,2),NILOOP(8),NISTD(8),IRGN,NRGN,NNI,NNK,
2      C     >NNL,NME,NDD,NSP,NYRBS,NYRFS,NYRRT,NST,NST1,NSTM1,
3      C      NEND,NRTST,N70,N71,N73,N80,NVNT,NWH,NCK,NRF,NOBS,
4      C      NSPRI,NNIHT,LOPT1,LOPT2,LOPT3,FSCH,LAG
      C      DATA CSTK/"STK "/,CADD/"ADD "/,CNO/"NO "/
25     C
      C      FOR VARIABLE S, N=1 CORRESPONDS TO NYRBS
      C      FSCH IS .TRUE. FOR STOCK APPROACH AND .FALSE. FOR
      C      THE INVESTMENT DEMAND APPROACH.
      C
30     C      F IS FRACTION OF FLOOR SPACE ADDS FROM VINTAGE NN STILL IN N
      C
      C      IF(L.NE.1)GO TO 10
      C      DO 20 N=1,NEND
20     F(N)=1.0-1.0/(1.0+EXP(6.91-0.15356*N))
35     10 IF(FSCH(L)) GO TO 500
      C
      C      ADDITIONS APPROACH SECTION
      C
      C      DO 30 N=NST,NEND
40     NIND=N-NST1
      C      SUM=0.0
      C      N2=N-2
      C      ADD(L,1)=0.0
      C      DO 40 NN=1,N2
45     40 SUM=SUM+F(NN)*ADD(L,N-NN)
      C      SUM=SUM+ASTK(L)*EP985(N-1)
      C      IF(N.EQ.NST) GO TO 50
      C      IF(LAG(L).EQ.CSTK) ALAG=SUM
      C      IF(LAG(L).EQ.CADD) ALAG=ADD(L,N-1)
50     IF(LAG(L).EQ.CNO) ALAG=0.0
      C      ADD(L,N)=CF(1,L)+CF(2,L)*EXOG(L,1,NIND)+CF(3,L)*EXOG(L,2,NIND)+
1      C      CF(4,L)*EXOG(L,3,NIND)+CF(5,L)*EXOG(L,4,NIND)+
2      C      CF(6,L)*ALAG
      C      IF(ADD(L,N).LT.0.0) ADD(L,N)=0.00
55     50 S(L,NIND)=SUM+ADD(L,N)
      C      30 CONTINUE
      C      GO TO 600

```

```

C
C   STOCK APPROACH SECTION
60  C
    500 FSG=FSGRTH(L)
        DO 60 N=NST,NEND
            NIND=N-NSTM1
            FAC=EXP(FSG*NIND)
65      SUM=0.0
            NZ=N-2
            ADD(L,1)=0.0
            DO 70 NN=1,NZ
70      SUM=SUM+F(NN)*ADD(L,N-NN)
            SUM=SUM+ASTK(L)*EPS85(N-1)
            IF(N.EQ.NST) GO TO 80
            IF(LAG(L).EQ.CSTK) ALAG=SUM
            IF(LAG(L).EQ.CADD) ALAG=ADD(L,N-1)
            IF(LAG(L).EQ.CNO) ALAG=0.0
75      SQFEMP=CF(2,L)*FAC
            S(L,NIND)=CF(1,L)+SQFEMP*EXOG(L,1,NIND)+CF(3,L)*EXOG(L,2,NIND)+
1          CF(4,L)*EXOG(L,3,NIND)+CF(5,L)*EXOG(L,4,NIND)+
2          CF(6,L)*ALAG
            ADD(L,N)=S(L,NIND)-SUM
80      IF(ADD(L,N).LT.0.0) ADD(L,N)=0.00
            GO TO 60
80  S(L,1)=SUM+ADD(L,NST)
60  CONTINUE
C
85  600 CONTINUE
C
    RETURN
    END

```

APPENDIX B

Listing of the FSHAR Subroutine

```

1      C
      C
      C
      C      SUBROUTINE FSHAR - CALCULATES SPACE HEATING FUEL SHARES
5      C      AND SPACE HEATING, AIR CONDITIONING AND VENTILATION EQUI'S
      C
      C      SUBROUTINE FSHAR(LL,NS,NNS),RETURNS(A1)
      C
10     C      LOGICAL LOPT1(7),LOPT2(13),LOPT3(4),FSCH(13)
      C
      INTEGER RHT,HALF
      REAL EPR(50,5),EDR(50,2),LCC(50,6),SUMPV(50,10,31),
15     2   EHT(50,6),EAC(50,6),EVT(50,6),EP(5),CP(5),PAL(5),
      3   CYS(6),CYSAC(6),ED(2),CD(2),DAL(2),SUMHT(6),
      4   SUMAC(6),SUMVT(6),LAG(13)
      DIMENSION IND(16)
      C
      COMMON /SIMVAR/ Q(8,5,31),U(8,5,79),E(8,5,79),A(8,5,79),
20     2   EBS(8,5,13),ABS(8,5,13),PR(5,48),DD(13,2),
      3   DDFAC(13,2),EP928(31),UEL(5),EEL(5),EMAX(8),
      4   NREPL(8),HWT(8),CLG(5),FPBS(5),ACS(13)
      COMMON /OUTVAR/ Q1(31,13,5),Q2(31,8,5),Q3(31,13,8),AST(8,5,31),
25     2   EST(8,5,31),UC(8,5,31),US(8,5,31),EC(8,5,31),
      3   ES(8,5,31),AC(8,5,31),AS(8,5,31),BC(8,5,31),
      4   Q1T(31,13),STOT(31),ATOT(31)
      COMMON /STKVAR/ ADD(13,79),S(13,31),EXOG(13,4,31),CF(6,13),
26     2   ASTK(13),F(79),EP985(79),FSGRTH(13)
      COMMON /SHRVAR/ CS(16,5,13),XP(3,5),XD(3,2),FREQ(7,50),TI(79),
30     2   CSF(13,16),IRB(13),AIRC(13),HTEBS(5),CZWT(4),
      3   SPLIT(13,3),HPPEN(13),EUICZ(2),D1(4),D2,D3,G,B,CZF
      COMMON /SETVAR/ TITLE(20,2),N1LOOP(8),N1STD(8),IRGN,NRGN,NNI,NNK,
27     2  >NNL,NNE,NDD,NSP,NYRBS,NYRFS,NYRRT,NST,NST1,NSTM1,
      3   NEND,NRTST,N70,N71,N73,N80,NVNT,NWH,NCK,NRF,NOBS,
35     4   NSPRI,NNIHT,LOPT1,LOPT2,LOPT3,FSCH,LAG
      C
      DATA IND/4*0,4*1,4*2,4*3/
      C
      C
40     C      CALCULATE THE DISTRIBUTION PARAMETERS AND GENERATE
      C      DISCOUNT RATES
      C
      RHT=NREPL(1)
      DO 10 ID=1,2
45     ED(ID)=0.0
      DO 20 IT=1,50
      ED1=XD(1,ID)-(((XD(2,ID)-ED(ID))*G)/((XD(3,ID)
28     -ED(ID))*B))
      DIFE=(ED1-ED(ID))/ED1
50     ED(ID)=ED1
      IF(DIFE.LE.0.05)GO TO 30
      IF(IT.LT.50) GO TO 20
      WRITE(6,5013)IT,DIFE
      GO TO 999
55     20 CONTINUE
      30 CD(ID)=1.2005/(ALOG((XD(3,ID)-ED(ID))/(XD(2,ID)
29     -ED(ID))))

```

```

        DAL(ID)=0.3665/CD(ID)+ALOG(XD(2,ID)-ED(ID))
        DAL(ID)=EXP(DAL(ID))
60      CD(ID)=1./CD(ID)
        IN=ID+NNIHT
        DO 40 IO=1,NOBS
        TD=1.0-FREQ(IN,IO)
        TD=ALOG(TD)
65      EDR(IO,ID)=DAL(ID)*((-TD)**CD(ID))+ED(ID)
40 CONTINUE
10 CONTINUE

C
C   CALCULATE THE DISTRIBUTION PARAMETERS AND GENERATE
70  C   PRICE EXPECTATIONS FOR EACH FUEL.
C
        DO 50 I=1,NNIHT
        EP(I)=0.0
        DO 60 IT=1,50
75      EP1=XP(1,I)-(((XP(2,I)-EP(I))*G)/((XP(3,I)
2        -EP(I))*B))
        DIFE=(EP1-EP(I))/EP1
        EP(I)=EP1
        IF(DIFE.LE.0.05)GO TO 70
        IF(IT.LT.50) GO TO 60
        WRITE(6,5014)IT,DIFE
        GO TO 999
60 CONTINUE
70 CP(I)=1.2005/(ALOG((XP(3,I)-EP(I))/(XP(2,I)
85      2        -EP(I))))
        PAL(I)=0.3665/CP(I)+ALOG(XP(2,I)-EP(I))
        PAL(I)=EXP(PAL(I))
        CP(I)=1./CP(I)
        DO 80 IO=1,NOBS
90      TD=ALOG(1.0-FREQ(I,IO))
        EPR(IO,I)=PAL(I)*((-TD)**CP(I))+EP(I)
80 CONTINUE
50 CONTINUE

C
95  C   CALCULATE THE PRESENT VALUE OF FUEL COSTS FROM EPR AND EDR
C
        IDD=NNIHT*2
        VTFLAG=1.0
        IF(NVNT.EQ.0)VTFLAG=0.0
100      PRI=FPBS(1)*.001
        DO 100 NP=1,NSP
        DO 110 I=1,IDD
        IJ=I
        IF(I.GT.NNIHT) IJ=I-NNIHT
105      IF(I.LE.NNIHT) IA=1
        IF(I.GT.NNIHT) IA=2
        DO 120 IO=1,NOBS
        IF(NP.EQ.2.AND.I.EQ.1) EDR(IO,IA)=EDR(IO,IA)*1.1
        SUM=0.0
110      DO 130 NT=1,RHT
        NTT=NT+(NP-1)
130      SUM=SUM+PR(IJ,NTT)*((EPR(IO,IJ)/EDR(IO,IA))*NT)
        SUMPV(IO,I,NP)=SUM
120 CONTINUE

```

```

115      110 CONTINUE
      100 CONTINUE
          DD 140 L=1,NNL
          HTEBS(1)=EBS(1,1,L)*(1./(.5*HPPEN(L)+(1.-HPPEN(L))))
          HTEBS(2)=EBS(1,1,L)*(1./(HPPEN(L)+2.*(1.-HPPEN(L))))
120      HTEBS(3)=EBS(1,2,L)
          HTEBS(4)=EBS(1,3,L)
          EBS21L=EBS(2,1,L)
          EBS31L=EBS(3,1,L)
          NCDF=16
125      IF(CZF.EQ.1.0) NCDF=8
          DO 150 I=1,NCDF
          SUM=0.0
          CS(I,1,L)=0.0
          ACFLAG=1.0
130      IF((I.GE.5.AND.I.LE.8).OR.I.GT.12) ACFLAG=0.0
          IJ=I-4*IND(I)
          JI=IJ
          IF(IJ.GT.1) JI=IJ-1
          IJJ=JI
135      IF(IRB(L).EQ.2) IJJ=NNIHT+JI
          IFU=1
          IF(IRB(L).EQ.2) IFU=4
          B1=-CS(I,3,L)/(CS(I,3,L)-1.)
          PRICE=FPBS(JI)*.001
140      DO 160 ID=1,NBBS
          PVHT=SUMPV(ID,IJJ,1)*PRICE*HTEBS(IJ)
          PVAC=SUMPV(ID,IFU,1)*PRI*EBS21L*ACFLAG
          PVVT=SUMPV(ID,IFU,1)*PRI*EBS31L*VTFLAG
          SUM=SUM+(PVHT+PVAC+PVVT)**B1
145      160 CONTINUE
          CS(I,1,L)=1./(SUM/NBBS)
          150 CONTINUE
          140 CONTINUE
          RETURN
150      999 RETURN A1

C
C      CALCULATE HVAC EUI'S AND LIFE CYCLE COST
C
C *****
155      ENTRY SHRCAL
C *****
          L=LL
          N=NS
          NN=NNNS
160      NIND=N-NSTM1
          NNOLD=NN
          IF(NN.EQ.N) NNOLD=N-1
          II=0
          TOTSYS=0.0
165      NNIH=NNIHT+1
          TIN=TI(NNOLD)
          ELT=E(NNK-1,1,NNOLD)
          U21=U(2,1,NNOLD)
          U31=U(3,1,NNOLD)
170      EBS21L=EBS(2,1,L)
          EBS31L=EBS(3,1,L)

```

```

      IF(NVNT.EQ.0) VTFLAG=0.0
      IF(NVNT.NE.0) VTFLAG=1.0
      HALF=.5*NOBS
175     PRI=FPBS(I)*.001
      DO 170 I=1,NNIH
      CYS(I)=0.0
      CYSAC(I)=0.0
      SUMHT(I)=0.0
180     SUMAC(I)=0.0
      SUMVT(I)=0.0
170 CONTINUE
C
C     PARTITION LOOP - CLIMATE ZONES, WITH/WITHOUT AIR COND
185     C
      NCLZ=4
      IF(CZF.EQ.1.0) NCLZ=2
      DO 180 J=1,NCLZ
C
190     IF(J.EQ.1.OR.J.EQ.3) ACFLAG=1.
      IF(J.EQ.2.OR.J.EQ.4) ACFLAG=0.0
      DD2=D2*ACFLAG
      DD3=D3*VTFLAG
      COVCOST=0.0
195     IF(J.LE.2) JJ=1
      IF(J.GE.3) JJ=2
C
C     DO 190 I=1,NNIH
C
200     IF(ACFLAG.EQ.1.0) SPLIT1=SPLIT(L,1)
      IF(ACFLAG.EQ.0.0) SPLIT1=SPLIT(L,2)
      SPLIT2=SPLIT(L,3)
      IJ=1
      IF(I.GT.1) IJ=I-1
205     IJJ=IJ
      IF(IRB(L).EQ.2) IJJ=NNIHT+IJ
      IFU=1
      IF(IRB(L).EQ.2) IFU=4
      II=II+1
210     U11=U(1,IJ,NNOLD)
      PRICE=FPBS(IJ)*.001
      B1=-CS(II,3,L)/(CS(II,3,L)-1.)
      B2=-CS(II,2,L)/(CS(II,3,L)-1.)
      B3=-CS(II,5,L)/(CS(II,3,L)-1.)
215     B4=-CS(II,4,L)/(CS(II,3,L)-1.)
      CDEN=1./CS(II,3,L)
      C1=-CS(II,2,L)*CDEN
      C2=-CS(II,5,L)*CDEN
      C3=-CS(II,4,L)*CDEN
220     D4=D1(I)+DD2+DD3
      WTU1=D1(I)/D4
      WTU2=DD2/D4
      UWT=(U11*WTU1+U21*WTU2+U31*(1.-WTU1-WTU2))
      P0=CS(II,1,L)
225     P2=UWT**B2
      P3=ELT**B3
      P4=TIN**B4
      PP2=UWT**C1

```



```

230      PP3=ELT**C2
      PP4=TIN**C3
      CSFF=CSF(L,II)
C
      DD 200 IO=1,NOBS
C
235      PVHT=SUMPV(IO,IJJ,NIND)*HTEBS(I)*PRICE
      PVAC=SUMPV(IO,IFU,NIND)*EBS21L*PRI*ACFLAG
      PVVT=SUMPV(IO,IFU,NIND)*EBS31L*PRI*VTFLAG
      P1=(PVHT+PVAC+PVVT)**B1
      HVAC=P0*P1*P2*P3*P4
240      EVT(IO,I)=-SPLIT1*VTFLAG*(1.-HVAC)+1.
      EAC(IO,I)=-SPLIT2*ACFLAG*(1.-HVAC)+1.
      EHT(IO,I)=(HVAC*(HTEBS(I)+EBS21L*ACFLAG+EBS31L*VTFLAG)-
2          EAC(IO,I)*ACFLAG+EBS21L-EVT(IO,I)*VTFLAG+EBS31L)/
3          HTEBS(I)
245      IF(EHT(IO,I).LT.EMAX(1)) EHT(IO,I)=EMAX(1)
      IF(EAC(IO,I).LT.EMAX(2)) EAC(IO,I)=EMAX(2)
      IF(EVT(IO,I).LT.EMAX(3)) EVT(IO,I)=EMAX(3)
      OPCOST=U1I+EHT(IO,I)*PVHT+U2I+EAC(IO,I)*PVAC+U3I+EVT(IO,I)*PVVT
      CCOST=CSFF*PP2*PP3*PP4*(HVAC**CDEN)
250      IF(NN.LT.N) COVCOST=AIRC(L)
      IF(IO.GT.HALF) COVCOST=0.0
      LCC(IO,I)=OPCOST+CCOST+COVCOST
200 CONTINUE
190 CONTINUE
255 C
C      DETERMINE MINIMUM LCC AND CALC FUEL SHARES AND EUI'S
C
      DD 210 IO=1,NOBS
      MINT=1
260      ONC=LCC(IO,1)
      IF(LCC(IO,2).GT.ONC) GO TO 220
      MINT=2
      ONC=LCC(IO,2)
220 IF(LCC(IO,3).GT.ONC) GO TO 230
265      MINT=3
      ONC=LCC(IO,3)
230 IF(LCC(IO,4).GT.ONC) GO TO 240
      MINT=4
      ONC=LCC(IO,4)
270 240 CYS(MINT)=CYS(MINT)+CZWT(J)
      CYSAC(MINT)=CYSAC(MINT)+CZWT(J)*ACFLAG
      TOTSYS=TOTSYS+CZWT(J)
      SUMHT(MINT)=SUMHT(MINT)+EHT(IO,MINT)*CZWT(J)*EUI CZ(JJ)
      SUMAC(MINT)=SUMAC(MINT)+EAC(IO,MINT)*CZWT(J)*ACFLAG
275      SUMVT(MINT)=SUMVT(MINT)+EVT(IO,MINT)*CZWT(J)*VTFLAG
210 CONTINUE
180 CONTINUE
C
C      CALCULATE FUEL SHARES AND AVERAGE EUI'S
280 C
      NM=NN-1
      IF(NM.LE.0) NM=1
      A(1,1,NN)=((CYS(1)+CYS(2))/TOTSYS)*100.
      A(1,2,NN)=(CYS(3)/TOTSYS)*100.
285      A(1,3,NN)=(CYS(4)/TOTSYS)*100.

```

```

      IF(A(1,1,NN).EQ.0.0) GO TO 250
      HTMP=(SUMHT(1)+SUMHT(2))/(CYS(1)+CYS(2))
      IF(HTMP.EQ.0.0) E(1,1,NN)=E(1,1,NM)
      IF(HTMP.NE.0.0) E(1,1,NN)=HTMP
290      GO TO 260
      250 E(1,1,NN)=E(1,1,NM)
      260 DO 270 I=3,4
            IF(CYS(I).EQ.0.0) GO TO 280
            HTMP=SUMHT(I)/CYS(I)
295      IF(HTMP.EQ.0.0) E(1,I-1,NN)=E(1,I-1,NM)
            IF(HTMP.NE.0.0) E(1,I-1,NN)=HTMP
            GO TO 270
      280 E(1,I-1,NN)=E(1,I-1,NM)
      270 CONTINUE
300      ACSUM=0.0
            VTSUM=0.0
            DO 290 I=1,NNIH
            IF(CYSAC(I).EQ.0.0) GO TO 290
            ACSUM=ACSUM+(SUMAC(I)/CYSAC(I))*(CYS(I)/TOTSYS)
305      VTSUM=VTSUM+SUMVT(I)
      290 CONTINUE
            VTMP=VTSUM/TOTSYS
            IF(VTMP.GT.1.05) VTMP=1.05
            IF(ACSUM.EQ.0.0) E(2,1,NN)=E(2,1,NM)
310      IF(ACSUM.NE.0.0) E(2,1,NN)=ACSUM
            IF(VTMP.EQ.0.0) E(3,1,NN)=E(3,1,NM)
            IF(VTMP.NE.0.0) E(3,1,NN)=VTMP
            RETURN
C
315      C  FORMATS
      C
      5013 FORMAT("1ED DID NOT CONVERGE AFTER ",I2,
2          "ITERATIONS-DIF IS (",F10.5,")")
      5014 FORMAT("1ER DID NOT CONVERGE AFTER ",I2,
320      2          "ITERATIONS-DIF IS (",F10.5,")")
      END

```

APPENDIX C

Heat Load Simulation Results

Office - Portland

<u>Case</u>	<u>ENERGY</u> (MMBtu)						<u>COSTS</u> (Change \$/FT**2)			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHH	6,975	2,008	1,715	1,178	252	12,128	0	0	0	0
HHHL	949	2,049	1,715	1,178	252	6,143	0	0	.55	.75
HHLH	3,934	1,503	1,243	1,178	252	8,110	0	0	0	-.44
HLHH	6,514	1,718	1,510	841	252	10,835	0	-.665	0	-.26
LHHH	*									
LLLL	350	1,177	901	841	252	3,521	1.58	-.665	.55	-.25
LLLH	2,907	1,089	901	841	252	5,990	1.58	-.665	0	-.80
LLHL	888	1,497	1,246	891	252	4,724	1.58	-.665	.55	.11
LHLL	235	1,431	1,050	1,178	252	4,146	1.58	0	.55	-.07
HLLL	501	1,312	1,094	841	252	4,000	0	-.665	.55	.04
Base Cost:							1.63	2.20		5.20

*Case not run

S = Structure
L = Lighting
O = Operation
E = Equipment

STR - Change in structure components cost (KS)
LGT - Change in lighting costs (L)
REC - Change in cost for heat recovery (KE)
EQUIP - Change in HVAC cost (sizing)
H - High energy use
L - Low energy use

Hospital - Portland

<u>Case</u>	<u>ENERGY</u> (MMBtu)						<u>COSTS</u> (Change \$/FT**2)			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHH	20,375	1,520	5,365	11,444	6,016	44,720	0	0	0	0
HHHL	12,136	2,065	5,263	11,444	6,016	36,924	0	0	.93	.28
HHLH	21,771	1,123	3,917	11,444	6,016	44,271	0	0	0	-.26
HLHH	22,107	1,168	4,680	8,454	6,016	42,425	0	-.49	0	-.07
LHHH	*									
LLLL	10,468	1,286	3,130	8,454	6,016	29,354	.64	-.49	.93	-.31
LLLH	21,393	909	3,237	8,454	6,016	40,009	.64	-.49	0	-.47
LLHL	10,084	1,591	4,313	8,454	6,016	30,458	.64	-.49	.93	0
LHLL	10,204	1,719	3,647	11,444	6,016	33,030	.64	0	.93	-.15
HLLL	14,070	1,172	3,352	8,454	6,016	33,064	0	-.49	.93	.11
Base Cost:							.67	1.84		10.9

*Case not run

S = Structure
L = Lighting
O = Operation
E = Equipment

STR - Change in structure components cost (KS)
LGT - Change in lighting costs (L)
REC - Change in cost for heat recovery (KE)
EQUIP - Change in HVAC cost (sizing)
H - High energy use
L - Low energy use

School - Portland

<u>Case</u>	<u>ENERGY</u> <u>(MMBtu)</u>						<u>COSTS</u> <u>(Change \$/FT**2)</u>			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHH	7,016	71	638	527	43	8,295	0	0	0	0
HHHL	6,833	96	638	527	43	8,137	0	0	0	.70
HHLH	6,305	45	515	527	43	7,435	0	0	0	-.09
HLHH	7,185	50	580	351	43	8,209	0	-.625	0	-.07
LHHH	6,706	79	618	527	43	7,973	.88	0	0	-.07
LLLL	*									
LLLH	*									
LLHL	*									
LHLL	*									
HLLL	*									
Base Cost:							.84	1.20	4.60	

*Case not run

S = Structure

L = Lighting

O = Operation

E = Equipment

STR - Change in structure components cost (KS)

LGT - Change in lighting costs (L)

REC - Change in cost for heat recovery (KE)

EQUIP - Change in HVAC cost (sizing)

H - High energy use

L - Low energy use

Office - Yakima

<u>Case</u>	<u>ENERGY</u> (MMBtu)						<u>COSTS</u> (Change \$/FT**2)			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHH	7,362	1,843	1,672	1,178	253	12,308	0	0	0	0
HHHL	1,695	1,862	1,672	1,178	253	6,660	0	0	.55	.60
HHLH	4,108	1,338	1,209	1,178	253	8,086	0	0	0	-.48
HLHH	6,919	1,551	1,460	841	253	11,024	0	-.665	0	-.26
LHHH	5,944	1,560	1,388	1,178	253	10,323	1.58	0	0	-.46
LLLL	*									
LLLH	*									
LLHL	*									
LHLL	*									
HLLL	*									
Base Cost:							1.56	2.20	5.34	

*Case not run

S = Structure
L = Lighting
O = Operation
E = Equipment

STR - Change in structure components cost (KS)
LGT - Change in lighting costs (L)
REC - Change in cost for heat recovery (KE)
EQUIP - Change in HVAC cost (sizing)
H - High energy use
L - Low energy use

Hospital - Yakima

Case	ENERGY (MMBtu)						COSTS (Change \$/FT**2)			
	HEAT	COOL	AUX	LIGHTS	EQUIP	TOTAL	STR	LGT	REC	EQUIP
<u>S L O E</u>										
HHHH	30,089	1,585	5,191	11,444	6,016	54,325	0	0	0	0
HHHL	17,901	2,300	5,020	11,444	6,016	42,681	0	0	.93	.13
HHLH	30,055	1,173	3,794	11,444	6,016	52,482	0	0	0	-.32
HLHH	31,595	1,279	4,503	8,454	6,016	51,847	0	-.49	0	-.11
LHHH	26,703	1,547	4,870	11,444	6,016	50,580	.64	0	0	-.17
LLLL	*									
LLLH	*									
LLHL	*									
LHLL	*									
HLLL	*									
Base Cost:							.69	1.84	11.14	

*Case not run

S = Structure
L = Lighting
O = Operation
E = Equipment

STR - Change in structure components cost (KS)
LGT - Change in lighting costs (L)
REC - Change in cost for heat recovery (KE)
EQUIP - Change in HVAC cost (sizing)
H - High energy use
L - Low energy use

School - Yakima

<u>Case</u>	<u>ENERGY</u> (MMBtu)						<u>COSTS</u> (Change \$/FT**2)			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHH	8,234	71	644	527	43	9,519	0	0	0	0
HHHL	8,038	91	644	527	43	9,343	0	0	0	.60
HHLH	7,444	49	532	527	43	8,595	0	0	0	-.08
HLHH	8,415	52	589	351	43	9,450	0	-.62	0	-.07
LHHH	7,835	77	621	527	43	9,103	.88	0	0	-.10
LLLL	*									
LLLH	*									
LLHL	*									
LHLL	*									
HLLL	*									
Base Cost:							.84	1.90	5.03	

*Case not run

S = Structure
L = Lighting
O = Operation
E = Equipment

STR - Change in structure components cost (KS)
LGT - Change in lighting costs (L)
REC - Change in cost for heat recovery (KE)
EQUIP - Change in HVAC cost (sizing)
H - High energy use
L - Low energy use

Office - Heat Pump - Portland

<u>Case</u>	<u>ENERGY</u> <u>(MMBtu)</u>						<u>COSTS</u> <u>(Change \$/FT**2)</u>			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHHP	2,277	538	748	1,178	252	4,493	0	0	0	0
HLHHP	2,490	412	659	840	252	4,653	0	-.625	0	.11
HHLHP	1,231	222	533	1,178	252	3,416	0	0	0	.78
LHHHP	1,680	520	630	1,178	252	4,260	1.49	0	0	.96

S = Structure

L = Lighting

O = Operation

E = Equipment

STR - Change in structure components cost (KS)

LGT - Change in lighting costs (L)

REC - Change in cost for heat recovery

EQUIP - Change in HVAC cost (sizing) (KE)

H - High energy use

L - Low energy use

School - Heat Pump - Portland

<u>Case</u>	<u>ENERGY</u> <u>(MMBtu)</u>						<u>COSTS</u> <u>(Change \$/FT**2)</u>			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHHP	4,673	99	567	527	43	5,909	0	0	0	0
HLHHP	4,708	76	512	351	43	5,690	0	-.62	0	-.22
HHLHP	3,945	85	448	527	43	5,048	0	0	0	-.53
LHHHP	4,559	105	549	527	43	5,783	.88	0	0	-.07

S = Structure

L = Lighting

O = Operation

E = Equipment

STR - Change in structure components cost (KS)

LGT - Change in lighting costs (L)

REC - Change in cost for heat recovery

EQUIP - Change in HVAC cost (sizing) (KE)

H - High energy use

L - Low energy use

Office - Heat Pump - Yakima

<u>Case</u>	<u>ENERGY</u> (MMBtu)						<u>COSTS</u> (Change \$/FT**2)			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHHP	2,862	503	733	1,177	252	5,527	0	0	0	0
HLHHP	3,098	394	642	840	252	5,226	0	-.625	0	-.53
HHLHP	1,628	478	522	1,177	252	4,057	0	0	0	-.69
LHHHP	2,119	445	606	1,177	252	4,599	1.49	0	0	-.51

S = Structure

L = Lighting

O = Operation

E = Equipment

STR - Change in structure components cost (KS)

LGT - Change in lighting costs (L)

REC - Change in cost for heat recovery

EQUIP - Change in HVAC cost (sizing) (KE)

H - High energy use

L - Low energy use

School - Heat Pump - Yakima

<u>Case</u>	<u>ENERGY</u> <u>(MMBtu)</u>						<u>COSTS</u> <u>(Change \$/FT**2)</u>			
	<u>HEAT</u>	<u>COOL</u>	<u>AUX</u>	<u>LIGHTS</u>	<u>EQUIP</u>	<u>TOTAL</u>	<u>STR</u>	<u>LGT</u>	<u>REC</u>	<u>EQUIP</u>
<u>S L O E</u>										
HHHHP	4,259	113	545	527	43	5,487	0	0	0	0
HLHHP	4,297	90	492	351	43	5,273	0	-.62	0	-.15
HHLHP	3,719	98	434	527	43	4,821	0	0	0	-.55
LHHHP	4,158	117	527	527	43	5,373	.88	0	0	0

S = Structure

L = Lighting

O = Operation

E = Equipment

STR - Change in structure components cost (KS)

LGT - Change in lighting costs (L)

REC - Change in cost for heat recovery (KE)

EQUIP - Change in HVAC cost (sizing)

H - High energy use

L - Low energy use